


TRONOX

Fredrick R. Stater
Plant Manager

(702) 651-2233
Fax (405) 302-4607
rick.stater@tronox.com

April 26, 2007



NPDES Compliance Coordinator
Nevada Division of Environmental Protection
Bureau of Water Permits & Compliance
901 South Stewart Street, Suite 4001
Carson City, NV 89701-5249

SUBJECT: First Quarter 2007 DMR - NPDES Permit # NV0000078

Tronox LLC (Tronox) maintains an NPDES Permit #NV0000078 covering its production operations in Henderson, Nevada. The attached Discharge Monitoring Reports (Attachment 1) reflect discharge from the Tronox Henderson facility as monitored by NPDES equipment. Stabilized water, from water leaks, discharged through the outfalls for brief periods and are quantified in Table 1a, below. A storm water discharge is quantified in Table 1b, below.

Table 1a. Non-Storm Flow Totals

Outfall	January Flow (thousands of gallons)	February Flow (thousands of gallons)	March Flow (thousands of gallons)
001	78	0	0
002	309	0	19
003	0	0	0

Table 1b. Stormwater Flow Totals (thousands of gallons)

Outfall	1-5-07 (thousands of gallons)	2-14-07 (thousands of gallons)	2-20-07 (thousands of gallons)
001	2.5	19.8	147
002	0.8	4.8	14.5
003	0	0	0

Analytical associated with outfall flow is attached to this report. Should you have any questions concerning this report, please contact Susan M. Crowley at (702) 651-2234 or e-mail susan.crowley@tronox.com. Thank you.

Sincerely,


Fredrick R. Stater
Plant Manager

Overnight Mail

cc: Susan Crowley
Elizabeth Hurst
Mr. Carey Houk (W-5-3)/U.S. EPA Region

Attachments

Tronox LLC

8000 West Lake Mead Parkway, Henderson, Nevada 89015 • P.O. Box 55, Henderson, Nevada 89009

TRONOX

Fredrick R. Stater
Plant Manager

(702) 651-2233
Fax (405) 302-4607
rick.stater@tronox.com

April 26, 2007

NPDES Compliance Coordinator
Nevada Division of Environmental Protection
Bureau of Water Permits & Compliance
901 South Stewart Street, Suite 4001
Carson City, NV 89701-5249

SUBJECT: First Quarter 2007 DMR - NPDES Permit # NV0000078

Tronox LLC (Tronox) maintains an NPDES Permit #NV0000078 covering its production operations in Henderson, Nevada. The attached Discharge Monitoring Reports (Attachment 1) reflect discharge from the Tronox Henderson facility as monitored by NPDES equipment. Stabilized water, from water leaks, discharged through the outfalls for brief periods and are quantified in Table 1a, below. A storm water discharge is quantified in Table 1b, below.

Table 1a. Non-Storm Flow Totals


Outfall	January Flow (thousands of gallons)	February Flow (thousands of gallons)	March Flow (thousands of gallons)
001	78	0	0
002	309	0	19
003	0	0	0

Table 1b. Stormwater Flow Totals (thousands of gallons)

Outfall	1-5-07 (thousands of gallons)	2-14-07 (thousands of gallons)	2-20-07 (thousands of gallons)
001	2.5	19.8	147
002	0.8	4.8	14.5
003	0	0	0

Analytical associated with outfall flow is attached to this report. Should you have any questions concerning this report, please contact Susan M. Crowley at (702) 651-2234 or e-mail susan.crowley@tronox.com. Thank you.

Sincerely,


Fredrick R. Stater
Plant Manager

Overnight Mail

cc: Susan Crowley
Elizabeth Hurst
Mr. Carey Houk (W-5-3)/U.S. EPA Region

Attachments

Tronox LLC

8000 West Lake Mead Parkway, Henderson, Nevada 89015 • P.O. Box 55, Henderson, Nevada 89009

ATTACHMENT 1

Discharge Monitoring Reports



C:\smc\My
Documents\Excel Spr

January 2007



C:\smc\My
Documents\Excel Spr

February 2007



C:\smc\My
Documents\Excel Spr

March 2007

PERMITTEE NAME/ADDRESS:
 NAME: Tronox LLC
 ADDRESS: PO Box 55
 Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

PERMIT NUMBER: NV0000078
 DISCHARGE NUMBER: 001 A

DISCHARGE - 001

F - FINAL
 MAJOR

FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

MONITORING PERIOD

FROM 07 | 01 | 01 TO 07 | 01 | 31

NO DISCHARGE

NOTE: Read instructions before completing this form

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNIT
TEMPERATURE, WATER DEG. CENTIGRADE	*****	*****	****	*****	18	19	0			
00010 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	33 30DA AVG	37 DAILY MX	0	CONTIN UOUS	RCORDR	
pH	*****	*****	****	8.2	*****	8.2	0			
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	6.0 MINIMUM	*****	9.0 MAXIMUM	0	ONCE/ DISCHG	DISCRT	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.019	0.057	(03)	*****	*****	*****	0			
50050 1 0 0 EFFLUENT GROSS VALUE	OPTIONAL REPORT 30DA AVG	REPORT DAILY MX	MGD	*****	*****	*****	0	CONTIN UOUS	RCORDR	
SOLIDS, TOTAL DISSOLVED	0.7	1.9	(26)	*****	4	4	0			
70295 > 0 0 INCREASE (NOT END OF PIPE)	1000 REPORT 30DA AVG	REPORT DAILY MX	LBS/DY	*****	REPORT 30DA AVG	REPORT DAILY MX	0	ONCE/ DISCHG	DISCRT	
PERCHLORATE (C104)	*****	*****	****	*****	0.027	0.027	0			
61209 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL REPORT 30DA AVG	REPORT DAILY MX	0	ONCE/ DISCHG	DISCRT	
	*****	*****	****	*****	*****	*****				
	*****	*****	****	*****	*****	*****		ONCE/ DISCHG	DISCRT	
	*****	*****	****	*****	*****	*****		ONCE/ DISCHG	DISCRT	
	*****	*****	****	*****	*****	*****		ONCE/ DISCHG	DISCRT	
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROGRAMS ARE SUBMITTED BASED ON THE REQUIREMENT OF THE PERMIT OR PERSONS WHO MANAGE THE FACILITY OR RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS TO THE BEST OF MY KNOWLEDGE AND BELIEF TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.			4-26-07 SWM			702-651-2200	07 04 26	TELEPHONE	DATE
Fredrick R. Stater	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			702-651-2200			07 04 26	AREA CODE NUMBER	YEAR MO DAY	
Plant Manager	TYPED OR PRINTED			OFFICER OR AUTHORIZED AGENT						

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Form by WinrowChem(707)864-0845;print1080;v5.01;4/17/96

PERMITTEE NAME/ADDRESS: Tronox LLC
 NAME: Tronox LLC
 ADDRESS: PO Box 55
 Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 002 A
 DISCHARGE NUMBER

DISCHARGE 002
 F - FINAL
 MAJOR

FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

MONITORING PERIOD
 FROM 07 | 01 | 01 TO 07 | 01 | 31

NO DISCHARGE
 NOTE: Read instructions before completing this form

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	NO. FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. CENTIGRADE	*****	*****	****	*****	18	19	0		
00010 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	33 30DA AVG	37 DAILY MX	0	CONTIN UOUS	RECORD
pH	*****	*****	****	*****	8.3	8.2	0		
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	6.0 MINIMUM	9.0 MAXIMUM	0	ONCE/ DISCHG	DISCRT
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.024	0.227	(03)	*****	*****	*****	0		
50050 1 0 0 EFFLUENT GROSS VALUE	OPTIONAL 30DA AVG	REPORT DAILY MX	MGD	*****	*****	*****	0	CONTIN UOUS	RECORD
SOLIDS, TOTAL DISSOLVED	1.18	19.20	(26)	*****	6	10	0		
70295 > 0 0 INCREASE (NOT END OF PIPE)	1000 30DA AVG	REPORT DAILY MX	LBS/DY	*****	REPORT 30DA AVG	REPORT DAILY MX	0	ONCE/ DISCHG	DISCRT
PERCHLORATE (C104)	*****	*****	****	*****	0.010	0.015	0		
61209 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	REPORT DAILY MX	0	ONCE/ DISCHG	DISCRT
	*****	*****	****	*****	*****	*****			
	*****	*****	****	*****	*****	*****			
	*****	*****	****	*****	*****	*****			
	*****	*****	****	*****	*****	*****			
	*****	*****	****	*****	*****	*****			
	*****	*****	****	*****	*****	*****			
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER				4-26-07			TELEPHONE	DATE	
Fredrick R. Stater				50N			702-651-2200	07 04 26	
Plant Manager				SIGNATURE OF PRINCIPAL EXECUTIVE			AREA CODE NUMBER	YEAR MO DAY	
TYPED OR PRINTED				OFFICER OR AUTHORIZED AGENT			702-651-2200	07 04 26	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS:
 NAME: Tronox LLC
 ADDRESS: PO Box 55
 Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

001 STORMWATER MONITORING
 DISCHARGE NUMBER
 001 B
 PERMIT NUMBER
 NV0000078

F - FINAL

FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

MONITORING PERIOD
 FROM 07 | 01 | 01 TO 07 | 01 | 31

MAJOR
 NO DISCHARGE

NOTE: Read instructions before completing this form

PARAMETER	QUANTITY OR LOADING				QUALITY OR CONCENTRATION				NO. EX	NO. FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNIT	MINIMUM			
pH	*****	*****	****	8.2	*****	(12)	0				
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	REPORT MINIMUM	REPORT MAXIMUM	SU	0	ONCE DISCHG	DISORT		
SOLIDS, TOTAL SUSPENDED	*****	*****	****	*****	14	(19)	0				
00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE DISCHG	DISORT		
NITROGEN, AMMONIA TOTAL (AS N)	*****	*****	****	*****	0.201	(19)	0				
00610 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE DISCHG	DISORT		
NITRITE PLUS NITRATE TOTAL 1 DET. (AS N)	*****	*****	****	*****	0.9	(19)	0				
00630 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE DISCHG	DISORT		
PHOSPHORUS, TOTAL (AS P)	*****	*****	****	*****	0.032	(19)	0				
00665 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE DISCHG	DISORT		
OIL AND GREASE	*****	*****	****	*****		(19)	0				
03582 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE DISCHG	DISORT		
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.001	0.001	(03)	*****	*****	MG/L	0				
50050 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	*****	MG/L	0	ONCE DISCHG	DISORT		
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	Fredrick R. Stater Plant Manager 4-2607 TELEPHONE										
COMMENT AND EXPLANATION OF ANY VIOLATIONS	TYPED OR PRINTED OFFICER OR AUTHORIZED AGENT SIGNATURE OF PRINCIPAL EXECUTIVE 702-651-2200 AREA CODE NUMBER 07 04 26 YEAR MO DAY										

CHERRY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED BY AN EMPLOYEE OF THE PERMITTEE OR SUPERVISOR IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED BASED ON AN INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.

PERMITTEE NAME/ADDRESS:
 NAME: Tronox LLC
 ADDRESS: PO Box 55
 Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

DISCHARGE NUMBER: 002 B
 PERMIT NUMBER: NV0000078

002 STORMWATER MONITORING

F - FINAL

FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

MONITORING PERIOD
 FROM 07 | 01 | 01 TO 07 | 01 | 31

MAJOR
 NO DISCHARGE

NOTE: Read instructions before completing this form

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	NO. FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
pH	MEASUREMENT	*****	*****	****	8.2	*****	(12)	0		
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	REPORT MINIMUM	REPORT MAXIMUM	SU		ONCE/DISCHG	DISORT
SOLIDS, TOTAL SUSPENDED	MEASUREMENT	*****	*****	****	*****	40	(19)	0		
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L		ONCE/DISCHG	DISORT
NITROGEN, AMMONIA TOTAL (AS N)	MEASUREMENT	*****	*****	****	*****	0.21	(19)	0		
00610 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT DAILY MX	MG/L		ONCE/DISCHG	DISORT
NITRITE PLUS NITRATE TOTAL 1 DET. (AS N)	MEASUREMENT	*****	*****	****	*****	0.90	(19)	0		
00630 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT DAILY MX	MG/L		ONCE/DISCHG	DISORT
PHOSPHORUS, TOTAL (AS P)	MEASUREMENT	*****	*****	****	*****	0.02	(19)	0		
00665 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L		ONCE/DISCHG	DISORT
OIL AND GREASE	MEASUREMENT	*****	*****	****	*****	ND	(19)	0		
03582 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT DAILY MX	MG/L		ONCE/DISCHG	DISORT
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	MEASUREMENT	<0.001	<0.001	(03)	*****	*****	****	0		
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	****	0		

NAME / TITLE: PRINCIPAL EXECUTIVE OFFICER
Fredrick R. Stater
 TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER: *Fredrick R. Stater* 4-26-07
 OFFICER OR AUTHORIZED AGENT

TELEPHONE: 702-651-2200
 DATE: 07 | 04 | 26

AREA CODE NUMBER: 702-651-2200
 YEAR: 07 | MO: 04 | DAY: 26

FORM BY: WindowChem(707)964-0845;pin1090c;v5.01;4/1/96

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS:
 NAME: Tronox LLC
 ADDRESS: PO Box 55
 Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

003 STORMWATER MONITORING
 F - FINAL
 MAJOR
 NO DISCHARGE
 NOTE: Read instructions before completing this form

PERMIT NUMBER: NV0000078
 DISCHARGE NUMBER: 003 B
 MONITORING PERIOD: FROM 07 | 01 | 01 TO 07 | 01 | 31
 FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
pH	*****	*****	****	*****	*****	(12)	0		
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	REPORT MINIMUM	REPORT MAXIMUM	SU	0	ONCE DISCHG	DISCRT
SULFATE, TOTAL (AS SO4)	*****	*****	****	*****	*****	(19)	0		
00945 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE DISCHG	DISCRT
MANGANESE, TOTAL (AS MN)	*****	*****	****	*****	*****	(19)	0		
01055 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE DISCHG	DISCRT
SOLIDS, TOTAL DISSOLVED	*****	*****	****	*****	OPTIONAL 30DA AVG	(19)	0		
70295 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE DISCHG	DISCRT
PERCHLORATE (CLO4)	*****	*****	****	*****	*****	(19)	0		
61209 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE DISCHG	DISCRT

NAME / TITLE: PRINCIPAL EXECUTIVE OFFICER
 Fredrick R. Stater
 Plant Manager
 TYPED OR PRINTED

OFFICER OR AUTHORIZED AGENT
 SIGNATURE OF PRINCIPAL EXECUTIVE
 4-26-07
 gnu

TELEPHONE: 702-651-2200
 DATE: 07 | 04 | 26

AREA CODE NUMBER: 702-651-2200
 YEAR: 07
 MO: 04
 DAY: 26

COMMENT AND EXPLANATION OF ANY VIOLATIONS
 No Discharge

(Reference all attachments here)

PERMITTEE NAME/ADDRESS:
 NAME: Tronox LLC
 ADDRESS: PO Box 55
 Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 001 A
 DISCHARGE NUMBER

DISCHARGE - 001
 F - FINAL
 MAJOR

FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

MONITORING PERIOD
 FROM 07 | 02 | 01 TO 07 | 02 | 28

NO DISCHARGE
 NOTE: Read instructions before completing this form

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. FREQUENCY OF EX ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM		
TEMPERATURE, WATER DEG. CENTIGRADE	*****	*****	****	*****		(04)	0	
00010 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	33 30DA AVG	DAILY MX	CONTIN UOUS	RECORD
pH	*****	*****	****	*****		(12)	0	
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	6.0 MINIMUM	MAXIMUM	ONCE/ DISCHG	DISCRT
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	*****	*****	(03)	*****		SU	0	
50050 1 0 0 EFFLUENT GROSS VALUE	*****	*****	MGD	*****		****	CONTIN UOUS	RECORD
SOLIDS, TOTAL DISSOLVED	*****	*****	(26)	*****		(19)	0	
70295 > 0 0 INCREASE (NOT END OF PIPE)	*****	*****	LBS/DY	*****	REPORT 1000 30DA AVG	DAILY MX	ONCE/ DISCHG	DISCRT
PERCHLORATE (CIO4)	*****	*****		*****		(19)	0	
61209 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	DAILY MX	ONCE/ DISCHG	DISCRT
	*****	*****	****	*****		(19)		
	*****	*****	****	*****		MG/L	ONCE/ DISCHG	DISCRT
	*****	*****	****	*****		MG/L		
	*****	*****	****	*****		MG/L	ONCE/ DISCHG	DISCRT
	*****	*****	****	*****		MG/L		
	*****	*****	****	*****		MG/L	ONCE/ DISCHG	DISCRT
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER				4-20-01			TELEPHONE	DATE
Frederick R. Stater				[Signature]				
Plant Manager				SIGNATURE OF PRINCIPAL EXECUTIVE			702-561-2200	07 04 26
TYPED OR PRINTED				OFFICER OR AUTHORIZED AGENT			AREA CODE NUMBER	YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Form by WindowChem(707)884-0845;pn11050v5.01-9/196

PERMITTEE NAME/ADDRESS:
 NAME: Tronox LLC
 ADDRESS: PO Box 55
 Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

DISCHARGE 002
 F - FINAL MAJOR
 002 A
 DISCHARGE NUMBER
 NV0000078
 PERMIT NUMBER

FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

MONITORING PERIOD

FROM 07 | 02 | 01 TO 07 | 02 | 28

NO DISCHARGE

NOTE: Read instructions before completing this form

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	NO. FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
TEMPERATURE, WATER DEG. CENTIGRADE	*****	*****	****	*****	*****	(04)	0		
00010 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	33 30DA AVG	DAILY MX	0	CONTIN UOUS	REORDR
pH	*****	*****	****	*****	*****	(12)	0		
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	6.0 MINIMUM	MAXIMUM SU	0	ONCE/ DISCHG	DISCRT
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	*****	*****	(03)	*****	*****	*****	0		
50050 1 0 0 EFFLUENT GROSS VALUE	*****	*****	MGD	*****	*****	*****	0	CONTIN UOUS	REORDR
SOLIDS, TOTAL DISSOLVED	*****	*****	(26)	*****	*****	(19)	0		
70295 > 0 0 INCREASE (NOT END OF PIPE)	*****	*****	LBS/DY	*****	*****	*****	0	ONCE/ DISCHG	DISCRT
PERCHLORATE (C104)	*****	*****	****	*****	*****	*****	0		
61209 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	*****	*****	0	ONCE/ DISCHG	DISCRT
	*****	*****	****	*****	*****	*****	0		
	*****	*****	****	*****	*****	*****	0	ONCE/ DISCHG	DISCRT
	*****	*****	****	*****	*****	*****	0	ONCE/ DISCHG	DISCRT

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER
Fredrick R. Stater
 Plant Manager
 TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
[Signature]
 OFFICER OR AUTHORIZED AGENT

702-651-2200
 AREA CODE NUMBER

07 | 04 | 26
 YEAR MO DAY

702-651-2200
 TELEPHONE

DATE

I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY OBTAIN AND EVALUATE THE INFORMATION SUBMITTED BASED ON MY PERSONAL KNOWLEDGE AND BELIEVE IT IS ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SEVERAL PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.

COMMENT AND EXPLANATION OF ANY VIOLATIONS
 (Reference all attachments here)

PERMITTEE NAME/ADDRESS: Tronox LLC
 NAME: PO Box 55
 ADDRESS: Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

001 B
 DISCHARGE NUMBER

NV0000078
 PERMIT NUMBER

001 STORMWATER MONITORING
 F - FINAL

FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

MONITORING PERIOD
 FROM 07 | 02 | 01 TO 07 | 02 | 28

MAJOR
 NO DISCHARGE

NOTE: Read instructions before completing this form

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
pH	*****	*****	****	8.2	*****	8.5	(12)	0	
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	REPORT MINIMUM	*****	REPORT MAXIMUM	SU	0	ONCE/ DISCHG
SOLIDS, TOTAL SUSPENDED	*****	*****	****	*****	*****	14	(19)	0	
00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	*****	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG
NITROGEN, AMMONIA TOTAL (AS N)	*****	*****	****	*****	*****	0.06	(19)	0	
00610 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	*****	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG
NITRITE PLUS NITRATE TOTAL 1 DET. (AS N)	*****	*****	****	*****	*****	1.6	(19)	0	
00630 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	*****	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG
PHOSPHORUS, TOTAL (AS P)	*****	*****	****	*****	*****	0.2	(19)	0	
00665 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	*****	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG
OIL AND GREASE	*****	*****	****	*****	*****	ND	(19)	0	
03582 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	*****	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.027	0.141	(03)	*****	*****	*****	MG/L	0	
50050 1 0 0 EFFLUENT GROSS VALUE	*****	*****	MGD	*****	*****	*****	*****	0	CONTIN UOUS
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	Fredrick R. Stater		SIGNATURE OF PRINCIPAL EXECUTIVE		OFFICER OR AUTHORIZED AGENT		TELEPHONE	DATE	
TYPED OR PRINTED	Fredrick R. Stater		4-26-01		5/26/01		702-651-2200	07 04 26	
COMMENT AND EXPLANATION OF ANY VIOLATIONS	(Reference all attachments here)		AREA CODE NUMBER		YEAR MO DAY		702-651-2200	07 04 26	

I HEREBY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED BASED ON AN INQUIRY OF THE PERSONS OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION. THE INFORMATION SUBMITTED IS TO THE BEST OF MY KNOWLEDGE AND BELIEF TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.

PERMITTEE NAME/ADDRESS: Tronox LLC
 NAME: Tronox LLC
 ADDRESS: PO Box 55
 Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)
 002 B
 DISCHARGE NUMBER

002 STORMWATER MONITORING

F - FINAL

FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

MONITORING PERIOD
 FROM 07 | 02 | 01 TO 07 | 02 | 28

MAJOR
 NO DISCHARGE

NOTE: Read instructions before completing this form

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	NO. FREQUENCY OF ANALYSIS	SAMPLE TYPE		
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM				UNIT	
PH	*****	*****	****	8.1	*****	8.4	(12)	0			
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	REPORT MINIMUM	*****	REPORT MAXIMUM	SU	ONCE DISCHG	DISCRT		
SOLIDS, TOTAL SUSPENDED	*****	*****	****	*****	*****	17	(19)	0			
00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	REPORT DAILY MX	MG/L	ONCE DISCHG	DISCRT		
NITROGEN, AMMONIA TOTAL (AS N)	*****	*****	****	*****	*****	0.374	(19)	0			
00610 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	REPORT DAILY MX	MG/L	ONCE DISCHG	DISCRT		
NITRITE PLUS NITRATE TOTAL 1 DET. (AS N)	*****	*****	****	*****	*****	0.63	(19)	0			
00630 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	REPORT DAILY MX	MG/L	ONCE DISCHG	DISCRT		
PHOSPHORUS, TOTAL (AS P)	*****	*****	****	*****	*****	0.14	(19)	0			
00665 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	REPORT DAILY MX	MG/L	ONCE DISCHG	DISCRT		
OIL AND GREASE	*****	*****	****	*****	*****	ND	(19)	0			
03582 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	REPORT DAILY MX	MG/L	ONCE DISCHG	DISCRT		
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.002	0.012	(03)	*****	*****	*****	MG/L	0			
50050 1 0 0 EFFLUENT GROSS VALUE	REPORT 30DA AVG	REPORT DAILY MX	MGD	*****	*****	*****	****	0	CONTIN UOUS		
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER				4-26-07			TELEPHONE	YEAR	MO	DATE	
Fredrick R. Stater				69MC			702-651-2200	07	04	26	
Plant Manager				SIGNATURE OF PRINCIPAL EXECUTIVE			AREA CODE NUMBER	YEAR	MO	DAY	
TYPED OR PRINTED				OFFICER OR AUTHORIZED AGENT			702-651-2200	702-651-2200	07	04	26

COMMENTS: (Reference all attachments here)

PERMITTEE NAME/ADDRESS: **Tronox LLC**
Tronox LLC
PO Box 55
Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)
003 B
003 STORMWATER MONITORING
DISCHARGE NUMBER

PERMIT NUMBER: **NV0000078**

FACILITY: **Tronox LLC**
 LOCATION: **BMI Park - Henderson**
 Attn: **Susan Crowley**

MAJOR
NO DISCHARGE

NOTE: Read instructions before completing this form

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
pH	*****	*****	****	*****	*****	(12)	0		
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	REPORT MINIMUM	REPORT MAXIMUM	SU	0	ONCE DISCHG	DISCRT
SULFATE, TOTAL (AS SO4)	*****	*****	****	*****	*****	(19)	0		
00945 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	REPORT DAILY MX	MG/L	0	ONCE DISCHG	DISCRT
MANGANESE, TOTAL (AS MN)	*****	*****	****	*****	*****	(19)	0		
01055 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	REPORT DAILY MX	MG/L	0	ONCE DISCHG	DISCRT
SOLIDS, TOTAL DISSOLVED	*****	*****	****	*****	*****	(19)	0		
70295 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	REPORT DAILY MX	MG/L	0	ONCE DISCHG	DISCRT
PERCHLORATE (CLO4)	*****	*****	****	*****	*****	(19)	0		
61209 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	REPORT DAILY MX	MG/L	0	ONCE DISCHG	DISCRT

NAME / TITLE: **Fredrick R. Stater**
Principal Executive Officer

DATE: **4-26-07**

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER: *[Signature]*

OFFICER OR AUTHORIZED AGENT: **4-26-07**

TELEPHONE: **702-651-2200**

AREA CODE NUMBER: **702**

YEAR: **07** | MO: **04** | DAY: **26**

TYPED OR PRINTED: **Plant Manager**

COMMENT AND EXPLANATION OF ANY VIOLATIONS: **No Discharge**

(Reference all attachments here)

PERMITTEE NAME/ADDRESS:
 NAME: Tronox LLC
 ADDRESS: PO Box 55
 Henderson, NV 89009-7000


NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 PERMIT NUMBER: NV0000078
 DISCHARGE NUMBER: 001 A

DISCHARGE - 001
 F - FINAL
 MAJOR

FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

MONITORING PERIOD
 FROM 07 | 03 | 01 TO 07 | 03 | 31

NO DISCHARGE X
 NOTE: Read instructions before completing this form

PARAMETER	QUANTITY OR LOADING				QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
	AVERAGE	MAXIMUM	UNITS	MEASUREMENT	MINIMUM	AVERAGE	MAXIMUM	UNIT				
TEMPERATURE, WATER DEG. CENTIGRADE	*****	*****	****	SAMPLE MEASUREMENT	*****	*****	(04)		0			
00010 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	PERMIT REQUIREMENT	*****	33 30DA AVG	37 DAILY MX	DEG. C	0	CONTIN UOUS	ACORDR	
pH	*****	*****	****	SAMPLE MEASUREMENT	*****	*****	(12)		0			
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	PERMIT REQUIREMENT	*****	6.0 MINIMUM	9.0 MAXIMUM	SU	0	ONCE/ DISCHG	DISCRT	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	*****	*****	(03)	SAMPLE MEASUREMENT	*****	*****	*****	****	0			
50050 1 0 0 EFFLUENT GROSS VALUE	*****	*****	MGD	PERMIT REQUIREMENT	*****	*****	*****	****	0	CONTIN UOUS	ACORDR	
SOLIDS, TOTAL DISSOLVED	*****	*****	(26)	SAMPLE MEASUREMENT	*****	*****	(19)	****	0			
70295 > 0 0 INCREASE (NOT END OF PIPE)	*****	*****	LBS/DY	PERMIT REQUIREMENT	*****	*****	*****	MG/L	0	ONCE/ DISCHG	DISCRT	
PERCHLORATE (C104)	*****	*****	*****	SAMPLE MEASUREMENT	*****	*****	(19)	MG/L	0			
61209 1 0 0 EFFLUENT GROSS VALUE	*****	*****	*****	PERMIT REQUIREMENT	*****	*****	*****	MG/L	0	ONCE/ DISCHG	DISCRT	
	*****	*****	*****	SAMPLE MEASUREMENT	*****	*****	(19)	MG/L	0			
	*****	*****	*****	PERMIT REQUIREMENT	*****	*****	*****	MG/L	0	ONCE/ DISCHG	DISCRT	
	*****	*****	*****	SAMPLE MEASUREMENT	*****	*****	*****	MG/L	0			
	*****	*****	*****	PERMIT REQUIREMENT	*****	*****	*****	MG/L	0	ONCE/ DISCHG	DISCRT	
	*****	*****	*****	SAMPLE MEASUREMENT	*****	*****	*****	MG/L	0			
	*****	*****	*****	PERMIT REQUIREMENT	*****	*****	*****	MG/L	0	ONCE/ DISCHG	DISCRT	
NAME / TITLE: PRINCIPAL EXECUTIVE OFFICER Fredrick R. Stater Plant Manager TYPED OR PRINTED											TELEPHONE	DATE
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)											702-651-2200	07 04 26
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 											AREA CODE NUMBER	YEAR MO DAY
											702-651-2200	07 04 26

I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT THE INFORMATION REPORTED IS TRUE AND CORRECT. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.

PERMITTEE NAME/ADDRESS:
 NAME: Tronox LLC
 ADDRESS: PO Box 55
 Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

DISCHARGE 002
 F - FINAL
 MAJOR


FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

MONITORING PERIOD

FROM 07 | 03 | 01 TO 07 | 03 | 31

NO DISCHARGE

NOTE: Read instructions before completing this form

PARAMETER	QUANTITY OR LOADING				QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNIT	MINIMUM			
TEMPERATURE, WATER DEG. CENTIGRADE	*****	*****	****	*****	18	19	(04)	0			
00010 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	33 30DA AVG	37 DAILY MX	DEG. C	0	CONTIN UOUS	RCORDR	
pH	*****	*****	****	*****	8.2	8.1	(12)	0			
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	6.0 MINIMUM	9.0 MAXIMUM	SU	0	ONCE/ DISCHG	DISCRT	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	0.001	0.004	(03)	*****	*****	*****	****	0	CONTIN UOUS	RCORDR	
50050 1 0 0 EFFLUENT GROSS VALUE	OPTIONAL 30DA AVG	REPORT DAILY MX	MGD	*****	*****	*****	****	0	CONTIN UOUS	RCORDR	
SOLIDS, TOTAL DISSOLVED	0.14	0.67	(26)	*****	16	36	(19)	0			
70295 > 0 0 INCREASE (NOT END OF PIPE)	1000 30DA AVG	REPORT DAILY MX	LBS/DY	*****	REPORT 30DA AVG	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG	DISCRT	
PERCHLORATE (ClO4)	*****	*****	****	*****	0.004	0.007	(19)	0			
61209 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG	DISCRT	
	*****	*****	****	*****	*****	*****	*****				
	*****	*****	****	*****	*****	*****	*****				
	*****	*****	****	*****	*****	*****	*****				
	*****	*****	****	*****	*****	*****	*****				
	*****	*****	****	*****	*****	*****	*****				
	*****	*****	****	*****	*****	*****	*****				
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER Fredrick R. Stater Plant Manager TYPED OR PRINTED											
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)											
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER  OFFICER OR AUTHORIZED AGENT											
TELEPHONE DATE 702-651-2200 07 04 26 AREA CODE NUMBER YEAR MO DAY											

FORMS BY WINDOWCHEM(707)865-0845;PINT1080;V5.01.4/1/96

PERMITTEE NAME/ADDRESS: Tronox LLC
 NAME: Tronox LLC
 ADDRESS: PO Box 55
 Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

001 B
 DISCHARGE NUMBER

NV0000078
 PERMIT NUMBER

001 STORMWATER MONITORING

F - FINAL

MAJOR

NO DISCHARGE

NOTE: Read instructions before completing this form

MONITORING PERIOD
 FROM 07 | 03 | 01 TO 07 | 03 | 31

FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	UNITS	AVERAGE	MAXIMUM	UNIT			
pH	*****	*****	****	*****		(12)	0		
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	REPORT MINIMUM	REPORT MAXIMUM	SU	0	ONCE/ DISCHG	DISCRT
SOLIDS, TOTAL SUSPENDED	*****	*****	****	*****		(19)	0		
00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	OPTIONAL 30DA AVG	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG	DISCRT
NITROGEN, AMMONIA TOTAL (AS N)	*****	*****	****	*****		(19)	0		
00610 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	OPTIONAL 30DA AVG	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG	DISCRT
NITRITE PLUS NITRATE TOTAL 1 DET. (AS N)	*****	*****	****	*****		(19)	0		
00630 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	OPTIONAL 30DA AVG	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG	DISCRT
PHOSPHORUS, TOTAL (AS P)	*****	*****	****	*****		(19)	0		
00665 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	OPTIONAL 30DA AVG	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG	DISCRT
OIL AND GREASE	*****	*****	****	*****		(19)	0		
03582 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	OPTIONAL 30DA AVG	REPORT DAILY MX	MG/L	0	ONCE/ DISCHG	DISCRT
FLOW, IN CONDUIT OR THRU TREATMENT PLANT			(03)	*****	*****		0		
50050 1 0 0 EFFLUENT GROSS VALUE	REPORT 30DA AVG	REPORT DAILY MX	MGD	*****	*****		0	CONTIN UOUS	RECORD

NAME / TITLE: PRINCIPAL EXECUTIVE OFFICER
Fredrick R. Stater
 Plant Manager
 TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER
Fredrick R. Stater
 OFFICER OR AUTHORIZED AGENT

TELEPHONE: 702-651-2200
 DATE: 07 | 04 | 26

COMMENT AND EXPLANATION OF ANY VIOLATIONS
 (Reference all attachments here)

PERMITTEE NAME/ADDRESS: Tronox LLC
 NAME: PO Box 55
 ADDRESS: Henderson, NV 89009-7000

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)
 002 B
 DISCHARGE NUMBER

002 STORMWATER MONITORING
 F - FINAL

FACILITY: Tronox LLC
 LOCATION: BMI Park - Henderson
 Attn: Susan Crowley

MONITORING PERIOD
 FROM 07 | 03 | 01 TO 07 | 03 | 31

MAJOR NO DISCHARGE X

NOTE: Read instructions before completing this form

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	NO. FREQUENCY OF ANALYSIS	SAMPLE TYPE
	AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM			
pH	*****	*****	****	*****	*****	(12)	0	ONCE/DISCHG	
00400 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	REPORT MINIMUM	REPORT MAXIMUM	SU	0	ONCE/DISCHG	DISCRT
SOLIDS, TOTAL SUSPENDED	*****	*****	****	*****	*****	(19)	0		
00530 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE/DISCHG	DISCRT
NITROGEN, AMMONIA TOTAL (AS N)	*****	*****	****	*****	*****	(19)	0		
00610 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE/DISCHG	DISCRT
NITRITE PLUS NITRATE TOTAL 1 DET. (AS N)	*****	*****	****	*****	*****	(19)	0		
00630 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE/DISCHG	DISCRT
PHOSPHORUS, TOTAL (AS P)	*****	*****	****	*****	*****	(19)	0		
00665 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE/DISCHG	DISCRT
OIL AND GREASE	*****	*****	****	*****	*****	(19)	0		
03582 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	OPTIONAL 30DA AVG	MG/L	0	ONCE/DISCHG	DISCRT
FLOW, IN CONDUIT OR THRU TREATMENT PLANT			(03)						
50050 1 0 0 EFFLUENT GROSS VALUE	*****	*****	****	*****	*****	MG/L	0		
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	FREDRICK R. STATER			4-26-07			TELEPHONE	DATE	
Fredrick R. Stater	SIGNATURE OF PRINCIPAL EXECUTIVE			OFFICER OR AUTHORIZED AGENT			702-651-2200	07 04 26	
Plant Manager	TYPED OR PRINTED			AREA CODE NUMBER			702-651-2200	YEAR	MO
COMMENT AND EXPLANATION OF ANY VIOLATIONS			REFERENCE all attachments here)			AREA CODE NUMBER	702-651-2200	YEAR	MO
						AREA CODE NUMBER	702-651-2200	YEAR	MO

I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER THE DIRECTION OR SUPERVISION OF THE PERSON WHO HAS BEEN DESIGNATED AS RESPONSIBLE FOR GATHERING THE INFORMATION, AND I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.

ATTACHMENT 2

Supporting Information



C:\smc\My
Documents\Excel Spr

Water Leak Outfall Analytical Summary



C:\smc\My
Documents\Excel Spr

Storm Outfall Analytical Summary

1st Q 07 - NPDES Permit NV0000078 - Analytical Summary - Leaks

<u>Sample Date</u>	<u>Sample ID</u>	<u>Analyte</u>	<u>Result</u>	<u>MRL</u>	<u>UNIT</u>	<u>Method</u>
1/17/2007	OUTFALL 001	Perchlorate	27	4	UGL	EPA 314
1/17/2007	OUTFALL 001	Specific Conductance	999	2	UMHO	2510B/ SW9050
1/17/2007	OUTFALL 001	pH	8.2	0.001	UNIT	SM4500-HB
1/17/2007	OUTFALL 001	Total Dissolved Solid (TDS)	670	10	MGL	SM 2540C
1/17/2007	OUTFALL 002	Perchlorate	5.2	4	UGL	EPA 314
1/17/2007	OUTFALL 002	Specific Conductance	999	2	UMHO	2510B/ SW9050
1/17/2007	OUTFALL 002	pH	8.3	0.001	UNIT	SM4500-HB
1/17/2007	OUTFALL 002	Total Dissolved Solid (TDS)	676	10	MGL	SM 2540C
1/17/2007	STABILIZED WATER	Total Dissolved Solid (TDS)	666	10	MGL	SM 2540C
1/24/2007	OUTFALL 002	Perchlorate	15	4	UGL	EPA 314
1/24/2007	OUTFALL 002	Specific Conductance	999	2	UMHO	2510B/ SW9050
1/24/2007	OUTFALL 002	pH	8.2	0.001	UNIT	SM4500-HB
1/24/2007	OUTFALL 002	Total Dissolved Solid (TDS)	680	10	MGL	SM 2540C
1/24/2007	STABILIZED WATER	Total Dissolved Solid (TDS)	676	10	MGL	SM 2540C
3/8/2007	OUTFALL 002	Perchlorate	6.5	4	UGL	EPA 314
3/8/2007	OUTFALL 002	Specific Conductance	1050	2	UMHO	2510B/ SW9050
3/8/2007	OUTFALL 002	pH	8.1	0.001	UNIT	SM4500-HB
3/8/2007	OUTFALL 002	Total Dissolved Solid (TDS)	698	10	MGL	SM 2540C
3/8/2007	STABILIZED WATER	Total Dissolved Solid (TDS)	696	10	MGL	SM 2540C
3/14/2007	OUTFALL 002	Perchlorate	5.7	4	UGL	EPA 314
3/14/2007	OUTFALL 002	Specific Conductance	1045	2	UMHO	2510B/ SW9050
3/14/2007	OUTFALL 002	pH	8.2	0.001	UNIT	SM4500-HB
3/14/2007	OUTFALL 002	Total Dissolved Solid (TDS)	692	10	MGL	SM 2540C
3/14/2007	STABILIZED WATER	Total Dissolved Solid (TDS)	682	10	MGL	SM 2540C
3/28/2007	OUTFALL 002	Perchlorate	ND	4	UGL	EPA 314
3/28/2007	OUTFALL 002	Specific Conductance	1044	2	UMHO	2510B/ SW9050
3/28/2007	OUTFALL 002	pH	8.1	0.001	UNIT	SM4500-HB
3/28/2007	OUTFALL 002	Total Dissolved Solid (TDS)	694	10	MGL	SM 2540C
3/28/2007	STABILIZED WATER	Total Dissolved Solid (TDS)	658	10	MGL	SM 2540C

1st Q 07 - NPDES Permit NV0000078 - Analytical Summary - Storm

<u>Sample Date</u>	<u>Sample ID</u>	<u>Analyte</u>	<u>Result</u>	<u>MRL</u>	<u>UNIT</u>	<u>Method</u>
1/5/2007	OUTFALL 001	Perchlorate	76	4	UGL	EPA 314
1/5/2007	OUTFALL 001	Chemical Oxygen Demand (COD)	37	5	MGL	ML/EPA 410.4
1/5/2007	OUTFALL 001	Ammonia Nitrogen	0.201	0.05	MGL	ML/EPA 350.1
1/5/2007	OUTFALL 001	Nitrate + Nitrite as N by RFA	0.9	0.1	MGL	ML/EPA 353.2
1/5/2007	OUTFALL 001	Oil & Grease	ND	5	MGL	EPA1664
1/5/2007	OUTFALL 001	pH	8.2	0.001	UNIT	SM4500-HB
1/5/2007	OUTFALL 001	Total phosphorus-P	0.032	0.01	MGL	S4500PE/ 365.1
1/5/2007	OUTFALL 001	Total Dissolved Solid (TDS)	640	10	MGL	SM 2540C
1/5/2007	OUTFALL 001	Total Suspended Solids (TSS)	14	10	MGL	ML/EPA 160.2
1/5/2007	OUTFALL 002	Perchlorate	71	4	UGL	EPA 314
1/5/2007	OUTFALL 002	Chemical Oxygen Demand (COD)	39	5	MGL	ML/EPA 410.4
1/5/2007	OUTFALL 002	Ammonia Nitrogen	0.21	0.05	MGL	ML/EPA 350.1
1/5/2007	OUTFALL 002	Nitrate + Nitrite as N by RFA	0.9	0.1	MGL	ML/EPA 353.2
1/5/2007	OUTFALL 002	Oil & Grease	ND	5	MGL	EPA1664
1/5/2007	OUTFALL 002	pH	8.2	0.001	UNIT	SM4500-HB
1/5/2007	OUTFALL 002	Total phosphorus-P	0.018	0.01	MGL	S4500PE/ 365.1
1/5/2007	OUTFALL 002	Total Dissolved Solid (TDS)	670	10	MGL	SM 2540C
1/5/2007	OUTFALL 002	Total Suspended Solids (TSS)	40	10	MGL	ML/EPA 160.2
2/14/2007	OUTFALL 001	Perchlorate	ND	4	UGL	EPA 314
2/14/2007	OUTFALL 001	Chemical Oxygen Demand (COD)	6.1	5	MGL	ML/EPA 410.4
2/14/2007	OUTFALL 001	Ammonia Nitrogen	ND	0.05	MGL	ML/EPA 350.1
2/14/2007	OUTFALL 001	Nitrate + Nitrite as N by RFA	0.56	0.2	MGL	ML/EPA 353.2
2/14/2007	OUTFALL 001	Oil & Grease	ND	5	MGL	EPA1664
2/14/2007	OUTFALL 001	pH	8.5	0.001	UNIT	SM4500-HB
2/14/2007	OUTFALL 001	Total phosphorus-P	0.17	0.1	MGL	S4500PE/ 365.1
2/14/2007	OUTFALL 001	Total Dissolved Solid (TDS)	680	10	MGL	SM 2540C
2/14/2007	OUTFALL 001	Total Suspended Solids (TSS)	ND	10	MGL	ML/EPA 160.2
2/14/2007	OUTFALL 002	Perchlorate	ND	4	UGL	EPA 314
2/14/2007	OUTFALL 002	Chemical Oxygen Demand (COD)	11	5	MGL	ML/EPA 410.4
2/14/2007	OUTFALL 002	Ammonia Nitrogen	ND	0.05	MGL	ML/EPA 350.1
2/14/2007	OUTFALL 002	Nitrate + Nitrite as N by RFA	0.63	0.2	MGL	ML/EPA 353.2
2/14/2007	OUTFALL 002	Oil & Grease	ND	5	MGL	EPA1664
2/14/2007	OUTFALL 002	pH	8.4	0.001	UNIT	SM4500-HB
2/14/2007	OUTFALL 002	Total phosphorus-P	0.14	0.05	MGL	S4500PE/ 365.1
2/14/2007	OUTFALL 002	Total Dissolved Solid (TDS)	688	10	MGL	SM 2540C
2/14/2007	OUTFALL 002	Total Suspended Solids (TSS)	ND	10	MGL	ML/EPA 160.2

1st Q 07 - NPDES Permit NV0000078 - Analytical Summary - Storm

<u>Sample Date</u>	<u>Sample ID</u>	<u>Analyte</u>	<u>Result</u>	<u>MRL</u>	<u>UNIT</u>	<u>Method</u>
2/20/2007	OUTFALL 001	Perchlorate	527	80	UGL	EPA 314
2/20/2007	OUTFALL 001	Chemical Oxygen Demand (COD)	9.9	5	MGL	ML/EPA 410.4
2/20/2007	OUTFALL 001	Ammonia Nitrogen	0.06	0.05	MGL	ML/EPA 350.1
2/20/2007	OUTFALL 001	Nitrate + Nitrite as N by RFA	1.6	0.2	MGL	ML/EPA 353.2
2/20/2007	OUTFALL 001	Oil & Grease	ND	5	MGL	EPA1664
2/20/2007	OUTFALL 001	pH	8.2	0.001	UNIT	SM4500-HB
2/20/2007	OUTFALL 001	Total phosphorus-P	ND	0.04	MGL	S4500PE/ 365.1
2/20/2007	OUTFALL 001	Total Dissolved Solid (TDS)	732	10	MGL	SM 2540C
2/20/2007	OUTFALL 001	Total Suspended Solids (TSS)	14	10	MGL	ML/EPA 160.2
2/20/2007	OUTFALL 002	Perchlorate	42	4	UGL	EPA 314
2/20/2007	OUTFALL 002	Chemical Oxygen Demand (COD)	23	5	MGL	ML/EPA 410.4
2/20/2007	OUTFALL 002	Ammonia Nitrogen	0.374	0.05	MGL	ML/EPA 350.1
2/20/2007	OUTFALL 002	Nitrate + Nitrite as N by RFA	0.59	0.2	MGL	ML/EPA 353.2
2/20/2007	OUTFALL 002	Oil & Grease	ND	5	MGL	EPA1664
2/20/2007	OUTFALL 002	pH	8.1	0.001	UNIT	SM4500-HB
2/20/2007	OUTFALL 002	Total phosphorus-P	0.05	0.04	MGL	S4500PE/ 365.1
2/20/2007	OUTFALL 002	Total Dissolved Solid (TDS)	504	10	MGL	SM 2540C
2/20/2007	OUTFALL 002	Total Suspended Solids (TSS)	17	10	MGL	ML/EPA 160.2

