



EMS Laboratories
117 W. Bellevue Drive
Pasadena, CA 91105

NARRATIVE

August 2, 2010

Derrick Willis
Tronox LLC-Henderson
560 West Lake Mead
Henderson, NV 89015

SDG/EMS# 137821
Project: 2027.01, Tronox LLC Henderson,
560 West Lake Mead Drive, Henderson, NV
Client COC ID: 02027.01.2126

REFERENCE:	DAS Case No. 0769F	TDD No.: 07-10-0012
	Task No. 0361	P. O. No.: 0063941
	Tronox Project# 2027.01	NGE Tracking# 03
	AUI Task# 6	

EMS REPORT NO.: 137821

When the samples are analyzed in the TEM the recorded data includes the dimensions of the respirable fibers of the regulated asbestos types, namely, chrysotile, Amosite (cummingtonite/grunerite), tremolite, actinolite, crocidolite, and anthophyllite. The fibers of importance are those included in the protocol fiber classification. The width of the protocol fibers is <0.4 μm and the length is divided into two groups, 5 to 10 μm and long fibers >10 μm . The 95% Poisson Confidence interval for the observed concentration of fibers is also calculated. Other asbestos fibers and non-asbestos fibers with protocol dimensions are noted in the counting sheet. The problem regarding the loss of particles on polycarbonate filters has been eliminated except for very alkaline particles. There is no evidence that asbestos fibers are lost.

Samples SSA7-03-0.00BPC and its field duplicate show a slight difference in asbestos fiber count for short chrysotile fibers but the difference is small and probably not statistically significant.



EMS Laboratories Inc.
 117 West Bellevue Drive, Pasadena, CA 91105
 Phone: 626-568-4065 Fax: 626-796-5282
 Email: akolk@emslabs.com

Attn: Derrick Wills
 Tronox-LLC-Henderson
 PO Box 55
 Henderson, NV 89009

Phone: (947) 375-7004

Project: Tronox LLX Henderson, 560 W. Lake Mead Dr.,
 Henderson, NV/2027.001

Customer ID: TRNX26
Customer PO: 2027.001
Received: 5/19/2010 10:05AM
EMS LAB No: 137821
Date Prepared: 6/16/2010 11:42AM
Analysis Date: 6/23/2010 0:00

Report Date:

Date Sampled: 5/12/2010 1:05PM

NIOSH 7402/ISO

DRAFT, MODIFIED ELUTRIATOR METHOD FOR THE DETERMINATION OF ASBESTOS IN SOILS AND BULK MATERIAL METHOD

EMS Laboratory Number:	137821	Mass of Respirable Dust on Fiber:	172	µg
Customer Sample Number:	SSAP8-01-0.00BPC	Area of collection filter:	385	mm ²
Minimum Level of Analysis (chrysotile):	CD	Grid openings area:	0.0094	mm ²
Minimum Level of Analysis (amphibole):	ADX	Grid Openings Analyzed:	91	
Magnification used for fiber counting:	9,200 x	Min. Str. Length/Max Str. Diameter:	>5/<0.4	microns
Aspect ratio for fiber definition:	3:1			

Analyst(s): Radha Singh

Dust Generator - Total Dried Sample Weight-76.8g	Soil % Moisture	4.6	%
Not Used	Air Flow Rate Through ME Opening of Dust Generator:	1370	
Used in Tumbler	Air Flow Rate Through IST Opening of Dust Generator:	130	
	Estimate Total Air Flow Through Elutriator:	1500	

Analytical Sensitivity: 2.62E+06 Structure /g PM 10 **Limit of Detection:** 7.84E+06 Structure /g PM 10

Test For Uniformity (Chi-Square results)

Structure Class	Min ID Level Required	Counts		Density St/mm ²	Conc. Str/g PM10	Poisson 95% Confidence Interval	
		Primary Str.	Total Str.			Lower Limit Str/g PM10	Upper Limit Str/g PM10
Asbestos Structures>5um, ≤10um	ADX/CD	0	0	0	0	0	7.84E+06
Asbestos Structures>5um, ≤10um (Chrys)	CD	0	0	0	0	0	7.84E+06
Asbestos Structures>5um, ≤10um (Amph)	ADX	0	0	0	0	0	7.84E+06
Asbestos Structure >10um (Long)	ADX/CD	0	0	0	0	0	7.84E+06
Asbestos Structure >10um (Chrys)	CD	0	0	0	0	0	7.84E+06
Asbestos Structure >10um (Amph)	ADX	0	0	0	0	0	7.84E+06
Total Protocol Asbestos Structures	ADX/CD	0	0	0	0	0	7.84E+06
Protocol Asbestos Structures (Chrys)	CD	0	0	0	0	0	7.84E+06
Protocol Asbestos Structures (Amph)	ADX	0	0	0	0	0	7.84E+06
Total Protocol Non Asbestos Structures	NAM	1	1	1.2	2.62E+06	6.60E+04	4.37E+07


 Approved by Technical Director

Elutriator Data

Date: 6/14/10

Client: Northgate

Lab #: 137821

Sample ID: SSAP 8-01-0.00 BPC

Sample weight (g): 76.8

Time air flow started: ~~295~~ 745

Tumbler rpm: 45

IST Flowmeter (mL/min): 130

ME Flowmeter (mL/min): 1370

Filter No.	Start Time	Tested flow rate (mL/min)	Final Filter Wt (mg)	Initial Filter Wt (mg)	Dust Weight (mg)	Time Value (min)	Avg. rate of deposition (ug/min)	Optimal time (min)
1	945	30	0.04894	0.02494	24.00	30		
2	1015		0.03045	0.02484	5.59	20		
3	1035		0.03387	0.02499	8.88	20		
4	1055		0.02975	0.02497	4.78	20		
5	1115		0.03054	0.02495	5.59	20		
6	1135		0.02787	0.02471	3.16	25		
7	1800							
8								
STOP								
START Time							Dep. Rate	Estimate
-1	1103	1089 1/2		4.347		5 1/2		
-2	1121	1131		4.394		10		
-3	1142	1158		4.437	172	10 1/2		
-4	1209	1225		4.392		10		
-5								
-6								
-7								
-8								

*blown out, 110 good.

blown out 20%.

blown out 66%.

prep 6/18/10

Eliutriator Data

Date: 6/17/10

Client: Northgate

Lab #: 137821

Sample ID: SSAP8-01-0.00 RPC-EP

Sample weight (g): 77.7

Time air flow started: 8:00

Tumbler rpm: 30

IST Flowmeter (mL/min): 130

ME Flowmeter (mL/min): 1370

Filter No.	Start Time	Tested flow rate (mL/min)	Final Filter Wt (mg)	Initial Filter Wt (mg)	Dust Weight (mg)	Time Value (min)	Avg. rate of deposition (ug/min)	Optimal time (min)
1	10:00	139	0.03040	0.02499	11.41	30		
2	10:30		0.02930	0.02498	4.32	20		
3	10:50		0.03172	0.02494	6.78	25		
4	11:15		0.03093	0.02496	5.97	25		
5	11:40		0.02949	0.02489	4.60	25		
6	12:05							
7								
8								
Time							Dep. Rate	Estimate
1	10:57			4.447		12		
2	11:21			4.509		13		
3	11:46			4.421	153	10		
4	12:11			4.388		11		
5								
6								
7								
8								

1
2
3
4
5
6
7
8

Prep: 6/18/10

138821

moisture content

41

6-7-10

#SSAP8-01-00BPC

dish wt. 19.25g

sample wt. 119.21g - 19.25 = 99.96g (initial wt.)

at 6:20 AM - 7:20 - 114.88 - 19.25 = 95.63g

8:05 - 9:05 - 114.86 - 19.25 = 95.61g (Final wt.)

$$\% \text{ moisture} \rightarrow 100 \times \frac{99.96 - 95.61}{95.61} = 4.55\%$$

#SSAN7-03-0.00BPC-FD

dish wt. 31.48g

sample wt. 131.92 - 31.48 = 100.44g (initial wt.)

8:50 - 9:50 129.19 - 31.48 = 97.71g

10:30 - 11:30 128.88 - 31.48 = 97.40g

12:30 - 1:30 128.87 - 31.48 = 97.39g

$$\% \text{ moisture} \rightarrow 100 \times \frac{100.44 - 97.39}{97.39} = 3.13\%$$

#SSAN7-03-0.00BPC

dish wt. 31.46g

sample wt. 131.89 - 31.46 = 100.43g (initial wt.)

8:50 - 9:50 128.96 - 31.48 = 97.50g

10:30 - 11:30 128.88 - 31.46 = 97.42g

12:30 - 1:30 128.84 - 31.46 = 97.38g

$$\% \text{ moisture} \rightarrow 100 \times \frac{100.43 - 97.38}{97.38} = 3.13\%$$

BP

TEM Asbestos Structure Count (Page of)

Report number: 13782-1

SAMPLE NO: SSAP8-01-0.00 BPC X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	G3-4							
	E3-6							
	G3-3							
	G4-4							
	G4-1							
	H4-1							
	E5-4							
	G5-1							
19	H5-4				MDID MI-	70 1.5	90 60	Nan ash
16	E3							
	E3-4							
	E3-1							
	F3-4							
	G2-3							
	H2-3							
	C3-3							
	C3-6							
	G4-4							
	E4-1							
	F4-1							
	G4-1							
	G4-4							
	G5-1							
	G5-4							
	B5-4							
	B4-4							
	B3-6							
10	E2-3							
	E2-6							
	E2-3							
	E2-6							
	B3-4							



EMS Laboratories Inc.
 117 West Bellevue Drive, Pasadena, CA 91105
 Phone: 626-568-4065 Fax: 626-796-5282
 Email: akolk@emslabs.com

Attn: Derrick Wills
 Tronox-LLC-Henderson
 PO Box 55
 Henderson, NV 89009

Customer ID: TRNX26
 Customer PO: 2027.001
 Received: 5/19/2010 10:05AM
 EMS LAB No: 137821
 Date Prepared: 6/28/2010 2:55PM
 Analysis Date: 6/29-30/10 1:00PM

Phone: (947) 375-7004

Project: Tronox LLX Henderson, 560 W. Lake Mead Dr.,
 Henderson, NV/2027.001

Report Date:

Date Sampled: 5/12/2010 12:26pm

NIOSH 7402/ISO

DRAFT, MODIFIED ELUTRIATOR METHOD FOR THE DETERMINATION OF ASBESTOS IN SOILS AND BULK MATERIAL METHOD

EMS Laboratory Number: 137821	Mass of Respirable Dust on Fiber: 168	µg
Customer Sample Number: SSAN7-03-0.00BPC_FD	Area of collection filter: 385	mm ²
Minimum Level of Analysis (chrysotile): CD	Grid openings area: 0.0094	mm ²
Minimum Level of Analysis (amphibole): ADX	Grid Openings Analyzed: 99	
Magnification used for fiber counting: 9,200 x	Min. Str. Length/Max Str. Diameter: >5/<0.4	microns
Aspect ratio for fiber definition: 3:1		

Analyst(s): Radha Singh

Dust Generator - Total Dried Sample Weight-78.1g	Soil % Moisture	3.1	%
Not Used	Air Flow Rate Through ME Opening of Dust Generator:	1370	
Used in Tumbler	Air Flow Rate Through IST Opening of Dust Generator:	103	
	Estimate Total Air Flow Through Elutriator:	1473	

Analytical Sensitivity: 2.46E+00 Structure /g PM 10 Limit of Detection: 7.38E+00 Structure /g PM 10

Test For Uniformity (Chi-Square results)

(Note: Amended report per client request to reflect the EPA definition of greater than 10µm and less than 0.4µm)

Structure Class	Min ID Level Required	Counts		Density St/mm ²	Conc. Str/g PM10	Poisson 95% Confidence Interval	
		Primary Str.	Total Str.			Lower Limit Str/g PM10	Upper Limit Str/g PM10
Asbestos Structures >5µm, ≤10µm	ADX/CD	0	0	0	0	0	7.38E+00
Asbestos Structures >5µm, ≤10µm (Chrys)	CD	0	0	0	0	0	7.38E+00
Asbestos Structures >5µm, ≤10µm (Amph)	ADX	0	0	0	0	0	7.38E+00
Asbestos Structure >10µm (Long)	ADX/CD	0	0	0	0	0	7.38E+00
Asbestos Structure >10µm (Chrys)	CD	0	0	0	0	0	7.38E+00
Asbestos Structure >10µm (Amph)	ADX	0	0	0	0	0	7.38E+00
Total Protocol Asbestos Structures	ADX/CD	0	0	0	0	0	7.38E+00
Protocol Asbestos Structures (Chrys)	CD	0	0	0	0	0	7.38E+00
Protocol Asbestos Structures (Amph)	ADX	0	0	0	0	0	7.38E+00
Total Protocol Non Asbestos Structures	NAM	0	0	0	0	0	7.38E+00


 Approved by Technical Director

ge 10f2
Elutriator Data

Date: 4/25/10 Client: Northgate

Lab #: 137821

Sample ID: SSAN7-03-0.00
BPC - FD

Sample weight (g): 75.1

Time air flow started: 8:00

Tumbler rpm: 30 * turn down RPM to 20 @ 1033 am
* turn up RPM to 30 @ 1340

IST Flowmeter (mL/min): 103 * See below

ME Flowmeter (mL/min): 1370

* loss 40%
* loss 10%
* loss 10%
* loss 45%

prep 6/29/10

Filter No.	Start Time	Tested flow rate (mL/min)	Final Filter Wt (mg)	Initial Filter Wt (mg)	Dust Weight (mg)	Time Value (min)	Avg. rate of deposition (ug/min)	Optimal time (min)
1	1000	155	0.03858	0.02518	1340	30		
2	1030		0.03497	0.02520	9.27	20		
3	1050		0.03111	0.02458	6.53	25		
4	1115		0.02894	0.02431	4.63	25		
5	1140		0.02784	0.02534	2.50	15		
6	1155		0.02887	0.02537	3.50	30		
7	1225		0.02623	0.02445	1.78	15		
8	1240		0.02952	0.02550	4.02	45		
Time							Dep. Rate	Estimate
1	1100			4.431		75.45		
2	1123			4.380		12		
3	1248			4.417		12		
4	1306			4.469		20		
5	1339			4.373		22		
6	1410			4.350		12		
7	1432			4.402		18		
8	1455		4.554	4.386	106	26		

* Raise up 1st flow to 118 @ 1155 AM

138821

moisture content

41

6-7-10

#SSAP8-01-00 BPC

dish wt. 19.25g

sample wt. 119.21g - 19.25 = 99.96g (initial wt.)

at 6:20 AM - 7:20 - 114.88 - 19.25 = 95.63g

8:05 - 9:05 - 114.86 - 19.25 = 95.61g (Final wt.)

$$\% \text{ moisture} \rightarrow 100 \times \frac{99.96 - 95.61}{95.61} = 4.55\%$$

#SSAN7-03-0.00 BPC - FD

dish wt. 31.48g

sample wt. 131.92 - 31.48 = 100.44g (initial wt.)

8:50 - 9:50 129.19 - 31.48 = 97.71g

10:30 - 11:30 128.88 - 31.48 = 97.40g

12:30 - 1:30 128.87 - 31.48 = 97.39g

$$\% \text{ moisture} \rightarrow 100 \times \frac{100.44 - 97.39}{97.39} = 3.13\%$$

#SSAN7-03-0.00 BPC

dish wt. 31.46g

sample wt. 131.89 - 31.46 = 100.43g (initial wt.)

8:50 - 9:50 128.96 - 31.48 = 97.50g

10:30 - 11:30 128.88 - 31.46 = 97.42g

12:30 - 1:30 128.84 - 31.46 = 97.38g

$$\% \text{ moisture} \rightarrow 100 \times \frac{100.43 - 97.38}{97.38} = 3.13\%$$

BP

927 910 G.O.

Prep 90°-113°

90

Count (Page of) NIOSH 7402/ISO

Report number : 137821

PC

Filter Type: MEE-385 mm2

Sample number: SSAN7-03-0.00BPC-FD

Date Sample was Run: 6/28/10

File name: Northgate

Copy

Sample Description: 168 mg

Magnification: 9,200 X

Preparation date: 6/29/10 By Jap

Grid opening dimension: 0.0094 mm²

Analysis date: 6-29-10 + 6-30-10 By Pt (A): ADX, ADQ

Level of Analysis: (C): CD, CDX

2 hrs

Grid loading Modem 2 Condition of Grid good

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
1A	C26							
	E23				MDI	80	130	Non ash
	E23				MI	8	110	
	E23				F	12	70	Non ash
	E26							
	E3-1							
	E3-4							
	E3-1							
	E3-4							
	H3-1							
	H3-4							
	H3-1							
	H3-4							
	H4-1							
	H4-4							
	E4-1							
	F4-4							
	F4-8							
	F4-6							
	H4-3							
	H4-6							
	E5-1							
	E5-4							
1B	C31							
	C34							
	E3-1							
	E3-4							
	H4-1							
	H4-4							

TEM Asbestos Structure Count (Page of)

Report number: 137821

SAMPLE NO: SSAN7-03-0,00 BPC-FD X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
1D	E34							
	P3-1							
	P3-4							
	G3-4							
	L3-4							
	H3-1							
	H3-4							
	E4-1							
	E4-4							
	F4-1							
	P4-4							
	G4-1							
	G4-4							
	H4-3							
	H4-6							
	E5-3							
	E5-6							
	19	P5-6						
1E	E2-3							
	E3-1							
	E3-2							
	E3-6							
	G3-3				F	15"	95"	Non ash
	G3-6							
	H3-3							
	P4-1							
	G4-1							
	G4-4							
	H4-1							
	H4-4							
	G4-1							
	G4-4							
	18	H4-1						
P6-1								



EMS Laboratories Inc.
 117 West Bellevue Drive, Pasadena, CA 91105
 Phone: 626-568-4065 Fax: 626-796-5282
 Email: akolk@emslabs.com

Attn: Derrick Wills
 Tronox-LLC-Henderson
 PO Box 55
 Henderson, NV 89009

Customer ID: TRNX26
 Customer PO: 2027.001
 Received: 5/19/2010 10:05AM
 EMS LAB No: 137821
 Date Prepared: 6/29/2010 2:00PM
 Analysis Date: 7/7/2010 0:00

Phone: (947) 375-7004

Project: Tronox LLX Henderson, 560 W. Lake Mead Dr.,
 Henderson, NV/2027.001

Report Date:

Date Sampled: 5/12/2010 12:15PM

NIOSH 7402/ISO

DRAFT, MODIFIED ELUTRIATOR METHOD FOR THE DETERMINATION OF ASBESTOS IN SOILS AND BULK MATERIAL METHOD

EMS Laboratory Number: 137821	Mass of Respirable Dust on Fiber: 167	µg
Customer Sample Number: SSAN7-03-0.00BPC	Area of collection filter: 385	mm ²
Minimum Level of Analysis (chrysotile): CD	Grid openings area: 0.0094	mm ²
Minimum Level of Analysis (amphibole): ADX	Grid Openings Analyzed: 96	
Magnification used for fiber counting: 9,200 x	Min. Str. Length/Max Str. Diameter: >5/<0.4	microns
Aspect ratio for fiber definition: 3:1		

Analyst(s): Radha Singh

Dust Generator - Total Dried Sample Weight-78.1g	Soil % Moisture	3.1	%
Not Used	Air Flow Rate Through ME Opening of Dust Generator:	1370	
Used in Tumbler	Air Flow Rate Through IST Opening of Dust Generator:	130	
	Estimate Total Air Flow Through Elutriator:	1500	

Analytical Sensitivity: 2.55E+06 Structure /g PM 10 Limit of Detection: 7.65E+06 Structure /g PM 10

Test For Uniformity (Chi-Square results)

Structure Class	Min ID Level Required	Counts		Density St/mm ²	Conc. Str/g PM10	Poisson 95% Confidence Interval	
		Primary Str.	Total Str.			Lower Limit Str/g PM10	Upper Limit Str/g PM10
Asbestos Structures >5um, ≤10um	ADX/CD	3	3	3.3	1.58E+06	0	2.24E+07
Asbestos Structures >5um, ≤10um (Chrys)	CD	3	3	3.3	1.58E+06	0	2.24E+07
Asbestos Structures >5um, ≤10um (Amph)	ADX	0	0	0	0	0	7.65E+06
Asbestos Structure >10um (Long)	ADX/CD	0	0	0	0	0	7.65E+06
Asbestos Structure >10um (Chrys)	CD	0	0	0	0	0	7.65E+06
Asbestos Structure >10um (Amph)	ADX	0	0	0	0	0	7.65E+06
Total Protocol Asbestos Structures	ADX/CD	3	3	3.3	1.58E+06	0	2.24E+07
Protocol Asbestos Structures (Chrys)	CD	3	3	3.3	1.58E+06	0	2.24E+07
Protocol Asbestos Structures (Amph)	ADX	0	0	0	0	0	7.65E+06
Total Protocol Non Asbestos Structures	NAM	0	0	0	0	0	7.65E+06


 Approved by Technical Director

Date: 6/29/10

Client: Northgate

Lab #: 137821

Sample ID: SSAN7-03-0.00 PPC Sample weight (g): 78.1

Time air flow started: 0800
 Tumbler rpm: 30 *turn down RPM to 20 @ 1031
 *turn up RPM to 30 @ 1209
 ME Flowmeter (mL/min): 1370

*loss 5%
 *loss 20%
 *loss 20%
 *loss 10%
 *loss 80%
 *loss 10%

Filter No.	Start Time	Tested flow rate (mL/min)	Final Filter Wt (mg)	Initial Filter Wt (mg)	Dust Weight (mg)	Time Value (min)	Avg. rate of deposition (ug/min)	Optimal time (min)
1	1000	1370	0.03025	0.02440	11.85	30		
2	1030		0.03225	0.02455	7.70	20		
3	1050		0.02803	0.02421	3.82	20		
4	1110		0.02659	0.02456	4.03	25		
5	1135		0.02650	0.02431	2.19	30		
6	1205		0.02962	0.02493	5.19	30		
7	1235		0.02902	0.02513	3.89	20		
8	1255		0.02884	0.02434	4.50	25		
Time								
1	1120						Dep. Rate	Estimate
2	1144			4.334		11		
3	1302			4.404		20		
4	1338			4.394		15		
5	1400		45.79	4.454		16		
6				4.412	107	20		
7								
8								

7/2/10 (prep)

138821

moisture content

41

6-7-10

#SSAP8-01-00 BPC

dish wt. 19.25g

sample wt. 119.21g - 19.25 = 99.96g (initial wt.)

at 6:20 AM - 7:20 - 114.88 - 19.25 = 95.63g

8:05 - 9:05 - 114.86 - 19.25 = 95.61g (final wt.)

$$\% \text{ moisture} \rightarrow 100 \times \frac{99.96 - 95.61}{95.61} = 4.55\%$$

#SSAN7-03-0.00 BPC - FD

dish wt. 31.48g

sample wt. 131.92 - 31.48 = 100.44g (initial wt.)

8:50 - 9:50 129.19 - 31.48 = 97.71g

10:30 - 11:30 128.88 - 31.48 = 97.40g

12:30 - 1:30 128.87 - 31.48 = 97.39g

$$\% \text{ moisture} \rightarrow 100 \times \frac{100.44 - 97.39}{97.39} = 3.13\%$$

#SSAN7-03-0.00 BPC

dish wt. 31.46g

sample wt. 131.89 - 31.46 = 100.43g (initial wt.)

8:50 - 9:50 128.96 - 31.48 = 97.50g

10:30 - 11:30 128.88 - 31.46 = 97.42g

12:30 - 1:30 128.84 - 31.46 = 97.38g

$$\% \text{ moisture} \rightarrow 100 \times \frac{100.43 - 97.38}{97.38} = 3.13\%$$

BP

Prep Time: 12⁰⁰ - 230 pm

Report number: 137821
 Sample number: SSAN7-03-0.00BPC
 File name: Northgate
 Sample Description: 167 mg

Filter Type: 385 mm2
 Date Sample was Run: 6/29/10
 Magnification: 9,200 X

Preparation date: 7/2/10 By JAP
 Analysis date: 7/7/10 By DE

Grid opening dimension: 0.0094 mm²
 Level of Analysis: (C): CD, CDX

Grid loading None Condition of Grid Good

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
A	B34	1						
	C34	1						
	E34	1						
	F34	1						
	G34	1						
	H34	1						
	J34	1						
	L34	1						
	N34	1						
	P34	1						
	R34	1						
	T34	1						
	V34	1						
	X34	1						
	Z34	1						
	B54	1						
	C54	1						
	E54	1						
	F54	1						
	G54	1						
	H54	1						
	J54	1						
	L54	1						
	N54	1						
	P54	1						
	R54	1						
	T54	1						
	V54	1						
	X54	1						
	Z54	1						
B	K3	2	2		MT	55	82	Char 3539
	L23	1			MT	0.9	60	
	E73	1						
	G23	1						
	H23	1						
	J23	1						
	L23	1						
	N23	1						
	P23	1						
	R23	1						
	T23	1						
	V23	1						
	X23	1						
	Z23	1						
	B36	1						
	E36	1						
	F36	1						
	G36	1						
	H36	1						
	J36	1						
	L36	1						
	N36	1						
	P36	1						
	R36	1						
	T36	1						
	V36	1						
	X36	1						
	Z36	1						

Report number: 137821

SAMPLE NO: SSAN7-03-0.00BPC X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	C43	NSD						
	E43	NSD						
	F43	NSD						
	G43	NSD						
	H43	NSD						
	B56	NSD						
	C56	NSD						
	E56	NSD						
	F56	NSD						
C	C26	NSD						
	F26	NSD						
	F26	NSD						
	G26	NSD						
	H26	NSD						November 1954
	C32	NSD						
	E32	NSD						
	F32	NSD						
	G32	NSD						
	H32	NSD						
	C41	NSD						
	E41	NSD						
	F41	NSD						
	G41	NSD						
	H41	NSD						
	K41	NSD						
	E56	NSD						
	F56	NSD						
	G56	NSD						
D	C31	NSD						
	E31	NSD						
	F31	NSD						
	G31	NSD						
	H31	NSD						
	B44	NSD						
	C44	NSD						
	E44	NSD						
	F44	NSD						
	G44	NSD						

TEM Asbestos Structure Count (Page 3 of 9)

Report number: 137821


SAMPLE NO: SSAN7-03-0.00 BPC

X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	H44	NSD						
	I41	NSD						
	E41	NSD						
	F51	NSD						
	G51	NSD						
	H51	NSD						
	I51	NSD						
	J51	NSD						MD chry 25u
	K51	NSD						
	L51	NSD						
	M51	NSD						
E	N51	NSD						
	O51	NSD						
	P51	NSD						
	Q51	NSD						
	R51	NSD						
	S51	NSD						
	T51	NSD						
	U51	NSD						
	V51	NSD						
	W51	NSD						
	X51	NSD						
	Y51	NSD						
	Z51	NSD						
	A52	NSD						
	B52	NSD						
	C52	NSD						
	D52	NSD						
	E52	NSD						
	F52	NSD						
	G52	NSD						
	H52	NSD						
	I52	NSD						
	J52	NSD						
	K52	NSD						
	L52	NSD						
	M52	NSD						
	N52	NSD						
	O52	NSD						
	P52	NSD						
	Q52	NSD						
	R52	NSD						
	S52	NSD						
	T52	NSD						
	U52	NSD						
	V52	NSD						
	W52	NSD						
	X52	NSD						
	Y52	NSD						
	Z52	NSD						
	A53	NSD						
	B53	NSD						
	C53	NSD						
	D53	NSD						
	E53	3	3	MDL	5	57		SAED 250
	F53	NSD		MF	0.3	57		chry
	G53	NSD						also on F15X 62
	H53	NSD						
	I53	NSD						
	J53	NSD						
	K53	NSD						
	L53	NSD						
	M53	NSD						
	N53	NSD						
	O53	NSD						
	P53	NSD						
	Q53	NSD						
	R53	NSD						
	S53	NSD						
	T53	NSD						
	U53	NSD						
	V53	NSD						
	W53	NSD						
	X53	NSD						
	Y53	NSD						
	Z53	NSD						

Full scale counts: 226

137821 SSAN7-03-00 BPC GRID B STR 1 GO C2-3



klm - 29 - Cu

Mon Aug 02 11:15:05 2010

Gaussian Fit With Standards Chi Squared:1.930

Correction Method: Cliff-Lorimer (MBTS) w/o Absorbance

Live Time:64.9 sec.

Acc.Voltage: 100.0 kV

Take Off Angle: 35.0 deg.


Detector: Det B- Quantum

Quantitative Results 137821 SSAN7-03-00 BPC GRID B STR 1 GO C2-3

Element Line	Net Counts	Weight %	Weight % Error	Atom %	Atom % Error
Mg K	685	44.38	---	47.97	+/- 2.17
Si K	1116	55.62	---	52.03	+/- 1.77
Total		100.00		100.00	

Full scale counts: 404

137821 SSAN7-03-00 BPC GRID E STR 1 GO E5-4



klm - 29 - Cu

Mon Aug 02 11:22:30 2010

Gaussian Fit With Standards Chi Squared:2.162

Correction Method: Cliff-Lorimer (MBTS) w/o Absorbance

Live Time:117.6 sec.

Acc.Voltage: 100.0 kV

Take Off Angle: 35.0 deg.


Detector: Det B- Quantum

Quantitative Results 137821 SSAN7-03-00 BPC GRID E STR 1 GO E5-4

Element Line	Net Counts	Weight %	Weight % Error	Atom %	Atom % Error
Mg K	605	45.98	---	49.59	+/- 2.38
Si K	924	54.02	---	50.41	+/- 1.86
Total		100.00		100.00	

Full scale counts: 440

137821 SSAN7-03-00 BPC GRID A STR 1 GO E54



Live Time: 109.5 sec.
 Acc. Voltage: 100.0 kV
 Take Off Angle: 35.0 deg.
 Detector: Det B- Quantum

Mon Aug 02 11:07:21 2010
 Gaussian Fit With Standards Chi Squared: 1.105
 Correction Method: Cliff-Lorimer (MBTS) w/o Absorbance

Quantitative Results 137821 SSAN7-03-00 BPC GRID A STR 1 GO E54

Element Line	Net Counts	Weight %	Weight % Error	Atom %	Atom % Error
Mg K	1172	46.01	---	49.61	+/- 1.69
Si K	1788	53.99	---	50.39	+/- 1.35
Total		100.00		100.00	



EMS Laboratories Inc.
 117 West Bellevue Drive, Pasadena, CA 91105
 Phone: 626-568-4065 Fax: 626-796-5282
 Email: akolk@emslabs.com

Attn: Derrick Wills
 Tronox-LLC-Henderson
 PO Box 55
 Henderson, NV 89009

Phone: (947) 375-7004

Project: Tronox LLX Henderson, 560 W. Lake Mead Dr.,
 Henderson, NV/2027.001

Customer ID: TRNX26
 Customer PO: 2027.001
 Received: 5/19/2010 10:05AM
 EMS LAB No: 137821
 Date Prepared: 6/30/2010 1:05PM
 Analysis Date: 7/6/2010 0:00

Report Date:

Date Sampled: 5/12/2010 09:10AM

NIOSH 7402/ISO

DRAFT, MODIFIED ELUTRIATOR METHOD FOR THE DETERMINATION OF ASBESTOS IN SOILS AND BULK MATERIAL METHOD

EMS Laboratory Number: 137821	Mass of Respirable Dust on Fiber: 156	µg
Customer Sample Number: SSAN5-02-0.00BPC	Area of collection filter: 385	mm ²
Minimum Level of Analysis (chrysotile): CD	Grid openings area: 0.0094	mm ²
Minimum Level of Analysis (amphibole): ADX	Grid Openings Analyzed: 100	
Magnification used for fiber counting: 9,200 x	Min. Str. Length/Max Str. Diameter: >5/<0.4	microns
Aspect ratio for fiber definition: 3:1	Analyst(s): Radha Singh	
Dust Generator - Total Dried Sample Weight-75.8g	Soil % Moisture	8.7 %
Not Used	Air Flow Rate Through ME Opening of Dust Generator:	1370
Used in Tumbler	Air Flow Rate Through IST Opening of Dust Generator:	100
	Estimate Total Air Flow Through Elutriator:	1470

Analytical Sensitivity: 2.63E+06 Structure /g PM 10 Limit of Detection: 7.86E+06 Structure /g PM 10

Test For Uniformity (Chi-Square results)

Structure Class	Min ID Level Required	Counts		Poisson 95% Confidence Interval			
		Primary Str.	Total Str.	Density	Conc.	Lower Limit	Upper Limit
				St/mm ²	Str/g PM10	Str/g PM10	Str/g PM10
Asbestos Structures >5um, ≤10um	ADX/CD	1	1	1.06	2.63E+06	6.60E+04	1.47E+07
Asbestos Structures >5um, ≤10um (Chrys)	CD	1	1	1.06	2.63E+06	6.60E+04	1.47E+07
Asbestos Structures >5um, ≤10um (Amph)	ADX	0	0	0	0	0	7.86E+06
Asbestos Structure >10um (Long)	ADX/CD	0	0	0	0	0	7.86E+06
Asbestos Structure >10um (Chrys)	CD	0	0	0	0	0	7.86E+06
Asbestos Structure >10um (Amph)	ADX	0	0	0	0	0	7.86E+06
Total Protocol Asbestos Structures	ADX/CD	1	1	1.06	2.63E+06	6.60E+04	1.47E+07
Protocol Asbestos Structures (Chrys)	CD	1	1	1.06	2.63E+06	6.60E+04	1.47E+07
Protocol Asbestos Structures (Amph)	ADX	0	0	0	0	0	7.86E+06
Total Protocol Non Asbestos Structures	NAM	2	2	2.12	5.20E+06	6.40E+05	1.90E+07


 Approved by Technical Director

Elutriator Data

Lab #: 137821.

Date: 6/30/10

Client: Northgate

Sample ID: SSANS-02-0.00BPC Sample weight (g): 75.8

Time air flow started: 800

Tumbler rpm: 30

IST Flowmeter (mL/min): 100

ME Flowmeter (mL/min): 1370

Filter No.	Start Time	Tested flow rate (mL/min)	Final Filter Wt (mg)	Initial Filter Wt (mg)	Dust Weight (mg)	Time Value (min)	Avg. rate of deposition (ug/min)	Optimal time (min)
1	1005	175	0.02630	0.02436	1.94	30		
2	1035		0.02827	0.02444	3.81	20		
3	1055		0.02695	0.02434	2.61	15		
4	1110		0.02748	0.02443	3.05	30		
5	1140		0.02657	0.02456	2.01	15		
6	1158		0.02909	0.02444	4.65	30		
7	1225		0.02824	0.02430	3.94	35		
8	1300		0.02954	0.02424	5.30	25		
Time							Dep. Rate	Estimate
1	1121			4.384		20		
2	1200			4.416		20		
3	1305		4.554	4.398	156	15		
4								
5								
6								
7								
8								

*loss 90%
 *loss 20%
 *loss 15%
 *loss 50%
 loss 10%
 OK
 loss 30%
 loss 5%

prep 7/1/10

1 2 3 4 5 6 7 8

137821

Moisture content

44

6-9-10

#SSAN5-02.0.00 BPC

dish wt. 19.24

dish + samp. 119.65 - 19.24 = 100.41g (initial wt.)

10:40 111.91 - 19.24 = 92.67g

11:30 111.90 - 19.24 = 92.66g

12:30 111.65 - 19.24 = 92.41 (Final wt.)

$$\% \text{ moist. } 100 \times \frac{100.41 - 92.41}{92.41} = 8.66\%$$

137821

#SSAK5-03-0.00 BPC

dish wt.

31.45

dish + samp.

131.57 - 31.45 = 100.12g (initial wt.)

10:40

123.43 - 31.45 = 91.98g

11:30

123.13 - 31.45 = 91.68g

12:30

123.10 - 31.45 = 91.65 (Final wt.)

$$\% \text{ moist. } 100 \times \frac{100.12 - 91.65}{91.65} = 9.14\%$$

137821

#SSAL5-02-0.00 BPC

dish wt.

31.45

dish + samp.

131.48 - 31.45 = 100.03g (initial wt.)

10:40

127.66 - 31.45 = 96.21g

11:30

127.47 - 31.45 = 96.02g

12:30

127.55 - 31.45 = 96.10g

10:40

$$\% \text{ moist. } 100 \times \frac{100.03 - 96.00}{96.00} = 4.2\%$$

BP

Prep Time: 12³⁰ 3⁰⁰

Report number: 137821
 Sample number: SSANS-02-0.00 BPC
 File name: Northgate
 Sample Description: 156 mg

Filter Type: PC 385 mm²
 Date Sample was Run: 6/30/10

Preparation date: 7/1/10 By JAP
 Analysis date: 7/6/10 By PK

Magnification: 9,200 X
 Grid opening dimension: 0.0094 mm²
 Level of Analysis: (C): CD, CDX

Grid loading Moderate Condition of Grid Good
 (A): ADX, ADQ

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
A	E31	NSD						
	F31	NSD						
	G31	NSD						
	H31	NSP						
	B44	NSD						
	C44	NSD						
	E44	NSD						
	F44							
	B54	NSD						
	C54	NSD						
	E54	NSP						
	F54	NSD						
	G54	NSD						
	H54							
	K54	NSD						
	C61	NSD						
	E61	NSD						
	F61	NSD						
	G61	NSP						
	H61	NSD						
B	B26	NSD						
	C26	NSD						
	E26	NSD						
	F26	NSD						Crack B ~ 5M
	G26	NSD						
	H26	NSD						
	B36	NSD						
	C36	NSD						Taken after MD
	E36	NSD						
	F36	NSD						
	G36	NSD						
	H36	NSD						

E44 2 x 88 x 6 Bar
 H54 MDU 35x83
 2.5 x 62 No ground

TEM Asbestos Structure Count (Page 2 of 3)

Report number: 137821

SAMPLE NO: SSAN5-02-0.00 BPC X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	K36	NSD						
	B46	NSD						
	C46	NSD						
	E46	NSD						MD Take Filter 5u
	F46	NSD						" " "
	G46	NSD						
	H46	NSD						
	E56	NSD						
C	C31	NSD						
	E31	NSD						
	F31	NSD						
	G31	NSD						
	H31	NSD						NSD, 1 in MD
	F41	NSD						
	G41	1			MO11	110	110	CH 14 3541
			1		MF	2	65	"
	H41	NSD						
	K41	NSD						
	C51	NSD				15	68	Take F 1.2x68
	E51	NSD						
	F51	NSD						
	G51	NSD						Non-Asbestos MD 25u
	H	NSD						
	K51	NSD						
	E61	NSD						
	G61	NSD						
D	H61	NSD						
	B33	NSD						
	C33	NSD						
	E33	NSD						
	F33	NSD						
	G33	NSD						
	H33	NSD						
	K33	NSD						
	B46	NSD						
	C46	NSD						
	E46	NSD						
	F46	NSD						

TEM Asbestos Structure Count (Page 3 of 7)

Report number: 157821

SAMPLE NO: SSANS-02-0.00 PFC X 9,200


Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	H46	NSD						
	B64	NSD						
	C64	NSD						
	E64	NSD						
	F64	NSD						
	C51	NSD						Capout > 5µ
	E51	NSD						
	F51	NSD						
	G51	NSD						
E	C31	NSD						Chry B < 5µ
	E31	NSD						
	F31	NSD						
	G31	NSD						M, or S1 SAED 3542x
	H31	NSD						
	B41	NSD						
	C41	NSD						
	E41				MDI	12	96	SAED 3544
					MB	5	96	X Grid P
	F41	NSD						
	B41	NSD						
	H41	NSD						
	K41	NSD						
	B54	NSD						
	C54	NSD						
	E54	NSD						
	F54	NSD						
	G54	NSD						
	H54	NSD						
	C64	NSD						
	E64	NSD						

* SAED looks like Chrysotile 10 15 x 63

Full scale counts: 99

137821 SSAN5-02-0,00 BPC GRID B GO E 46 TALC FIBER

Cursor: 5.187 keV
1 Counts



Wed Jul 07 16:04:18 2010

Gaussian Fit Chi Squared:0.455

Correction Method: Cliff-Lorimer (MBTS) w/o Absorbance

Live Time:19.1 sec.


Quantitative Results 137821 SSAN5-02-0,00 BPC GRID B GO E 46 TALC FIBER

Element	Net Counts	Net Weight %	Weight % Error	Atom %	Atom % Error
Mg	50	20.26	+/- 3.24	22.92	+/- 3.67
Si	241	77.02	+/- 5.11	75.42	+/- 5.01
Ca	7	1.64	+/- 1.40	1.12	+/- 0.96
Ca	0	---	---	---	---
Fe	4	1.09	+/- 1.63	0.54	+/- 0.80
Fe	11	---	---	---	---
Total		100.00		100.00	

Full scale counts: 99

137821 SSAN5-02-0 00 BPC GRID C GO G41

Cursor: 5.075 keV
2 Counts



Wed Jul 07 16:38:24 2010

Gaussian Fit Chi Squared:0.768


Correction Method: Cliff-Lorimer (MBTS) w/o Absorbance

Live Time:68.1 sec.

Quantitative Results 137821 SSAN5-02-0 00 BPC GRID C GO G41

Element	Net Counts	Net Weight %	Weight % Error	Atom %	Atom % Error
Mg	754	37.15	+/- 1.43	41.55	+/- 1.60
Si	1486	57.76	+/- 1.55	55.90	+/- 1.50
Ca	13	0.37	+/- 0.26	0.25	+/- 0.17
Ca	0	---	---	---	---
Fe	143	4.73	+/- 0.53	2.30	+/- 0.26
Fe	45	---	---	---	---
Total		100.00		100.00	

Full scale counts: 67 GRID E E41 Cursor: 5.932 keV
4 Counts



Live Time: 46.5 sec.

Wed Jul 07 18:38:17 2010
 Gaussian Fit Chi Squared: 0.578
 Correction Method: Cliff-Lorimer (MBTS) w/o Absorbance


Quantitative Results GRID E E41

Element	Net Counts	Net Weight %	Weight % Error	Atom %	Atom % Error
Mg	273	38.10	+/- 2.51	42.04	+/- 2.77
Si	539	59.34	+/- 2.64	56.66	+/- 2.52
Ca	5	0.40	+/- 0.48	0.27	+/- 0.32
Ca	0	---	---	---	---
Fe	23	2.15	+/- 0.75	1.03	+/- 0.36
Fe	9	---	---	---	---
Total		100.00		100.00	

Full scale counts: 186

137821 SSAN5-02-0 00 BPC GRID E G31 NON ASB

Cursor: 5.999 keV
0 Counts



Wed Jul 07 18:27:02 2010

Gaussian Fit Chi Squared:0.595

Correction Method: Cliff-Lorimer (MBTS) w/o Absorbance

Live Time:29.6 sec.

Quantitative Results 137821 SSAN5-02-0 00 BPC GRID E G31 NON ASB

Element	Net Counts	Weight %	Weight % Error	Atom %	Atom % Error
Mg	268	14.73	+/- 0.99	16.86	+/- 1.13
Si	1897	82.24	+/- 1.95	81.49	+/- 1.93
P	6	0.26	+/- 0.30	0.23	+/- 0.27
Ca	4	0.13	+/- 0.19	0.09	+/- 0.13
Ca	0	---	---	---	---
Fe	72	2.65	+/- 0.44	1.32	+/- 0.22
Fe	2	---	---	---	---
Total		100.00		100.00	



EMS Laboratories Inc.
 117 West Bellevue Drive, Pasadena, CA 91105
 Phone: 626-568-4065 Fax: 626-796-5282
 Email: akolk@emslabs.com

Attn: Derrick Wills
 Tronox-LLC-Henderson
 PO Box 55
 Henderson, NV 89009

Phone: (947) 375-7004

Project: Tronox LLX Henderson, 560 W. Lake Mead Dr.,
 Henderson, NV/2027.001

Date Sampled: 5/12/2010 8:20AM

Customer ID: TRNX26
Customer PO: 2027.001
Received: 5/19/2010 10:05AM
EMS LAB No: 137821
Date Prepared: 7/1/2010 11:38AM
Analysis Date: 7/8/2010 10AM

Report Date:

NIOSH 7402/ISO

DRAFT, MODIFIED ELUTRIATOR METHOD FOR THE DETERMINATION OF ASBESTOS IN SOILS AND BULK MATERIAL METHOD

EMS Laboratory Number:	137821	Mass of Respirable Dust on Fiber:	137	µg
Customer Sample Number:	SSAK5-03-0.00BPC	Area of collection filter:	385	mm ²
Minimum Level of Analysis (chrysotile):	CD	Grid openings area:	0.0094	mm ²
Minimum Level of Analysis (amphibole):	ADX	Grid Openings Analyzed:	101	
Magnification used for fiber counting:	9,200 x	Min. Str. Length/Max Str. Diameter:	>5/<0.4	microns
Aspect ratio for fiber definition:	3:1			

Analyst(s): Radha Singh

Dust Generator - Total Dried Sample Weight-73.36g	Soil % Moisture	9.2	%
Not Used	Air Flow Rate Through ME Opening of Dust Generator:	1370	
Used in Tumbler	Air Flow Rate Through IST Opening of Dust Generator:	100	
	Estimate Total Air Flow Through Elutriator:	1470	

Analytical Sensitivity: 2.96E+06 Structure /g PM 10 **Limit of Detection:** 8.87E+06 Structure /g PM 10

Test For Uniformity (Chi-Square results)

Structure Class	Min ID Level Required	Counts		Density Str/mm ²	Conc. Str/g PM10	Poisson 95% Confidence Interval	
		Primary Str.	Total Str.			Lower Limit Str/g PM10	Upper Limit Str/g PM10
Asbestos Structures >5um, ≤10um	ADX/CD	1	1	1.05	2.96E+06	7.50E+04	1.65E+07
Asbestos Structures >5um, ≤10um (Chrys)	CD	1	1	1.05	2.96E+06	7.50E+04	1.65E+07
Asbestos Structures >5um, ≤10um (Amph)	ADX	0	0	0	0	0	8.87E+06
Asbestos Structure >10um (Long)	ADX/CD	0	0	0	0	0	8.87E+06
Asbestos Structure >10um (Chrys)	CD	0	0	0	0	0	8.87E+06
Asbestos Structure >10um (Amph)	ADX	0	0	0	0	0	8.87E+06
Total Protocol Asbestos Structures	ADX/CD	1	1	1.05	2.96E+06	7.50E+04	1.65E+07
Protocol Asbestos Structures (Chrys)	CD	1	1	1.05	2.96E+06	7.50E+04	1.65E+07
Protocol Asbestos Structures (Amph)	ADX	0	0	0	0	0	8.87E+06
Total Protocol Non Asbestos Structures	NAM	1	1	1.05	2.90E+06	7.50E+04	1.65E+07


 Approved by Technical Director

137821

Moisture content

44

6-9-10

#SSAN5-02.0.00 BPC

dish wt. 19.24

dish + samp. 119.65 - 19.24 = 100.41g (initial wt.)

11:40 111.91 - 19.24 = 92.67g

12:30-1:30 111.90 - 19.24 = 92.66g

1:30-2:30 111.65 - 19.24 = 92.41 (Final wt.)

$$\% \text{ Moist. } 100 \times \frac{100.41 - 92.41}{92.41} = 8.66\%$$

137821 #SSAK5-03-0.00 BPC

dish wt. 31.45

dish + samp. 131.57 - 31.45 = 100.12g (initial wt.)

11:40 123.43 - 31.45 = 91.98g

12:30 123.13 - 31.45 = 91.68g

1:30-2:30 123.10 - 31.45 = 91.65 (Final wt.)

$$\% \text{ Moist. } 100 \times \frac{100.12 - 91.65}{91.65} = 9.24\%$$

137821 #SSAL5-02-0.00 BPC

dish wt. 31.45

dish + samp. 131.48 - 31.45 = 100.03g (initial wt.)

11:40 127.66 - 31.45 = 96.21g

12:30 127.47 - 31.45 = 96.02g

1:30-2:30 127.55 - 31.45 = 96.10g

$$\% \text{ Moist. } 100 \times \frac{100.03 - 96.00}{96.00} = 4.2\%$$

BP

Report number: 137821
 Sample number: SSAKS-03-0.00 BPC
 File name: Northgate
 Sample Description: 137 mg

Filter Type: PC 385 mm²
 Date Sample was Run: 7/1/10
 Magnification: 9,200 X

Preparation date: 7/7/10 By JAP
 Analysis date: 7/8/10 By
 Grid loading moderate Condition of Grid Good

Grid opening dimension: 0.0094 mm²
 Level of Analysis: (C): CD, CDX

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
A	E31	N4D						
	F31	N4D						
	G31	N4D						
	C41	N4D						
	E41	N4D						
	F41	N4D						
	C51	N5D						
	F51	N4D						Basio CP
	J51	N4D						
	G51	N4D						Tale M7 4.5M
	H51	N5D						
	K51	N5D						
	C61	N5D						
	E61	N5D						Tale F 5K
	F61	N5D						" 4.5K
	E61	N5D						
	C23	N4D						Copy B 4.5M
	E23	N4D						
	F23	N4D						
	H23	N4D						
B	C31	N5D						
	E31	N5D						
	F31	N5D						
M	E31	1			MJL	69	170	3.54
	H31	N5D	1		MF	2.5	89	CMY
	C41	N5D						
	E41	N5D						
	F41	N5D						
	H41	N5D						
	K41	N5D						
	C51	N5D						

Report number: 137821

SAMPLE NO: SSAK5-03-0.00 BPC X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	F51	N5D						
	F51	N5D						
	G51	N5D						
	K51	N5D						
	C64	N5D						
	E64	N5D						
	F64	N5D						
	G64	N5D						
	H61	N5D						
C	B31	N5D						
	E31	N5D						
	F31	N5D						
	G31	N5D						
	H31	N5D						
	F41	N5D						
	E41	N5D						
	F41	N5D						
	G41	N5D						
	H41	N5D						
	K41	N5D						
	C51	N5D						
	E51	N5D						
	F51	N5D						
	G51	N5D						
	H51	N5D						Resid MDF < 5M
	K51	N5D						
	C61	N5D						
	E61	N5D						Non-Res F < 5M
	F61	N5D						
D	B26	N5D						
	C26	N5D						Non-Res MDF < 5M
	F26	N5D						
	G26	N5D						
	B31	N5D						
	B36	N5D						
	C36	N5D						
	E36	N5D						
	G36	N5D						

D Resid - a few holes, all other grids perfect

TEM Asbestos Structure Count (Page of)

Report number: 137821


SAMPLE NO: SSAK5-03-0.00BPC X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	B31	NSD						
	B33	NSD						
	C33	NSD						
	E33	2	2		MDU M.B	110 18	336 310	SAED 3545 Chm + 4F < 5M
	G33	NSD						
	H33	NSD						
	K33	NSD						
	G43	NSD						
	H43	NSD						
	K43	NSD						
E	E21	NSD						
	F21	NSD						
	C31	NSD						
	E31	NSD						
	F31	NSD						
	G31	NSD						
	H31	NSD						
	C41	NSD						
	E41	NSD						also E 25M 2.5M
	F41	NSD						
	G41	NSD						
	H41	NSD						
	C51	NSD						
	E51	NSD						
	F51	NSD						
	G51	NSD						
	H51	NSD						
	K51	NSD						Tab F < 5M
	E53	NSD						
G	G53	NSD						
	K43	NSD						
	R6-4	NSD						

Full scale counts: 301

137821 SSAKS-03-0 00BPC GRID D GO E33

Cursor: 6.066 keV
8 Counts



Thu Jul 08 18:23:18 2010

Gaussian Fit Chi Squared:1.652

Correction Method: Cliff-Lorimer (MBTS) w/o Absorbance

Live Time:24.9 sec.


Quantitative Results 137821 SSAKS-03-0 00BPC GRID D GO E33

Element	Net Counts	Weight %	Weight % Error	Atom %	Atom % Error
Mg	2693	42.54	+/- 0.85	46.77	+/- 0.94
Si	4346	54.16	+/- 0.86	51.53	+/- 0.82
Ca	68	0.62	+/- 0.16	0.41	+/- 0.11
Ca	5	---	---	---	---
Fe	253	2.68	+/- 0.26	1.28	+/- 0.13
Fe	52	---	---	---	---
Total		100.00		100.00	

Full scale counts: 129

137821 SSAKS -03-0.00 BPC GRID B GO G31

Cursor: 4.836 keV
5 Counts



Thu Jul 08 16:40:23 2010

Gaussian Fit Chi Squared:0.467

Correction Method: Cliff-Lorimer (MBTS) w/o Absorbance

Live Time:42.6 sec.

Quantitative Results 137821 SSAKS -03-0.00 BPC GRID B GO G31

Element	Net Counts	Weight %	Weight % Error	Atom %	Atom % Error
Mg	972	44.46	+/- 1.60	48.46	+/- 1.74
Si	1486	53.62	+/- 1.52	50.58	+/- 1.43
Ca	10	0.26	+/- 0.32	0.17	+/- 0.21
Ca	0	---	---	---	---
Fe	54	1.66	+/- 0.43	0.79	+/- 0.20
Fe	4	---	---	---	---
Total		100.00		100.00	

Copy 1

Count (Page of) NIOSH 7402/ISO

Report number : 137822 ^{INST} Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 7/18/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: 7/10 By WK, RS. Level of Analysis: (C): CD, CDX
 (A): ADX, ADQ
 Grid loading Right Condition of Grid Good

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
A	E21							
	E24							
	F21							
	F24							
	G21							
	G24							
	B26							
	C23							
	C26							
	E23							
	E26							
	F23							
	F26							
	G23							
	G26							
	F31							
	G31							
	G34							
	H31							
	H34							
	K34							
	F36							
	G33							
	G36							
	H33							
	H36							
	K33							
	K36							
	B46							
	C43							
	C46							
	E43							

Count (Page of) NIOSH 7402/ISO

Report number : 137822 ^{Final} Filter Blank2
Sample number: 00105200
File name: Northgate
Sample Description: NA mg

Filter Type: MCE 385 mm2
Date Sample was Run: NA
Prep Time: NA
Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP
Analysis date: 9-10 By BK
(A): ADX, ADQ
Grid loading Condition of Grid

Grid opening dimension: 0.0094 mm²
Level of Analysis: (C): CD, CDX

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	E46							
	M56							
	C53							
	C56							
	E37							
	F56							
	G61							
	F64							
10	E26							
	F22							
	F26							
	G23							
	G27							
	C34							
	E31							
	E34							
	F31							
	F34							
	G31							
	G34							
	F33							
	F36							
	G33							
	G36							
	H32							
	F44							
	G41							
	G44							
	H41							
	H44							
	K41							
	K44							

Removal folder

Count (Page 7 of) NIOSH 7402/ISO

Report number : 137822 ^{Just} Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By (A): ADX, ADQ Level of Analysis: (C): CD, CDX
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	G46							
	H46							
	H46							
	K43							
	K46							
	E51							
	E51							
	G51							
	G54							
	H51							
	H54							
	K51							
	K54							
	E51							
	G53							
	G54							
C	C2-6							
	F2-3							
	F2-6							
	V2-3							
	F2-6							
	G2-3							
	H2-6							
	H2-3							
	C3-7							
	C3-4							
	F3-4							
	F3-6							
	F3-7							
	F3-4							

137822

00105200

Normgate

4

TEM Asbestos Structure Count (Page of)

Report number:

SAMPLE NO:

X 9,200

5

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	63-4							
	63-4							
	1B-4							
	1A-4							
	C3-3							
	C2-6							
	E3-3							
	E3-6							
	E3-3							
	F2-1							
	63-3							
	63-3							
	1A-3							
	1B-6							
	C4-1							
	C4-4							
	E4-1							
	E4-4							
	1C4-1							
39	E4-4							
	64-1							
	64-4							
	F4-3							
	F4-6							
	1E4-3							
	1C4-6							
	64-3							
	64-6							
1D	C2-6							
	F2-3							
	F2-6							
	F2-3							
	E2-6							
	G2-3							
	G2-6							

137822

00105200

Norwidge

5

TEM Asbestos Structure Count (Page of)

Report number:

SAMPLE NO:

X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
D66	C3-1							
	C3-4							
	E3-1							
	E3-4							
	F3-1							
	F3-4							
	h3-1							
	h3-4							
	I3-1							
	I3-4							
	C3-2							
	C3-6							
	E3-3							
	E3-6							
	F3-3							
	F3-6							
	h3-3							
	h3-6							
	I3-3							
	I3-6							
	C4-1							
	C4-4							
	E4-1							
	E4-4							
	F4-1							
	F4-4							
	h4-1							
	h4-4							
	I4-1							
	I4-4							
	R4-3							
	R4-6							
	h4-3							
	h4-6							
	I4-3							
	I4-6							
IE	C2-6							

137822

00105200

Norwiche

TEM Asbestos Structure Count (Page of)

Report number:

SAMPLE NO:

X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
E 1nd	E23							
	E26							
	F23							
	F26							
	G23							
	G26							
	H23							
	E3-1							
	E3-4							
	F3-1							
	F3-4							
	G3-1							
	G3-4							
	H3-1							
	H3-4							
	C3-2							
	C3-6							
	E3-3							
	E3-6							
	G3-3							
	C4-1							
	C4-4							
	E4-1							
	E4-4							
	F4-1							
	F4-4							
	G4-1							
	G4-4							
	C5-1							
	C5-4							
	E5-1							
	F5-1							
	F5-4							
	G5-1							
	G5-4							
	H5-1							
	H5-4							
	I5-1							
	I5-4							
	J5-1							
	J5-4							
	K5-1							
	K5-4							

K5-1

Filter Lot Blank

Count (Page of) NIOSH 7402/ISO

Prep Time: NA

Report number: 137822 Filter Blank 1

Filter Type: NCE 385 mm²

Sample number: 0005200

Date Sample was Run: NA

File name: Northgate

Sample Description: NA mg

Magnification: 9,200 X

Preparation date: 6/8/10

By: JAP

Grid opening dimension: 0.0094 mm²

Analysis date: 1/9/10

By: AE

Level of Analysis: (C): CD, CDX

(A): ADX, ADQ

Grid loading: Very Light

Condition of Grid: Good

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	C26							
	E27							
	E26							
	E22							
	F26							
	G22							
	C31							
	F04							
	E31							
	E34							
	F31							
	F34							
	G31							
	G34							
	H31							
	B44							
	C41							
	C44							
	E41							
	E44							
	F41							
	F44							
	G41							
	B44							
	H41							
	H44							
	V41							
	X44							
	C51							
	C54							
	E51							
	E54							

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX
 (A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	F 51							
	F 54							
	G 51							
	G 54							
	H 51							
	H 54							
	K 51							
	G 61							
B	C 26							
	E 23							
	F 26							
	F 23							
	F 26							
	G 23							
	G 26							
	D 36							
	C 33							
	C 36							
	E 33							
	E 36							
	F 33							
	F 36							
	H 33							
	H 36							
	K 33							
	K 36							
	D 46							
	C 43							
	C 46							
	E 43							
	E 46							
	F 43							

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By (A): ADX, ADQ Level of Analysis: (C): CD, CDX
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	F46							
	G43							
	G46							
	H43							
	H46							
	K43							
	K46							
	C53							
	C56							
	E53							
	E56							
	F53							
	F56							
	G53							
	G56							
	H53							
C	B24							
	C31							
	C34							
	E31							
	E34							
	F31							
	F34							
	G31							
	G34							
	H31							
	H34							
	B41							
	B44							
	C41							
	C44							
	E41							

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX
 (A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	E44							
	F41							
	F44							
	G41							
	G44							
	H41							
	H44							
	K41							
	B51							
	B54							
	C51							
	C54							
	E51							
	E54							
	F51							
	F54							
	G51							
	G54							
	H51							
	H54							
	C61							
	C64							
	E64							
	E61							
B	C23							
	C26							
	E23							
	F26							
	F23							
	G23							
	G26							
	H23							

TEM-10A (2002)

0 grid torn where placed in grid bag

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX

(A): ADX, ADQ

Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	B36							
	C33							
	C36							
	E33							
	E36							
	F33							
	F36							
	G33							
	G36							
	H33							
	H36							
	H46							
	C43							
	C46							
	E43							
	E46							
	F43							
	F46							
	G43							
	G46							
	H43							
	H46							
	K43							
	K46							
	B56							
	C53							
	C56							
	E53							
	E56							
	F53							
	F56							
	G53							

Count (Page 6 of 7) NIOSH 7402/ISO

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By (A): ADX, ADQ Level of Analysis: (C): CD, CDX

Grid loading *Very light* Condition of Grid *Good*

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
E	B31							
	B34							
	C21							
	C34							
	E31							
	E34							
	F31							
	F34							
	G31							
	G34							
	H31							
	H34							
	B41							
	D44							
	C41							
	C44							
	E41							
	E44							
	F41							
	F44							
	G41							
	G44							
	H41							
	H44							
	K41							
	K44							
	B54							
	C51							
	C54							
	E51							
	E54							
	F51							
	F54							

0.094 micrometers < 500

Count (Page 7 of 7) NIOSH 7402/ISO

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX

(A): ADX, ADQ

Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	E54							
	G51							
	E54							
	H51							
	H54							
	K51							
	E61							
	E64							

TEM ASBESTOS ANALYSIS

Client Sand blank
 Sample No. 5-12-10

EMS Lab No. _____
 Page _____ of _____

TYPE OF SAMPLE
 Air Water
 Soil Bulk
 Other Sand

LENGTHS
 All Sizes (EPA)
 (µm) ≥ 0.5
 ≥ 1.0
 ≥ 2.5
 ≥ 10.0
 PCM Range*
 * ≥ 0.25 µm width
 ≥ 5.0 µm length)

FILTER TYPE / AREA (mm²)
 MCE 385
 PC 314
 MCN 107
 Other _____

METHOD OF ANALYSIS
 EPA 600/4-83-043 ISO
LEVEL OF ANALYSIS
 Chrysotile _____
 Amphibole _____

PORE SIZE
 0.45 µm 0.8 µm
 0.1 µm 0.22 µm
 Other _____

ASPECT RATIO
 3:1 5:1

G.O. Area (mm²) 0.094
 No. of G.O. to Analyze 200
67/gmc

EPA/600/R-94/134 100.1 100.2

PREP

DIRECT PREP
 INDIRECT PREP

Volume _____ liters
 Working Volume _____ ml
 Weight 50 grams
 Ashed Area _____ %

Prepared By JAP
 Date 5/12/10

RECEIVING

MICROSCOPE
 H600A - Serial No. 542-36-01
 H600B - Serial No. 542-05-06
 H600C - Serial No. 542-24-03

ENERGY DISPERSIVE X-RAY SYSTEM
 Keveex - Model No. 3200-0106-0365
 Keveex - Model No. 3600-0206-0146
 Quantum System

Grid Address: A
 Screen Magnification: 9800 X
 Camera Constant: 28.3
 Accelerating Voltage: 100KV
 Beam Current: 10 µA
 K-Factor: 1.4

Analyst Radh Date 5/13/10

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification										EDS Analysis						Comments								
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	AUX	AQ	ADQ	AZQ	AZZ	Ns		Mg	Si	Ca	Pb				
C23		NXP																											
C26																													
E23																													
E28																													
F23																													
F28																													
G23																													
G28																													
H23																													
C3-1				4.5	75																								
C34																													
E3-1																													
E34																													
F3-1																													
F34																													

OBSERVATIONS:
 Clean
 Debris:
 Gypsum:
 Condition of the Grid:

Moderate
 Moderate
 Undissolved Filter
 Light
 Light
 Scrappy
 Very Light
 Very Light
 Good

Heavy
 Heavy
 Folded
 Very Heavy
 Very Heavy

TEM - 1A (1-08)

TEM ASBESTOS ANALYSIS

Client Saved blank
 Sample No. S-12-10

EMS Lab No. _____
 Page 2 of _____

RECEIVING

ANALYSIS

MICROSCOPE

- H600A - Serial No. 542-36-01
 - H600B - Serial No. 542-05-06
 - H600C - Serial No. 542-24-03
- ENERGY DISPERSIVE X-RAY SYSTEM**
- Keveex - Model No. 3200-0106-0365
 - Keveex - Model No. 3600-0206-0146
- Quantum System

Grid Address: A
 Screen Magnification: X
 Camera Constant: _____
 Accelerating Voltage: 100KV
 Beam Current: _____ μ A
 K-Factor: _____

Analyst _____ Date _____

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification												EDS Analysis					Comments						
			Width	Length	NAM	TM	CM	CD	CO	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	Na	Mg	Si		Ca	Fe				
G3-1		N7D																										
G3-4																												
H3-1																												
H3-4																												
C3-3																												
G3-6																												
E3-3																												
E3-6																												
F3-3																												
F3-6																												
G3-3																												
G3-6																												
H3-3																												
H3-6																												
K3-3																												

OBSERVATIONS:

- Clean
- Debris:
- Gypsum:
- Condition of the Grid:

- Very Light
- Light
- Scrappy

- Moderate
- Moderate
- Undissolved Filter

- Heavy
- Very Heavy
- Folded

TEM ASBESTOS ANALYSIS

Client Sand block
 Sample No. 5-12-70

EMS Lab No. _____ of _____
 Page 3

MICROSCOPE

HG00A - Serial No. 542-35-01
 HG00B - Serial No. 542-05-06
 HG00C - Serial No. 542-24-03

ENERGY DISPERSIVE X-RAY SYSTEM

Kevex - Model No. 3200-0106-0965
 Kevex - Model No. 3600-0206-0146
 Quantum System

Grid Address: A
 Screen Magnification: X
 Camera Constant: _____
 Accelerating Voltage: 100KV
 Beam Current: _____ μA
 K-Factor: _____

Analyst P. d.L. Date 5-13-10

RECEIVING ANALYSIS

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification											EDS Analysis					Comments				
			Width	Length	NAM	TM	CM	CD	CO	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZ	Na		Mg	Si	Ca	Re
K4-1		P-7																							
K4-4																									
K4-7																									
K4-9																									
K4-1																									
K4-4																									
K4-7																									
K4-9																									
K4-1																									
K4-4																									
K4-7																									
K4-9																									
K4-1																									
K4-4																									
K4-7																									
K4-9																									
K4-1																									
K4-4																									
K4-7																									
K4-9																									

OBSERVATIONS: Clean Debris: Gypsum: Condition of the Grid: _____

Very Light Light Moderate Heavy Very Heavy

Very Light Light Moderate Heavy Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand blank
 Sample No. S-12-10

EMS Lab No. _____ of _____
 Page _____ of _____

RECEIVING

ANALYSIS

- MICROSCOPE**
- H600A - Serial No. 542-36-01
 - H600B - Serial No. 542-05-06
 - H600C - Serial No. 542-24-03
 - ENERGY DISPERSIVE X-RAY SYSTEM
 - Kevex - Model No. 3200-0106-0365
 - Kevex - Model No. 3600-0206-0146
 - Quantum System

Grid Address: A
 Screen Magnification: X
 Camera Constant: _____
 Accelerating Voltage: 100KV
 Beam Current: _____ μ A
 K-Factor: _____

Analyst: Roddy Date: 5-13-10

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification										EDS Analysis					Comments						
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ		Na	Mg	Si	Ca	Fe	
G43		N-y																								
G48																										
H43																										
H46																										
K43																										
K46																										
E5B																										
E54																										
F51																										
F54																										
G51																										
G54																										
H51		F-																								
H54		N-y																								
K51																										

OBSERVATIONS:

Clean
 Debris:
 Gypsum:
 Condition of the Grid:

Very Light
 Very Light
 Light
 Light
 Moderate
 Moderate
 Heavy
 Heavy
 Very Heavy
 Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand blank
 Sample No. 5-12-10

EMS Lab No. _____
 Page 5 of _____

RECEIVING

SISVIVV

- MICROSCOPE**
- H600A - Serial No. 542-36-01
 - H600B - Serial No. 542-05-06
 - H600C - Serial No. 542-24-03
 - ENERGY DISPERSIVE X-RAY SYSTEM
 - Kevex - Model No. 3200-0106-0365
 - Kevex - Model No. 3600-0206-0146 Quantum System

Grid Address: A
 Screen Magnification: X
 Camera Constant: _____
 Accelerating Voltage: 100KV
 Beam Current: _____ μ A
 K-Factor: _____

Analyst Rondke Date 5-13-10

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification										EDS Analysis					Comments						
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ		Na	Mg	SI	Ca	Fe	
CS-2		N-10																								
CS-6																										
ES-3																										
ES-6																										
ES-7																										
ES-8																										
US-3																										
US-6																										

OBSERVATIONS:

Clean
 Debris:
 Gypsum:
 Condition of the Grid:

Very Light
 Very Light
 Light
 Light
 Moderate
 Moderate
 Heavy
 Heavy
 Very Heavy
 Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand blank EMS Lab No. _____
 Sample No. S-12-10 Page 1 of _____

- MICROSCOPE**
- H600A - Serial No. 542-36-01
 - H600B - Serial No. 542-05-06
 - H600C - Serial No. 542-24-03
- ENERGY DISPERSIVE X-RAY SYSTEM**
- Kevex - Model No. 3200-0106-0365
 - Kevex - Model No. 3600-0206-0146 Quantum System

Grid Address: B
 Screen Magnification: 9,200 X
 Camera Constant: 28.3
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 K-Factor: 1.4

Analyst Kadk Date 5/18/10

RECEIVING ANALYSIS

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification													EDS Analysis				Comments						
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ	Na	Mg		Si	Ca	Fe			
<u>G23</u>																												
<u>G26</u>																												
<u>E23</u>																												
<u>E26</u>																												
<u>F23</u>																												
<u>F26</u>																												
<u>G23</u>																												
<u>G26</u>																												
<u>F23</u>																												
<u>G31</u>																												
<u>G34</u>																												
<u>E37</u>																												
<u>E34</u>																												
<u>F37</u>																												
<u>F34</u>																												

OBSERVATIONS:

Clean Debris: Gypsum:

Very Light Light Moderate Heavy Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand blank EMS Lab No. _____
 Sample No. S-12-10 Page 1 of _____

RECEIVING

ANALYSIS

- MICROSCOPE
 H600A - Serial No. 542-36-01
 H600B - Serial No. 542-05-06
 H600C - Serial No. 542-24-03
ENERGY DISPERSIVE X-RAY SYSTEM
 Kevex - Model No. 3200-0106-0365
 Kevex - Model No. 3600-0206-0146
 Quantum System

Grid Address: B
 Screen Magnification: 9,200 X
 Camera Constant: 28.5
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 K-Factor: 1.4

Analyst Radh Date 5/18/10

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification												EDS Analysis				Comments										
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ	Na		Mg	Si	Ca	Fe						
L254		N20																													
L254																															
L130		F																													
L254		N20	2.0	130																											
L254																															
L254																															
L254																															
L153																															
L254																															
L254																															

OBSERVATIONS:

- Clean
 Debris:
 Gypsum:

- Very Light
 Light

- Moderate
 Moderate

- Heavy
 Heavy

- Very Heavy
 Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand blank
 Sample No. S-12-10

EMS Lab No. _____
 Page 7 of _____

ANALYSIS

MICROSCOPE
 H600A - Serial No. 542-36-01
 H600B - Serial No. 542-05-06
 H600C - Serial No. 542-24-03
ENERGY DISPERSIVE X-RAY SYSTEM
 Levas - Model No. 300-0106-0365
 Levas - Model No. 360-0206-0146
 Quantum System

Grid Address: B
 Screen Magnification: 9,200 X
 Camera Constant: 28.5
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 K-Factor: 1.4

Analyst Radh Date 5/18/10

RECEIVING

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification												EDS Analysis	Comments								
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ			ADQ	AZQ	AZZ	Na	Mg	Si	Ca	Fe
C47																										
C47																										
E47																										
R47																										
R47																										
R47																										
Q47																										
Q47																										
H47																										
H47																										
V47																										
V47																										
C48																										
E43																										
R46																										

OBSERVATIONS:
 Clean
 Debris:
 Gypsum:
 Very Light
 Light
 Moderate
 Heavy
 Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand blank EMS Lab No. _____
 Sample No. 5-12-10 Page 4 of _____

RECEIVING

ANALYSIS

MICROSCOPE

H600A - Serial No. 542-36-01
 H600B - Serial No. 542-05-06
 H600C - Serial No. 542-24-03

ENERGY DISPERSIVE X-RAY SYSTEM
 Levee - Model No. 3200-0106-0365
 Levee - Model No. 3600-0206-0146
 Quantum System

Grid Address: B
 Screen Magnification: 9,200 X
 Camera Constant: 28-2
 Accelerating Voltage: 100KV
 Beam Current: 10 14
 K-Factor: 14

Analyst Radh Date 5/18/10

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification												EDS Analysis					Comments					
			Width	Length	NAM	TM	CM	CD	CQ	CMO	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZJ	Na	Mg		Si	Ca	Fe		
R243		W>D																									
R406																											
Q113																											
U148																											
1-453																											
1446																											
V113																											
V140			25	130																							
15-11		W>D																									
15-24																											
E5-1																											
F5-4																											
F5-7																											
F5-10																											
W5-1																											

OBSERVATIONS:

Clean
 Debris:
 Gypsum:

Very Light
 Light
 Moderate
 Heavy
 Very Heavy


TEM ASBESTOS ANALYSIS

Client Sand blank EMS Lab No. _____
 Sample No. S-12-10 Page 5 of _____

MICROSCOPE
 H600A - Serial No. 542-36-01
 H600B - Serial No. 542-05-06
 H600C - Serial No. 542-24-03
ENERGY DISPERSIVE X-RAY SYSTEM
 Kevex - Model No. 3200-0106-0365
 Kevex - Model No. 3600-0206-0146
 Quantum System

Grid Address: B
 Screen Magnification: 9,200 X
 Camera Constant: 28.3
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 R-Factor: 1.4

Analyst Radh Date 5/18/10




Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification												EDS Analysis					Comments					
			Width	Length	NAM	TM	CM	CD	CO	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ	Na	Mg		Si	Ca	Fe		
W52A																											
B57																											
H54																											
V5-1																											
B6-1																											
E6-2																											
R6-7																											
G6-1																											

OBSERVATIONS:
 Clean
 Debris:
 Gypsum:
 Very Light
 Very Light
 Light
 Light
 Moderate
 Moderate
 Heavy
 Heavy
 Very Heavy
 Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand bank
 Sample No. 5-12-70

EMS Lab No. _____
 Page _____ of _____



MICROSCOPE

- H600A - Serial No. 542-35-01
- H600B - Serial No. 542-05-06
- H600C - Serial No. 542-24-03

ENERGY DISPERSIVE X-RAY SYSTEM

- Kevex - Model No. 3200-0106-0565
- Kevex - Model No. 3600-0206-0146 Quantum System

Grid Address: C
 Screen Magnification: 4200 X
 Camera Constant: 283
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 K-Factor: 1.4

Analyst Reddy Date 5/13/10


Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification										EDS Analysis				Comments									
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	AUX	AQ	ADQ	AZQ		AZZ	Na	Mg	Si	Ca	Fe			
E23																												
E24																												
E23																												
R24																												
V22		F	1.8	32																								
U24																												
H23																												
H26																												
G31																												
G34																												
R25																												
R34																												
F34		F	3.5	55																								
R34																												
G31																												

- OBSERVATIONS:**
- Clean
 - Debris:
 - Gypsum:
 - Condition of the Grid:
 - Very Light
 - Light
 - Moderate
 - Moderate
 - Heavy
 - Very Heavy
 - Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand Bank
 Sample No. 5-12-10

EMS Lab No. _____ of _____
 Page _____



- MICROSCOPE**
- H600A - Serial No. 542-36-01
 - H600B - Serial No. 542-05-06
 - H600C - Serial No. 542-24-03
- ENERGY DISPERSIVE X-RAY SYSTEM**
- Kevex - Model No. 3200-0106-0365
 - Kevex - Model No. 3600-0206-0146 Quantum System

Grid Address: C
 Screen Magnification: 9200 X
 Camera Constant: 283
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 K-Factor: 1.4

Analyst: Rodh Date: 5/13/10

Grid Opening	Structure Number	Structure	Dimensions (mm)			Fiber Classification										EDS Analysis				Comments								
			Width	Length		NAM	TM	CM	CD	CO	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ		AZZ	Na	Mg	Si	Ca	Fe		
G3-4		RSD																										
H3-1																												
H3-2																												
K3-1																												
K3-2																												
L3-1																												
L3-2																												
L3-3																												
L3-4																												
L3-5																												
L3-6																												
L3-7																												
L3-8																												
L3-9																												
L3-10																												

OBSERVATIONS:

- Clean
- Debris: General Light Moderate Heavy Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand Bank
 Sample No. 5-12-10

EMS Lab No. _____
 Page 3 of _____

RECEIVING ANALYSIS

MICROSCOPE
 H600A - Serial No. 542-36-01
 H600B - Serial No. 542-05-06
 H600C - Serial No. 542-24-03

ENERGY DISPERSIVE X-RAY SYSTEM
 Kevex - Model No. 3200-0106-0365
 Kevex - Model No. 3600-0206-0146
 Quantum System

Grid Address: C
 Screen Magnification: 9200 X
 Camera Constant: 283
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 X-Factor: 1.4

Analyst Rodh Date 5/13/10

Grid Opening	Structure Number	Structure	Dimensions (mm)			Fiber Classification										EDS Analysis					Comments							
			Width	Length		NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ		Na	Mg	Si	Ca	Fe		
K33																												
K36																												
C47																												
C49																												
B7																												
B44																												
B41																												
F40																												
S07																												
S04																												
H41																												
M49																												
K41																												
K40																												
B53																												


OBSERVATIONS:

Clean Heavy Very Heavy
 Debris: Heavy Very Heavy
 Contamin Moderate Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand Bank
 Sample No. 5-12-10

EMS Lab No. _____
 Page 1 of _____



MICROSCOPE
 H600A - Serial No. 542-36-01
 H600B - Serial No. 542-05-06
 H600C - Serial No. 542-24-03
 ENERGY DISPERSIVE X-RAY SYSTEM
 Keveex - Model No. 3200-016-0365
 Keveex - Model No. 3600-0216-0146
 Quantum System

Grid Address: C
 Screen Magnification: 9200 X
 Camera Constant: 283
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 K-Factor: 1.4

Analyst Roddy Date 5/13/10

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification										EDS Analysis					Comments						
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ		Na	Mg	Si	Ca	Fe	
R276		R276																								
R43		R43																								
R476		R476																								
603																										
6476																										
R43		R43	2	65																						
17476																										
603																										
6476																										
A57																										
R43		R43																								
657																										
657																										

OBSERVATIONS:

- Clean
- Debris:
- Quantum:
- Very Light
- Light
- Moderate
- Heavy
- Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand Bank
 Sample No. S-1270

EMS Lab No. _____ of _____
 Page _____

RECEIVING **ANALYSIS**

MICROSCOPE

- H600A - Serial No. 542-36-01
- H600B - Serial No. 542-05-06
- H600C - Serial No. 542-24-03

ENERGY DISPERSIVE X-RAY SYSTEM

- Leica - Model No. 3200-0106-0365
- Leica - Model No. 3600-0206-0146 Quantum System

Grid Address: C
 Screen Magnification: 4200 X
 Camera Constant: 282
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 X-Factor: 1.4

Analyst: Rodh Date: 5/13/10

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification										EDS Analysis					Comments							
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ		Na	Mg	Si	Ca	Fe		
K5-4																											
K5-7																											
K5-4																											
K5-7																											
K5-6																											
K5-3																											
K5-6																											
K5-3																											
K5-6																											

OBSERVATIONS:

- Clean
- Debris:
- Gaseous
- Very Light
- Light
- Moderate
- Heavy
- Very Heavy

Count (Page / of) NIOSH 7402/ISO

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: LOT 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: 7/8/10 By (A): ADX, ADQ Level of Analysis: (C): CD, CDX

Grid loading *Very light* Condition of Grid *Good*

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
A	C23							
	C26							
	E23							
	E26							
	F23							
	F26							
	G23							
	G26							
	H23							
	H26							
	I23							
	C33							
	C36							
	E33							
	E36							
	F33							
	F36							
	G33							
	G36							
	H33							
	H36							
	K33							
	K36							
	E43							
	E46							
	F43							
	F46							
	G43							
	G46							
	H43							
	H46							
	I43							

TEM-10A (2002)

Count (Page *101*) NIOSH 7402/ISO

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX

(A): ADX, ADQ

Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	V46							
	B56							
	C53							
	C56							
	E53							
	E56							
	F53							
	F56							
B	C23							
	C26							
	E23							
	E26							
	F23							
	F26							
	C31							Boycott
	E34							
	E31							
	F34							
	F31							
	F34							
	B36							
	C33							
	C56							
	E33							
	E56							
	F33							
	F31							
	B44							
	C41							
	C44							
	E41							
	E44							

TEM-10A (2002)

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX
 (A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	F41							
	F44							
	G41							
	G44							
	H41							
	H44							
	B46							
	C43							
	C46							
	E43							
	E46							
	F43							
	F46							
	G43							
	G46							
	F56							
C	E27							
	E24							
	F21							
	B26							
	C23							
	C26							
	E23							
	E26							
	F23							
	F26							
	G23							
	G26							
	H23							
	H26							
	B36							
	C33							

TEM-10A (2002)

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX
 (A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	C36							
	E33							
	E36							
	F33							
	F66							
	G33							
	G36							
	H33							
	H36							
	K33							
	B43							Org
	B46							
	C43							
	C46							
	E43							
	E46							
	F43							
	F46							
	G43							
	G46							
	H43							
	H46							
	K43							
	C52							
	C56							
P	E21							
	E24							
	F21							
	B34							
	C31							
	C34							
	E31							

TEM-10A (2002)

Count (Page of) NIOSH 7402/ISO

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX
 (A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	F34							
	F31							
	F34							
	G31							
	G34							
	H31							
	H34							
	B41							
	E41							
	E44							
	F41							
	F44							
	G41							
	G44							
	H41							
	H44							
	K41							
	K44							
	B54							
	C51							
	C54							
	E51							
	E54							
	F51							
	F54							
	B56							
	C53							
	C56							
	E53							
	E56							
	F53							
	F56							

TEM-10A (2002)

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX
 (A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
✓	C23							
	C24							
	E23							
	E24							
	F23							
	F24							
	G23							
	G24							
	H23							
	H24							
	B33							
	C33							
	C34							
	E33							
	E34							
	F33							
	F34							
	G33							
	B43							
✓	C43							
	E43							
	E44							
	F43							
	F44							
	G43							
	C44							
	H43							
	H44							
	K43							
	F53							
	F54							

TEM-10A (2002)

Count (Page of) NIOSH 7402/ISO

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By (A): ADX, ADQ Level of Analysis: (C): CD, CDX

Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	G53							
	G56							
	H53							
	H56							
	K53							
	C64							
	E61							
	E64							
	F61							
	F64							

TEM -10A (2002)

Spot Size Measurements

Scope: H60B
Date: May 2010
Name: R_s

Conditions of Measurements

High Voltage: 100K
Beam Current: 10 μ A
Magnification: 19,200
Condenser Aperture Size: #2


Measurements from a photo 8.5

Shortest diameter: 8.5 mm
Longest diameter: 9 mm
Average: 8.75 mm

Spot Size Calculation

$$\text{Spot size in } \mu\text{m} = \frac{(\text{average spot size in mm}) \times 1000 \mu\text{m} \times 0.4125}{\text{Magnification}} \quad 188$$

Note: $1.65/4 = 0.4125$ (see the Hitachi Fax)



TEM CAMERA CONSTANT DETERMINATION

TEM H600B

Measured and Calculated by RS Date May 2010

Camera Constant (mm A) = D (mm) X 1/2 X d (A)

where D (mm) is the diameter of a gold ring and

d (A) is the d-spacing in Angstroms for a particular reflection

CC (1*) = (24.1 mm) X 1/2 x 2.355 = 28.34

CC (2*) = (27.8 mm) X 1/2 x 2.039 = 28.34

CC (3*) = (39.3 mm) X 1/2 x 1.442 = 28.34

CC (4*) = (45.9 mm) X 1/2 x 1.230 = 28.3


Average Camera Constant = $\sqrt{28.3}$

* 1 is the first largest diameter ring. 2 the second, etc.

Average Camera Constant = (CC<1> + ... + CC<n>) X 1/n

For gold:

d(A)	nk1
2.355	(111)
2.039	(200)
1.442	(220)
1.230	(311)
1.1774	(222)



08/07/01
csl

DATE: May 2010
 WEEKLY CALIBRATION 3m
 MONTHLY CALIBRATION 3m
 AFTER SERVICE CALIBRATION _____


A-600/B-600/C-600

BY: R

Measurement	Number of Spacing Flourescent Screen Magnification	Distance (mm)	Number of Spacing Film Magnification
1	25,000x 53/6 - 19,260	12,000x 51/12 - 9,180	
2	53/6 - 19,260	51.5/12 - 9,270	
3	53/6 - 19,080	51.5/12 - 9,270	
4	53/6 - 19,180	51/12 - 9,180	
5	53.5/6 - 19,260	51/12 - 9,180	
6		51/12 - 9,180	
7	ave 19,200		
8		ave 9,200	
9			
10			
AVERAGE:			

OPERATING VOLTAGE 100 KV

- 54, 864 lines/inch or 2,160 lines/mm or 0.463µm/line
- 28, 800 lines/inch or 1,134 lines/mm or 0.882µm/line
- 15, 240 lines/inch or 600 lines/mm or 1.67µm/line
- 16.94 µm for one bar and one opening for Ni screen on edge



FORM CALIBRATION 2
 1992)

SCOPE B

K = [Cn/C(Si)] / [In/(Si)]
C(Si) = 18.74

n	Cn	RUN 1		RUN 2		RUN 3		RUN 4		RUN 5		RUN 6	
		I(Si)=	In	I(Si)=	In	I(Si)=	In	I(Si)=	In	I(Si)=	In	I(Si)=	In
Na	1.81	22860	1694	12101	1095	15953	986	16554	1004	16203	395	7464	1.8251
Mg	7.57	1.3034	3738	1.0674	1.3077	1.5627	1.4491	1.4112	1.3641	1.3885	1.5587	1.5205	
Al	6.54	1.027	4152	1.0171	5455	1.0206	5761	1.0028	5708	0.9906	2576	1.0112	
Si	18.74	1	12101	1	15953	1	16554	1	16203	1	7464	1	
K	0.97	0.8144	827	0.7574	1311	0.6299	1333	0.6428	1195	0.7018	584	0.6615	
Ca	8.26	1.5336	3406	1.566	5845	1.203	5222	1.3973	4998	1.4289	2852	1.1535	
Ti	3.02	1.6483	1170	1.6668	1821	1.4118	1867	1.4289	1753	1.4895	928	1.2962	
Mn	0.14	17.078	22	4.1092	12	9.9316	29	4.2645	2	60.523	22	2.5346	
Fe	9.51	1.9669	2935	2.0923	4934	1.6408	4856	1.73	4473	1.8383	2351	1.6111	
O	43.83		7849	3.6059	7051	5.2917	10526	3.6783	9433	4.0174	3333	5.2377	

**** NVLAP REQUIREMENTS ****


- 1.0 < K(Na) wrt Si < 4.0
- 1.0 < K(Mg) & K(Fe) wrt Si < 2.0
- 1.0 < K(Al) & K(Ca) wrt Si < 1.75

K(Mg)/K(Fe) < 1.5

stdev < 10% for Mg, Al, Si, Fe
stdev < 20% for Na
wrt mean value of k-factor wrt Si

SCOPE B

RUN 7		RUN 8		RUN 9		RUN 10		RUN 11		RUN 12		RUN 13	
I(Si)=	In	I(Si)=	In	I(Si)=	In	I(Si)=	In	I(Si)=	In	I(Si)=	In	I(Si)=	In
12627	4491	15830	14684	25368	25374	15830	14684	25368	25374	1542	25374	4628	4628
Kn		Kn		Kn		Kn		Kn		Kn		Kn	
849	1.4365	950	1.6094	982	1.4442	1543	1.5879	1542	1.5893	1542	1.5893	4628	Kn
3523	1.4478	4331	1.4765	4325	1.3715	7480	1.37	7479	1.3705	7479	1.3705	1213	1.5412
4458	0.9885	5717	0.9663	5043	1.0162	9260	0.9561	9260	0.9563	9260	0.9563	1556	1.038
12627	1	15830	1	14684	1	25368	1	25374	1	25374	1	4628	1
1099	0.5947	1505	0.5444	1185	0.6414	2315	0.5672	2318	0.5666	2318	0.5666	363	0.6599
4553	1.2224	6257	1.1151	4602	1.4064	9813	1.1394	9832	1.1375	9832	1.1375	1754	1.163
1480	1.3749	1994	1.2794	1703	1.3895	3188	1.2823	3196	1.2794	3196	1.2794	510	1.4624
4	23.583	7	16.894	25	1.7048	8840	7.5806	8884	1.4494	8884	1.4494	6	5.7624
3889	1.6477	5899	1.3618	4371	3.6262	35609	1.4563	8840	1.4494	8884	1.4494	1497	1.5689
6102	4.8398	5950	6.2225	9471	6.2225	35609	1.6662	13315	4.4571	13315	4.4571	2045	5.293



Auto Manual FWHM FSS Bench Test

Elements

Atomic Symbol Line:

Atomic Symbol Line:

Ratio Peaks

Additional Measurements

Measure Zero Peak Measure FWHM and FWTM


Acquisition Criteria

C LiveTime (s) Max Time:

Peak Count No. Traks:

Time Constant (Slow)

Peak #	Min. Channel	Max. Channel	FWHM (eV)	Avg. FWHM
1	5.895	5.991	146.79	146.79
2	5.895	5.930	155.00	151.89
3	5.894	3178	155.83	153.21
4	5.892	3379	149.17	152.20
5	5.891	3438	155.40	152.84
	---	---	---	---
Avg:	5.893	3883	152.84	
Sigma:	0.002	988	3.34	
RMS:	0.0%	10.0%	2.3%	



Auto | Manual FWHM | F=55 Bench Test

Elements

Atomic Symbol Mn Line K

Atomic Symbol Line K

Ratio Peaks

Additional Measurements

Measure Zero Peak Measure FWHM and FWTM

Acquisition Criteria

Lifetime (s) Max Time: 50

Peak Count No. Trials: 5

Time Constant: 50 (Slow)

Trial #	Mn Centroid ...	Net Counts	FWHM (eV)	Avg. FWHM ...
1	5.896	1277	126.16	126.16
2	5.900	5295	151.73	138.95
3	5.897	6460	146.02	141.30
4	5.898	5560	146.26	142.54
5	5.899	5291	133.62	140.76
				...
Avg:	5.898	4776	140.76	
Stdev:	0.001	2014	10.52	
RMS:	0.0%	42.2%	7.5%	

137821



Laboratory Submittal Form

Date: _____ Time: _____ Relinquished by: _____
 Client: Northgate Date of Shipment: _____
 Address: 1100 Quail Street, Suite 102 Shipped from: _____ Carrier: _____
 Newport Beach, CA 92660 Client P.O. No: 2027.01
 Telephone: 949-260-9293 Client Project ID: COC# 02027.01.2126
 Contact: Derrick Willis TRINOX LLC, Henderson
 Results via: Fax No: Email address: Derrick.Willis@ngem.com Verbal
 (Complete written reports will follow all analyses, in addition to any prior verbal, fax, or email results)

Turnaround Time: STD Sample Preservatives: _____
 Number of Samples: 10 (3 each) Sampler's Name: _____
 Date & Time of Sample Collection: 5-12-10 Holding Times: _____ Signature: _____
 Type: Water Waste Water Soil Filter Impinger Sorbent Tube Other

EMS Only	Client Sample No.	Description/Location	Analysis	Volume/Weight
1	SSAP8-01-0.00BPC			
2	SSAP8-01-0.00BPC_FD			
3	SSAP8-01-0.33BPC			
4	SSAN7-03-0.33BPC			
5	SSAN7-03-0.00BPC_FD			
6	SSAN7-03-0.00BPC			
7	SSAN5-02-0.00BPC	SEE ATTACHMENT		
8	SSAN5-02-0.33BPC			
9	SSAK5-03-0.00BPC			
10	SSAK5-03-0.33BPC			
11				
12				
13				
14				
15				
16				
17				

EDD send to: Frank.Hagar@ngem.com

137821

For EMS Only
 Laboratory Number: _____ Received by: _____ Time: 10:05
 Date of Package Delivery: 5/19/2010 Shipping Bill Retained? yes
 Condition of Package on Receipt: OK Condition of Custody Seal: NONE
 Number of Samples: 10 Chain of Custody Signature: _____
 Disposition of Samples: EMS LABS Misc. Info: SF 7/06

137821 Revised



environmental management, inc.
1100 Quail Street, Suite 102
Newport Beach, CA 92660 (949) 260-9293

CHAIN-OF-CUSTODY / Analytical Request Document
The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed and accurate.

COC # 02027.01.2126 Revised 2010-06-25

Total # of Samples: 10 Event Complete?

Required Project Information:
 Site ID #: TRONOX LLC, HENDERSON
 Project #: 2027.01
 Site Address: 660 W Lake Mead Drive
 City: Henderson State, Zip: NV, 89015
 Phone/Fax: 626-563-4665 / Derrick Willis
 Lab PM email: alkolli@emslabs.com
 Applicable Lab Quote #:
 Site PM Email: derrick.willis@ngem.com

Required Invoice Information:
 Send Invoice to:
 Address: PO Box 55
 City/State: Henderson, NV 89009 Phone #: (949) 260-9293
 PO #:
 Send EDD to: Frank.Hagan@ngem.com
 CC Hardcopy report to: PDF Electronic Version Only - FTP Upload
 CC Hardcopy report to:

ITEM #	SAMPLE ID Samples IDs MUST BE UNIQUE	SAMPLE LOCATION	MATRIX CODE	G-RAB C-COMP	SAMPLE TYPE	SAMPLE DATE	SAMPLE TIME	#OF CONTAINERS	Comments/Lab Sample I.D.	Analysis	Regular	Rush	Mark One
	SSAP8-01-0.00BPC	SSAP8-01	SO	C	N	05/12/2010	13:05	3		X			
	SSAP8-01-0.00BPC_FD	SSAP8-01	SO	C	FD	05/12/2010	13:05	3		X			
	SSAN7-03-0.33BPC	SSAN7-03	SO	C	N	05/12/2010	13:20	3	Hold	H			
	SSAN7-03-0.33BPC_FD	SSAN7-03	SO	C	N	05/12/2010	12:28	3	Hold	H			
	SSAN7-03-0.00BPC	SSAN7-03	SO	C	FD	05/12/2010	12:15	3		X			
	SSAN5-02-0.00BPC	SSAN5-02	SO	C	N	05/12/2010	12:15	3		X			
	SSAN5-02-0.33BPC	SSAN5-02	SO	C	N	05/12/2010	09:10	3		X			
	SSAK5-03-0.00BPC	SSAK5-03	SO	C	N	05/12/2010	09:22	3	Hold	H			
	SSAK5-03-0.33BPC	SSAK5-03	SO	C	N	05/12/2010	08:20	3		X			
							08:29	3	Hold	H			

Additional Comments/Special Instructions:
 Modification by Joni Fisher NGEI, modifications shown in bold font

Company: Francisco Barron
 Tracking #: DATE SIGNED: TIME

Sample Receipt Conditions:
 Temp in OC: Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N
 Samples on Ice?: Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N
 Sample Intact?: Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N
 Trip Blank?: Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N Y/N

137821

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed and accurate



1100 Quail Street, Suite 102
Newport Beach, CA 92660 (949) 260-9293

Required Project Information:
 Site ID #: TRONOX LLC. HENDERSON
 Project #: 2027.01
 Site Address: 560 W Lake Mead Drive
 City: Henderson State: NV Zip: 89015
 Site PM Name: Derrick Willis
 Phone/Fax: (949) 375-7004
 Site PM Email: derrick.willis@ngem.com

Required Invoice Information:
 Send Invoice to:
 Address: PO Box 55
 City/State: Henderson, NV 89008 Phone #: (949) 280-9293
 PO #:
 Send EDD to: Frank.Hagar@ngem.com
 CC Hardcopy report to: PDF Electronic Version Only - FTP Upload
 CC Hardcopy report to:

Required Information:
 Lab Name: EMS Laboratories, Inc.
 Address: 117 W Bellevue Dr
 City: Pasadena, CA 91105
 Lab PM: Tony Kolk
 Phone/Fax: 626-588-4065
 Lab PM email: akolk@emslabs.com
 Applicable Lab Quote #:

ITEM #	SAMPLE ID Samples IDs MUST BE UNIQUE	SAMPLE LOCATION	MATRIX CODE	G-GRAB C-COMP	SAMPLE TYPE	SAMPLE DATE	SAMPLE TIME	# OF CONTAINERS	Comments/Lab Sample I.D.	Regular		Rush	Mark One
										Y/N	Y/N	X	
1	SSAP8-01-0.00BPC	SSAP8-01	SO	C	N	05/12/2010	13:05	3					
2	SSAP8-01-0.00BPC_FD	SSAP8-01	SO	C	FD	05/12/2010	13:05	3					
3	SSAP8-01-0.33BPC	SSAP8-01	SO	C	N	05/12/2010	13:20	3					
4	SSAN7-03-0.33BPC	SSAN7-03	SO	C	N	05/12/2010	12:26	3					
5	SSAN7-03-0.00BPC_FD	SSAN7-03	SO	C	FD	05/12/2010	12:15	3					
6	SSAN7-03-0.00BPC	SSAN7-03	SO	C	N	05/12/2010	12:15	3					
7	SSAN5-02-0.00BPC	SSAN5-02	SO	C	N	05/12/2010	09:10	3					
8	SSAN5-02-0.33BPC	SSAN5-02	SO	C	N	05/12/2010	09:22	3					
9	SSAK5-03-0.00BPC	SSAK5-03	SO	C	N	05/12/2010	08:20	3					
10	SSAK5-03-0.33BPC	SSAK5-03	SO	C	N	05/12/2010	08:29	3					

Additional Comment/Special Instructions:

RELINQUISHED BY / AFFILIATION: Environmental Management, Inc. DATE: 5/12/10 TIME: 15:06
 ACCEPTED BY / AFFILIATION: [Signature] DATE: 5/12/10 TIME: 15:06

SHIPPING INFO: Company: Francisco Barron Tracking #: 151216
 PRINTER NAME OF SAMPLER: Francisco Barron SIGNATURE OF SAMPLER: [Signature] DATE SIGNED: 5/12/10

Temp in OC: 15.06

Sample Receipt Conditions:
 Samples on Ice? Y/N: Y/N
 Sample Intact? Y/N: Y/N
 Trip Blank? Y/N: Y/N

COC # 02027.01.2126
 Total # of Samples: 10
 Event Complete?