



117 W. Bellevue Drive
Pasadena, CA 91105

NARRATIVE

July 8, 2010

Derrick Willis
Tronox LLC-Henderson
560 West Lake Mead
Henderson, NV 89015

SDG/EMS# 137865
Project: 2027.01, Tronox LLC Henderson,
560 West Lake Mead Drive, Henderson, NV
Client COC ID: 02027.01.2129

REFERENCE:	DAS Case No. 0769F	TDD No.: 07-10-0012
	Task No. 0361	P. O. No.: 0063941
	Tronox Project# 2027.01	NGE Tracking# 03
	AUI Task# 6	

EMS REPORT NO.: 137865

When the samples are analyzed in the TEM the recorded data includes the dimensions of the respirable fibers of the regulated asbestos types, namely, chrysotile, Amosite (cummingtonite/grunerite), tremolite, actinolite, crocidolite, and anthophyllite. The fibers of importance are those included in the protocol fiber classification. The width of the protocol fibers is <0.4 μm and the length is divided into two groups, 5 to 10 μm and long fibers >10 μm . The 95% Poisson Confidence interval for the observed concentration of fibers is also calculated. Other asbestos fibers and non-asbestos fibers with protocol dimensions are noted in the counting sheet. The problem regarding the loss of particles on polycarbonate filters has been eliminated except for very alkaline particles. There is no evidence that asbestos fibers are lost.





EMS Laboratories Inc.
 117 West Bellevue Drive, Pasadena, CA 91105
 Phone: 626-568-4065 Fax: 626-796-5282
 Email: akolk@emslabs.com

Attn: Derrick Wills
 Tronox-LLC-Henderson
 PO Box 55
 Henderson, NV 89009

Phone: (947) 375-7004

Project: Tronox LLX Henderson, 560 W. Lake Mead Dr.,
 Henderson, NV/2027.001

Customer ID: TRNX26
 Customer PO: 2027.001
 Received: 5/20/2010 9:50AM
 EMS LAB No: 137865
 Date Prepared: 7/2/2010 12:15PM
 Analysis Date: 6/8&7/12 0:00

Report Date:

Date Sampled: 5/18/2010 11:55

NIOSH 7402/ISO

DRAFT, MODIFIED ELUTRIATOR METHOD FOR THE DETERMINATION OF ASBESTOS IN SOILS AND BULK MATERIAL METHOD

EMS Laboratory Number: 137865	Mass of Respirable Dust on Fiber: 174	µg
Customer Sample Number: SSAL6-02-0.00BPC	Area of collection filter: 385	mm ²
Minimum Level of Analysis (chrysotile): CD	Grid openings area: 0.0094	mm ²
Minimum Level of Analysis (amphibole): ADX	Grid Openings Analyzed: 96	
Magnification used for fiber counting: 9,200 x	Min. Str. Length/Max Str. Diameter: >5/<0.4	microns
Aspect ratio for fiber definition: 3:1		

Analyst(s): Radha Singh


Dust Generator - Total Dried Sample Weight-73.94g	Soil % Moisture	7.87	%
Not Used	Air Flow Rate Through ME Opening of Dust Generator:	1370	
Used in Tumbler	Air Flow Rate Through IST Opening of Dust Generator:	100	
	Estimate Total Air Flow Through Elutriator:	1470	

Analytical Sensitivity: 2.45E+06 Structure /g PM 10 Limit of Detection: 7.34E+06 Structure /g PM 10

(Note: Amended report per client request to reflect the EPA definition of greater than 10µm and less than 0.4µm)

Test For Uniformity (Chi-Square results)

Structure Class	Min ID Level Required	Counts		Density St/mm ²	Conc. Str/g PM10	Poisson 95% Confidence Interval	
		Primary Str.	Total Str.			Lower Limit Str/g PM10	Upper Limit Str/g PM10
Asbestos Structures >5µm, ≤10µm	ADX/CD	0	0	0	0	0	7.34E+06
Asbestos Structures >5µm, ≤10µm (Chrys)	CD	0	0	0	0	0	7.34E+06
Asbestos Structures >5µm, ≤10µm (Amph)	ADX	0	0	0	0	0	7.34E+06
Asbestos Structure >10µm (Long)	ADX/CD	0	0	0	0	0	7.34E+06
Asbestos Structure >10µm (Chrys)	CD	0	0	0	0	0	7.34E+06
Asbestos Structure >10µm (Amph)	ADX	0	0	0	0	0	7.34E+06
Total Protocol Asbestos Structures	ADX/CD	0	0	0	0	0	7.34E+06
Protocol Asbestos Structures (Chrys)	CD	0	0	0	0	0	7.34E+06
Protocol Asbestos Structures (Amph)	ADX	0	0	0	0	0	7.34E+06
Total Protocol Non Asbestos Structures	NAM	0	0	0	0	0	7.34E+06


 Approved by Technical Director



NIOSH 7402/ISO

117 W. Bellevue Drive
Pasadena, CA 91105
626-568-4065

Client:	Derrick Willis, Tronox LLC-Henderson	Filter Type:	MCE 385 mm ²
Report number :	137865	Magnification:	9200
Sample number:	SSAL6-02-0.00BPC	Grid Opening Dimension:	0.0094
Project:	2027.001/Tronox LLC Henderson, 560 W. Lake Mead Dr.,	Grid Loading:	Light Moderate

Elutriation Date: 7/2/2010 by Joel Paruli
Preparation Date: 7/7/2010 by Joel Paruli
Analysis Date: 7/8/10 and 7/12/10 by Radha Singh

Grid Openings 96
Mass - ug 174
Anlytical sensitivity

Asbestos Structures >5um, ≤10um (Chrys) 0
 Asbestos Structures >5um, ≤10um (Amph) 0
 Asbestos Structure >10um (Chrys) 0
 Asbestos Structure >10um (Amph) 0
 Protocol Asbestos Structures (Chrys) 0
 Protocol Asbestos Structures (Amph) 0

Grid ID	Grid Opening	Structure Type	Structure Number		Dimensions (µm)		Level of ID	Mineral Type	Image Number	Structure Comments
			Primary	Total	Width	Length				
1A	C26	None Detected								
1A	E26	None Detected								
1A	F26	None Detected								
1A	G26	None Detected								
1A	C26	None Detected								
1A	E36	None Detected								
1A	F36	None Detected								
1A	G36	None Detected								
1A	H36	None Detected								
1A	B46	None Detected								
1A	C46	None Detected								
1A	E46	None Detected								
1A	F46	None Detected								
1A	G46	None Detected								
1A	H46	None Detected								
1A	K46	None Detected								
1A	E56	None Detected								
1A	F56	None Detected								
1B	C26	None Detected								
1B	E23	None Detected								
1B	E26	None Detected								
1B	F23	None Detected								
1B	F26	None Detected								
1B	G23	None Detected								
1B	C34	None Detected								
1B	E31	None Detected								
1B	E34	None Detected								
1B	F31	None Detected								
1B	F34	None Detected								
1B	G31	None Detected								
1B	G34	None Detected								
1B	H31	None Detected								
1B	E41	None Detected								
1B	E44	None Detected								
1B	F41	None Detected								
1B	G43	None Detected								
1B	G46	None Detected								
1C	C31	None Detected								
1C	C34	None Detected								
1C	E31	None Detected								
1C	E34	None Detected								
1C	F31	None Detected								
1C	F34	None Detected								

MD F>5µ Non Asbesto:

Elutriator Data

Lab #: 137865

Date: 7/2/10

Client: Northgate

Sample ID: SSAL6-02-0.00 Pp2 Sample weight (g): 73.94

Time air flow started: 800

Tumbler rpm: 30

IST Flowmeter (mL/min): 100

ME Flowmeter (mL/min): 1370

Filter No.	Start Time	Tested flow rate (mL/min)	Final Filter Wt (mg)	Initial Filter Wt (mg)	Dust Weight (mg)	Time Value (min)	Avg. rate of deposition (ug/min)	Optimal time (min)
1	1000	170	0.03202	0.02432	7.70	30		
2	1030		0.02658	0.02441	2.17	15		
3	1045		0.02471	0.02423	2.48	15		
4	1100		0.02935	0.02443	4.92	15		
5	1115		0.03222	0.02430	7.92	25		
6	1140		0.02791	0.02442	3.49	30		
7	1210		0.02003	0.02527	4.76	25		
8	1235		0.02789	0.2595	1.94	30		
Time							Dep. Rate	Estimate
1	1126	1137	41.610	486	0.125			
2	1150	1205	40.615	486	0.135	11		
3	1215	1232	4.632	4.405	0.240	15		
4	1245	1302	4.612	4.458	0.174	17		
5				4.492	0.120	17		
6								
7								
8								

3% loss
 65% loss
 70% loss
 OK
 100% loss
 100% loss
 100% loss
 100% loss

7/7/10 (prep)

137865

Moisture content

46

6-10-10

SSAL6-02-00BPC

dish wt.	19.24 g		
dish + samp.	119.54	- 19.24 =	100.30 g (initial wt.)
11:30 - 12:30	119.40	- 19.24 =	93.16
12:45 - 1:45	111.98	- 19.24	92.74
1:45 - 2:40	111.94	- 19.24	92.70 (Final wt.)

$$\% \text{ moist. } = 100 \times \frac{100 - 92.70}{92.70} = 7.87\%$$

SSAL6-01-00BPC

dish wt.	31.47 g		
dish + samp.	131.40	- 31.47 =	99.93 g (initial wt.)
11:30 - 12:30	125.72	- 31.47 =	94.25
12:45 - 1:45	124.96	- 31.47 =	93.49
1:45 - 2:40	124.92	- 31.47	93.45 (Final wt.)

$$\% \text{ moist. } = 100 \times \frac{99.93 - 93.45}{93.45} = 6.93\%$$

SSAP7-02-0.00BPC

dish wt.	31.44 g		
dish + samp.	131.83	- 31.44 =	100.39 (initial wt.)
11:30 - 12:30	131.08	- 31.44 =	99.64
12:45 - 1:45	131.04	- 31.44 =	99.60 (Final wt.)

$$\% \text{ moist. } = 100 \times \frac{100.39 - 99.60}{99.60} = 0.79\%$$

BP

Copy

80 GD

Count (Page of) NIOSH 7402/ISO

Prep Time: 12⁰⁰ 23⁰⁰

Report number: 137865
Sample number: SSALG-02-0.00 BPC
File name: Northgate
Sample Description: 174 mg

Filter Type: 385 mm2
Date Sample was Ruri: 7/2/10
Magnification: 9,200 X

Preparation date: 7/7/10 By JAP
Analysis date: 7/8/10 By BK/120
7/12/10 (A): ADX, ADQ
Grid loading 1.4 / Moderate Condition of Grid Dark / Excellent

Grid opening dimension: 0.0094 mm²
Level of Analysis: (C): CD, CDX

2 1/2 hrs

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
A	C26	N40						
	K26	N50						
	F26	N40						
	G26	N40						
	C36	N50						
	I36	N50						
	F36	N50						
	G36	N50						
	H36	N50						
	B46	N40						
	C46	N50						
	E46	N40						
	F46	N40						
	G46	N50						
	H46	N50						
	K46	N50						
	E56	N50						
	F56	N50						
B	C26	N20						
	E23	N20						
	F23	N20						
	K23	N20						
	F26	N20						
	H23	N20						
	C34	N20						
	E34	N20						
	F34	N20						
	K34	N20						
	G37	N20						
	H34	N20						

MD F-5K Non-Dig No SEMED

TEM Asbestos Structure Count (Page of)

Report number: 137865

SAMPLE NO: SSAL6-02-0.00BPCx 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	E4-4	N20						
	H4-4	N20						
	G4-4	N20						
	H4-4	N20						
	H4-4	N20						
	K4-4	N20						
	N4-4	N20						
	N4-4	N20						
	#4-4	N20						
	H4-4	N20						
	B6-4	N20						
	C6-4	N20						
	G6-4	N20						
2)	H6-4	N20						
1/2	C3-3	N20						
	C3-6	N20						
	E3-3	N20						
	E3-6	N20						
	F3-3	N20						
	F3-4	N20						
	G3-1	N20						
	G3-4	N20						
	H3-1	N20						
	H3-4	N20						
	C4-4	N20						
	E4-1	N20						
	E4-4	N20						
	F4-1	N20						
	F4-4	N20						
	G4-3	N20						
	G4-6	N20						
	H4-3	N20						
1/1	H4-6	N20						

TEM Asbestos Structure Count (Page of)

Report number: 137865

SAMPLE NO: SSALG-02-0.00BPC X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	1B-1	N/D						
	E1-1	N/D						
	E1-4	N/D						
	F4-1	N/D						
	G4-3	N/D						
19	G1-6	N/D						
1C	R3-1	N/D						
	C3-4	N/D						
	E3-1	N/D						
	E3-4	N/D						
	F3-1	N/D						
	F3-6	N/D						
	G2-6	N/D						
	H1-3	N/D						
	E4-1	N/D						
	E4-4	N/D						
	E4-7	N/D						
	R4-4	N/D						
	G4-1	N/D						
	G4-4	N/D						
	H4-1	N/D						
	G1-1	N/D						
	G1-4	N/D						
	H1-1	N/D						
19	H1-4	N/D						
1D	C3-3	N/D						
	C3-6	N/D						
	E3-3	N/D						
	E3-6	N/D						
	R3-3	N/D						
	R3-6	N/D						
	F4-1	N/D						



EMS Laboratories Inc.
 117 West Bellevue Drive, Pasadena, CA 91105
 Phone: 626-568-4065 Fax: 626-796-5282
 Email: akolk@emslabs.com

Attn: Derrick Wills
 Tronox-LLC-Henderson
 PO Box 55
 Henderson, NV 89009

Customer ID: TRNX26
 Customer PO: 2027.001
 Received: 5/20/2010 9:50AM
 EMS LAB No: 137865
 Date Prepared: 7/6/2010 2:05PM
 Analysis Date: 7/21/2010 0:00

Project: Tronox LLX Henderson, 560 W. Lake Mead Dr.,
 Henderson, NV/2027.001

Report Date: August 9, 2010

Date Sampled: 5/18/2010 9:10AM

NIOSH 7402/ISO

DRAFT, MODIFIED ELUTRIATOR METHOD FOR THE DETERMINATION OF ASBESTOS IN SOILS AND BULK MATERIAL METHOD

EMS Laboratory Number: 137865	Mass of Respirable Dust on Fiber: 132	µg
Customer Sample Number: SSAL6-01-0.00BPC	Area of collection filter: 385	mm ²
Minimum Level of Analysis (chrysotile): CD	Grid openings area: 0.0094	mm ²
Minimum Level of Analysis (amphibole): ADX	Grid Openings Analyzed: 106	
Magnification used for fiber counting: 9,200 x	Min. Str. Length/Max Str. Diameter: >5/<0.4	microns
Aspect ratio for fiber definition: 3:1		

Analyst(s): Radha Singh

Dust Generator - Total Dried Sample Weight-75.8g	Soil % Moisture	6.9 %
Not Used	Air Flow Rate Through ME Opening of Dust Generator:	1370
Used in Tumbler	Air Flow Rate Through IST Opening of Dust Generator:	133
	Estimate Total Air Flow Through Elutriator:	1503

Analytical Sensitivity: 2.93E+06 Structure /g PM 10 Limit of Detection: 8.77E+06 Structure /g PM 10

Test For Uniformity (Chi-Square results)

Structure Class	Min ID Level Required	Counts		Poisson 95% Confidence Interval			
		Primary Str.	Total Str.	Density Str/mm ²	Conc. Str/g PM10	Lower Limit Str/g PM10	Upper Limit Str/g PM10
Asbestos Structures >5um, ≤10um	ADX/CD	18	18	17.9	5.27E+07	3.12E+07	8.34E+07
Asbestos Structures >5um, ≤10um (Chrys)	CD	18	18	17.9	5.27E+07	3.12E+07	8.34E+07
Asbestos Structures >5um, ≤10um (Amph)	ADX	0	0	0	0	0	8.78E+06
Asbestos Structure >10um (Long)	ADX/CD	15	15	14.9	4.37E+07	2.47E+07	7.25E+07
Asbestos Structure >10um (Chrys)	CD	15	15	14.9	4.37E+07	2.47E+07	7.25E+07
Asbestos Structure >10um (Amph)	ADX	0	0	0	0	0	8.78E+06
Total Protocol Asbestos Structures	ADX/CD	33	33	32.9	9.67E+07	6.66E+07	1.36E+08
Protocol Asbestos Structures (Chrys)	CD	33	33	32.9	9.67E+07	6.66E+07	1.36E+08
Protocol Asbestos Structures (Amph)	ADX	0	0	0	0	0	8.78E+06
Total Protocol Non Asbestos Structures	NAM	5	5	4.98	1.47E+07	4.75E+06	3.42E+07


 Approved by Technical Director



Client:	Derrick Willis, Tronox LLC-Henderson	Filter Type:	PC 385 mm ²
Report number :	137865	Magnification:	9200
Sample number:	SSAL6-01-0.00BPC	Grid Opening Dimension: mm²	0.0094
Project:	2027.001/Tronox LLC Henderson, 560 W. Lake Mead Dr.,	Grid Loading:	Moderate

Elutriation Date: 7/6/2010 by Joel Paruli
Preparation Date: 7/15/2010 by Joel Paruli
Analysis Date: 7/21/2010 by Radha Singh

Asbestos Structures >5um, ≤10um (Chrys)	18	Grid Openings	106
Asbestos Structures >5um, ≤10um (Amph)	0	Mass - ug	132
Asbestos Structure >10um (Chrys)	15	Analytical sensitivity	
Asbestos Structure >10um (Amph)	0		
Protocol Asbestos Structures (Chrys)	33		
Protocol Asbestos Structures (Amph)	0		

Grid ID	Grid Opening	Structure Type	Structure Number		Dimensions - mm		Dimensions (µm)		Level of ID	Mineral Type	Image Number	Structure Comments
			Primary	Total	Width	Length	Width	Length				
1A	E21	None Detected										
1A	F21	None Detected										
1A	G21	None Detected										
1A	C31	None Detected										
1A	E31	None Detected										
1A	F31	None Detected										
1A	G31	None Detected										
1A	H31	None Detected										
1A	K31	F	1	1	2.5	63	0.27	6.85	CD	CHRYSOTILE		
		F	2	2	0.5	50	0.05	5.43	CD	CHRYSOTILE		
1A	C41	F	3	3	2.5	78	0.27	8.48	CD	CHRYSOTILE		
		F	4	4	0.5	58	0.05	6.30	CD	CHRYSOTILE		
1A	E41	None Detected										
1A	F41	None Detected										
1A	G41	MD11	5		50	145	5.43	15.76				
		MF		5	1.5	110	0.16	11.96	CD	CHRYSOTILE		
		MD11	6		55	610	5.98	66.30				Crosses grid bar, Double
		MF		6	2.5	610	0.27	66.30	CD	CHRYSOTILE		
1A	H41	MD11	7		10	80	1.09	8.70				
		MF		7	2	80	0.22	8.70	CD	CHRYSOTILE		
1A	K41	None Detected										
1A	C51	None Detected										
1A	E51	F	8	8	2	74	0.22	8.04	CD	CHRYSOTILE		
1A	F51	None Detected										
1A	G51	MD11	9		45	65	4.89	7.07				
		MF		9	3	65	0.33	7.07	CD	CHRYSOTILE		
1A	H51	None Detected										
1A	K51	None Detected										
1B	F26	MD11	10		50	90	5.43	9.78				
		MF		10	0.5	75	0.05	8.15	CD	CHRYSOTILE		
1B	G26	None Detected										
1B	F36	None Detected										
1B	G21	MD11			5	170	0.54	18.48				Non Asbestos
		MF			18	90	1.96	9.78				Non Asbestos
1B	G36	None Detected										
1B	H36	None Detected										
1B	B46	None Detected										
1B	F46	None Detected										
1B	G46	None Detected										
1B	H41	None Detected										
1B	C56	None Detected										
1B	E56	F	11	11	1.5	96	0.16	10.43	CD	CHRYSOTILE		
1B	F56	None Detected										



NIOSH 7402/ISO

117 W. Bellevue Drive
Pasadena, CA 91105
626-568-4065

Report Number: [REDACTED]
Sample number: [REDACTED]

Analyzed by: [REDACTED]
Date of Analysis: [REDACTED]

Grid ID	Grid Opening	Structure Type	Structure Number		Dimensions (µm)			Level of ID	Mineral Type	Image Number	Structure Comments
			Primary	Total	Width	Length	Length				
1B	G56	F	12	12	2.5	340	0.27	36.96	CD	CHRYSOTILE	Crosses grid bar
1B	H56	None Detected									
1B	C64	None Detected									
1B	E64	None Detected									
1B	F64	None Detected									
1B	G64	None Detected									
1B	E54	None Detected									
1B	F54	None Detected									
1B	G54	F			0.5	52	0.05	5.65			Non Asbestos Si
		MD11	13		20	135	2.17	14.67			
		MF		13	2	155	0.22	16.85	CD	CHRYSOTILE	
1C	F31	None Detected									
1C	C31	None Detected									
1C	E31	None Detected									
1C	F31	None Detected									
1C	G31	None Detected									
1C	H31	None Detected									
1C	C41	None Detected									
1C	E41	F	14	14	2	100	0.22	10.87	CD	CHRYSOTILE	
1C	F41	F			3	55	0.33	5.98			Non Asbestos Al, k, Fe, Si
		MD11	15		40	125	4.35	13.59			
		MF		15	1.5	115	0.16	12.50	CD	CHRYSOTILE	
		F	16	16	0.75	90	0.08	9.78	CD	CHRYSOTILE	
1C	G41	None Detected									
1C	K41	MD11	17		6	68	0.65	7.39			
		MF		17	1	68	0.11	7.39	CD	CHRYSOTILE	
1C	C51	None Detected									
1C	E51	None Detected									
1C	F51	None Detected									
1C	G51	None Detected									
1C	H51	F			2	89	0.22	9.67			Non Asbestos, Al
1C	K51	MD11	18		10	78	1.09	8.48			
		MF		18	1.5	78	0.16	8.48	CD	CHRYSOTILE	
		MD11	19		85	300	9.24	32.61			Crosses grid Bar (MD)
		MF		19	2.5	112	0.27	12.17	CD	CHRYSOTILE	F (Does not cross grid bar)
1C	C61	None Detected									
1C	E61	None Detected									
1C	F61	None Detected									
1C	G61	MD11			5	49	0.54	5.33			Non Asbestos
		MF			0.5	49	0.05	5.33			Non Asbestos
1D	E21	None Detected									
1D	G21	None Detected									
1D	B31	MD11	20		23	220	2.50	23.91			
		MB		20	4	220	0.43	23.91	CD	CHRYSOTILE	
		MD11	21		30	270	3.26	29.35			
		MF		21	1	270	0.11	29.35	CD	CHRYSOTILE	Crosses grid bar
1D	C31	F	22	22	2.5	130	0.27	14.13	CD	CHRYSOTILE	Crosses grid bar
1D	E31	None Detected									
1D	F31	None Detected									
1D	H31	None Detected									
1D	B41	None Detected									
1D	C41	None Detected									
1D	F41	MD11	23		6	110	0.65	11.96			
		MF		23	2.5	110	0.27	11.96	CD	CHRYSOTILE	
		F	24	24	0.3	55	0.03	5.98	CD	CHRYSOTILE	
		F	25	25	2	105	0.22	11.41	CD	CHRYSOTILE	



NIOSH 7402/ISO

117 W. Bellevue Drive
Pasadena, CA 91105
626-568-4065

Report Number: [Redacted]
Sample number: [Redacted]

Analyzed by: [Redacted]
Date of Analysis: [Redacted]

Grid ID	Grid Opening	Structure Type	Structure Number		Dimensions (µm)		Level of ID	Mineral Type	Image Number	Structure Comments
			Primary	Total	Width	Length				
1D	G41	None Detected								
1D	H41	None Detected								
1D	K41	MD11	26		50	91	5.43	9.89		
		MF		26	2	91	0.22	9.89	CD	CHRYSOTILE
1D	B51	None Detected								
1D	C51	None Detected								
1D	E51	None Detected								
1D	F51	None Detected								
1D	G51	None Detected								
1D	H51	MD11	27		25	85	2.72	9.24		
		MF		27	2.5	85	0.27	9.24	CD	CHRYSOTILE
1D	B33	None Detected								
1D	C33	None Detected								
1D	E33	MD11	28		14	110	1.52	11.96		
		MB		28	1.5	100	0.16	10.87	CD	CHRYSOTILE
1E	B21	None Detected								
1E	C31	None Detected								
1E	E31	None Detected								
1E	F31	MD11	29		90	115	9.78	12.50		
		MF		29	1.5	70	0.16	7.61	CD	CHRYSOTILE
1E	B41	None Detected								
1E	C41	None Detected								
1E	E41	F	30	30	1.5	60	0.16	6.52	CD	CHRYSOTILE
		MD11			140	160	15.22	17.39		
		MF			5.5	160	0.60	17.39	ADX	AMOSITE
1E	F41	None Detected								
1E	G41	None Detected								
1E	B51	None Detected								
1E	C51	F	31	31	0.5	50	0.05	5.43	CD	CHRYSOTILE
		MD11	32		50	92	5.43	10.00		
		MF		32	0.25	92	0.03	10.00	CD	CHRYSOTILE
1E	E51	None Detected								
1E	F51	None Detected								
1E	G51	None Detected								
1E	B61	None Detected								
1E	C61	F			3	60	0.33	6.52		Non Asbestos
1E	E61	None Detected								
1E	F61	None Detected								
1E	G61	None Detected								
1E	E44	MD11	33		140	200	15.22	21.74		
		MF		33	2	120	0.22	13.04	CD	CHRYSOTILE

Elutriator Data
Lab #: 137865

Date: 7/6/10

Client: Northgate

Sample ID: SSALF-01-0.00 PPG Sample weight (g): 75.8

Time air flow started: 815

Tumbler rpm: 30

IST Flowmeter (mL/min): 100

ME Flowmeter (mL/min): 1370

Filter No.	Start Time	Tested flow rate (mL/min)	Final Filter Wt (mg)	Initial Filter Wt (mg)	Dust Weight (mg)	Time Value (min)	Avg. rate of deposition (ug/min)	Optimal time (min)
1	1015	85	0.02887	0.02540	3.47	30		
2	1045		0.03165	0.02530	6.35	15		
3	1100		0.03258	0.02491	7.67	20		
4	1120		0.02822	0.02499	3.23	30		
5	1150		0.03158	0.02536	6.22	25		
6	1215		0.02791	0.02578	2.13	30		
7	1245		0.03007	0.02549	4.58	25		
8	1305		0.03333	0.02520	8.13	25		
Time							Dep. Rate	Estimate
1110	1118		4.577	4.502	0.075	8		
1132	1148		4.576	4.459	0.117	16		
1210	1242		4.539	4.489	0.050	22		
1250	1304		4.529	4.495	0.034	16		
1320	1346		4.510	4.510	0.215	26		
1405	1425		4.707	4.575	0.132	20		

loss 80%
loss 5%
loss 5%
loss 75%
loss 2%
loss 95%
loss 5%
pk

prep 7/15/10

* Change 1st flow 133 @ 1253 pm

137865

Moisture content

46

6-10-10

SSALG-02-00BPC

dish wt.	19.24 g		
dish + samp.	119.54	- 19.24 =	100.30 g (initial wt.)
11:30 - 12:30	119.40	- 19.24 =	93.16
12:45 - 1:45	111.98	- 19.24 =	92.74
1:45 - 2:40	111.94	- 19.24 =	92.70 (Final wt.)

$$\% \text{ Moist. } = 100 \times \frac{100 - 92.70}{92.70} = 7.87\%$$

SSALG-01-00BPC

dish wt.	31.47 g		
dish + samp.	131.40	- 31.47 =	99.93 g (initial wt.)
11:30 - 12:30	125.72	- 31.47 =	94.25
12:45 - 1:45	124.96	- 31.47 =	93.49
1:45 - 2:40	124.92	- 31.47 =	93.45 (Final wt.)

$$\% \text{ Moist. } = 100 \times \frac{99.93 - 93.45}{93.45} = 6.93\%$$

SSAP7-02-0.00BPC

dish wt.	31.44 g		
dish + samp.	131.83	- 31.44 =	100.39 (initial wt.)
11:30 - 12:30	131.08	- 31.44 =	99.64
12:45 - 1:45	131.04	- 31.44 =	99.60 (Final wt.)

$$\% \text{ Moist. } = 100 \times \frac{100.39 - 99.60}{99.60} = 0.79\%$$

BP

Prep Time: 1030-1300

Report number: 137665
 Sample number: SSALG-01-0.00 BPC
 Site name: Northgate
 Sample Description: 132 mg

Filter Type: PC 385 mm²
 Date Sample was Run: 7/6/10

DO 10580

Preparation date: 7/15/10 By JAP
 Analysis date: 7/24/10 By _____
 Grid loading: Md (A): ADX, ADQ
 Condition of Grid: Good

Grid opening dimension: 0.0094 mm²
 Level of Analysis: (C): CD, CDX

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
A	E21							
	F31							
	G21							
	C31							Ca PO ₄
	E31							
	F31							
	G31							
	H31							
	K31	1	1		F	2.5	63	Ch SAED 3550
		2	2		F	0.5	50	Chr
	CH1	3	3		F	2.5	78	Chr
					F	0.5	58	Chr
	EM4							
	FM4							
	G41	4	4		MD11	50	145	
		5	5		ME	1.5	110	Ch
					MD11	55	610	*6 K ₂ CO ₃
					ME	2.5	610	Ch
	H41	6	6		MD11	10	85	
					ME	2	80	Ch
	K41							
	C51							
	E51	7	7		F	2	74	Ch
	F61							
	G51	8	8		MD11	45	65	
					ME	2.5	65	Ch ED9
A	H51	NSD						
	K51	NSD						
B	F26	9	9		MD11	50	90	
						0.5	75	Ch
	G26							
	F26							

(-10A (2002))
 21 M D₂H₁₀X₄70 Blackfeter
 ME 18x90 CaPO₄

Report number: 136865

SAMPLE NO: SSALG-01-0.00 BPC X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	G36							
	H36							
	B46							
	F46							
	G46							
	H46							
	C56							
	E56	10	10		F	1.5	96	chry
	F56							
	G56	17	11		F	2.5	310	chry XGB
	H56							
	C64							
	E64							
	F64							
	G64							
	E54							
	F54							
g1	G54	12	12		F	0.5	52	Non-ash Si
					MD11	20	135	
					MF	2	152	chry
C	F31							
	C31							
	E31							
	F31							
	G31							
	H31							
	C41							
	E41	13	13		F	2	100	chry
	F41				F	3	55	Non-ash OR Fe:0
		14	14		MD11	40	125	
					MF	1.5	115	chry
		15	15		F	0.75	90	chry
	G41							
	H41	16	16		MD11	6	68	
					MF	1	68	chry
	C51							
	E51							
	F51							

TEM Asbestos Structure Count (Page 3 of 4)

Report number: 136865

SAMPLE NO: SSAL6-01-0.00 RPC X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	G51							
	H51	17	17		F	2	89	Hard Non-Sub
	K51	17	17		MDII	1.0	78	
		18	18		MF	1.5	78	CH
			18		MDII	85	300	MDXGB
					MF	2.5	112	F drop 2nd XGB CH
	L61							
	E61							
	F61							
21	G61				MDII	5	49	
					MF	0.5	49	RESID
10	E21							
	G21							
	B31	19	19		MDII	23	220	
		20	20		MB	4	220	CH
			20		MDII	30	270	
			20		MF	1	270	CH
	C31	21	21		F	2.5	120	CH XGB XGB
	E31							
	G31							
	H31							
	B41							
	C41							
	F41	22	22		MDII	6	110	
			22		MF	2.5	110	CH
		23	23		F	0.3	55	CH
	G41	24	24		F	2	65	CH
	H41							
	K41	25	25		MDII	50	91	
					MF	2	91	CH
	B51							
	C51							
	E51							
	F51							
	G51							
	H51	26	26		MDII	25	85	
					MF	2.5	85	CH
	B33							

TEM Asbestos Structure Count (Page 4 of 4)


Report number: 136865

SAMPLE NO: SSALG-01-0.00 BPC X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
W	C30							
	E30	27	27		MD11 MB	14 1.5	110 100	chug
E	D31							
	E31	28	28		MD11 MF	90 1.7	115 70	ch
	B41							
	O41							
	E41	29	29		F	1.5	50	ch
		30	30		MD11 MF	140 5.5	160 160	MD11 MF
	F41							
	G41							
	B51							
	C51	31	31		F	0.5	50	ch
		32	32		MD11 MF	50 0.75	92 92	ch
	E51							
V	F51							
	G51							
	B61							
	C61	33	33		F	3	60	non pap - hand
	E61							
	F61							
X	G61							
	ELL4	34	34		MD11 MF	140 2	200 120	ch

Full scale counts: 1241

137865 SSAL6-01-0.00BPC GRID A G51




Quantitative Results 137865 SSAL6-01-0.00BPC GRID A G51

Element Line	Net Counts	Weight %	Weight % Error	Atom %	Atom % Error
Mg K	11003	49.81	---	54.41	+/- 0.55
Si K	13250	46.14	---	43.62	+/- 0.40
Ca K	44	0.21	---	0.14	+/- 0.06
Fe K	762	3.85	---	1.83	+/- 0.09
Total		100.00		100.00	

Full scale counts: 325

13865 SSAL6-01-0.00BPV GRID E GO E41




Quantitative Results 13865 SSAL6-01-0.00BPV GRID E GO E41

Element Line	Net Counts	Weight % Error	Atom % Error
Mg K	538	7.49	11.49 +/- 0.56
Si K	3777	40.46	53.69 +/- 0.91
Ca K	24	0.35	0.32 +/- 0.17
Fe K	3329	51.70	34.50 +/- 0.63
Total		100.00	100.00

Full scale counts: 657

SSAL6-01-000-BPC GRID C #51



Live Time:45.3 sec.



EMS Laboratories Inc.
 117 West Bellevue Drive, Pasadena, CA 91105
 Phone: 626-568-4065 Fax: 626-796-5282
 Email: akolk@emslabs.com

Attn: Derrick Wills
 Tronox-LLC-Henderson
 PO Box 55
 Henderson, NV 89009

Phone: (947) 375-7004

Project: Tronox LLX Henderson, 560 W. Lake Mead Dr.,
 Henderson, NV/2027.001

Customer ID: TRNX26
 Customer PO: 2027.001
 Received: 5/20/2010 9:50AM
 EMS LAB No: 137865
 Date Prepared: 7/7/2010 12:26PM
 Analysis Date: 7/21/2010 0:00

Report Date:

Date Sampled: 5/18/2010 8:30AM

NIOSH 7402/ISO

DRAFT, MODIFIED ELUTRIATOR METHOD FOR THE DETERMINATION OF ASBESTOS IN SOILS AND BULK MATERIAL METHOD

EMS Laboratory Number: 137865	Mass of Respirable Dust on Fiber: 135	µg
Customer Sample Number: SSAP7-02-0.00BPC	Area of collection filter: 385	mm ²
Minimum Level of Analysis (chrysotile): CD	Grid openings area: 0.0094	mm ²
Minimum Level of Analysis (amphibole): ADX	Grid Openings Analyzed: 106	
Magnification used for fiber counting: 9,200 x	Min. Str. Length/Max Str. Diameter: >5/<0.4	microns
Aspect ratio for fiber definition: 3:1		

Analyst(s): Radha Singh

Dust Generator - Total Dried Sample Weight-78.7g	Soil % Moisture	0.8	%
Not Used	Air Flow Rate Through ME Opening of Dust Generator:	1370	
Used in Tumbler	Air Flow Rate Through IST Opening of Dust Generator:	138	
	Estimate Total Air Flow Through Elutriator:	1508	

Analytical Sensitivity: 2.86E+06 Structure /g PM 10 Limit of Detection: 8.57E+06 Structure /g PM 10

Test For Uniformity (Chi-Square results)

Structure Class	Min ID Level Required	Counts		Density St/mm ²	Conc. Str/g PM10	Poisson 95% Confidence Interval	
		Primary Str.	Total Str.			Lower Limit Str/g PM10	Upper Limit Str/g PM10
Asbestos Structures >5um, ≤10um	ADX/CD	0	0	0	0	0	8.57E+06
Asbestos Structures >5um, ≤10um (Chrys)	CD	0	0	0	0	0	8.57E+06
Asbestos Structures >5um, ≤10um (Amph)	ADX	0	0	0	0	0	8.57E+06
Asbestos Structure >10um (Long)	ADX/CD	0	0	0	0	0	8.57E+06
Asbestos Structure >10um (Chrys)	CD	0	0	0	0	0	8.57E+06
Asbestos Structure >10um (Amph)	ADX	0	0	0	0	0	8.57E+06
Total Protocol Asbestos Structures	ADX/CD	0	0	0	0	0	8.57E+06
Protocol Asbestos Structures (Chrys)	CD	0	0	0	0	0	8.57E+06
Protocol Asbestos Structures (Amph)	ADX	0	0	0	0	0	8.57E+06
Total Protocol Non Asbestos Structures	NAM	1	1	1.00	2.86E+06	5.7E+04	1.59E+07


 Approved by Technical Director

Elutriator Data

Date: 7/7/10

Client: Northgate

Lab #: 137865

Sample ID: SSAP7-02-0.00ppc Sample weight (g): 78.7

Time air flow started: 8:00

Tumbler rpm: 30

IST Flowmeter (mL/min): 100

ME Flowmeter (mL/min): 1370

Filter No.	Start Time	Tested flow rate (mL/min)	Final Filter Wt (mg)	Initial Filter Wt (mg)	Dust Weight (mg)	Time Value (min)	Avg. rate of deposition (ug/min)	Optimal time (min)
1	10:00	180	0.02745	0.02520	2.25	30		
2	10:30	1	0.02733	0.02494	2.39	15		
3	10:45		0.02710	0.02490	2.20	15		
4	11:00		0.02755	0.02543	2.52	25		
5	11:25		0.02768	0.02517	2.51	30		
6	11:55		0.03005	0.02520	4.75	35		
7	12:30							
8								
Time							Dep. Rate	Estimate
1	11:08		4.649	4.574	0.075	13		
2	11:40		4.674	4.537	0.137	13		
3	12:10		4.631	4.496	0.135	16		
4								
5								
6								
7								
8								

loss 65%
loss 25%
loss 60%
loss 80%

prep 7/9/10

Raise up 1st flow to 130 @ 1138

1
2
3
4
5
6
7
8

137865

Moisture content

46

6-10-10

SSALG-02-00BPC

dish wt.	19.24 g		
dish + samp.	119.54	- 19.24 =	100.30 g (initial wt.)
11:30 - 12:30	119.40	- 19.24 =	93.16
12:45 - 1:45	111.98	- 19.24 =	92.74
1:45 - 2:40	111.94	- 19.24 =	92.70 (Final wt.)

$$\% \text{ moist. } 100 \times \frac{100 - 92.70}{92.70} = 7.87\%$$

SSALG-01-00BPC

dish wt.	31.47 g		
dish + samp.	131.40	- 31.47 =	99.93 g (initial wt.)
11:30 - 12:30	125.72	- 31.47 =	94.25
12:45 - 1:45	124.96	- 31.47 =	93.49
1:45 - 2:40	124.92	- 31.47 =	93.45 (Final wt.)

$$\% \text{ moist. } 100 \times \frac{99.93 - 93.45}{93.45} = 6.93\%$$

SSAPT-02-0.00BPC

dish wt.	31.44 g		
dish + samp.	131.82	- 31.44 =	100.39 (initial wt.)
11:30 - 12:30	131.08	- 31.44 =	99.64
12:45 - 1:45	131.04	- 31.44 =	99.60 (Final wt.)

$$\% \text{ moist. } 100 \times \frac{100.39 - 99.60}{99.60} = 0.79\%$$

BP

Prep Time: 12⁰⁰ 23⁰

Report number: 137865
 Sample number: SSAP7-02-0.00 BPC
 File name: Northgate
 Sample Description: 135 mg

Filter Type: PC 385 mm²
 Date Sample was Run: 7/7/10

Magnification: 9,200 X

Do 10560

Preparation date: 7/9/10
 Analysis date: 7/21/10

By JAP
 By BK

Grid opening dimension: 0.0094 mm²
 Level of Analysis: (C): CD, CDX

Grid loading Mrd

(A): ADX, ADO
 Condition of Grid Wood

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
A	C31				E	0.5	55	NO SAED Non-Ad
	E31							
	G31							
	H31							
	B41							
	E41							
	F41							
	G41							
	H41							
	K41							
	C51							
	E51							
	F51							
	G51							
	K51							
	C64							
	E64							
	F64							
	G64							
	H64							
	H33							
B	E23							
	F23							
	G23							
	H23							
	B23							
	E33							
	F33							
	G33							
	H33							
	K33							
	C43							

MV filter

TEM Asbestos Structure Count (Page 2 of 3)

Report number: 137805

SAMPLE NO: SSAP7-02-0.00 BPC X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	E43							
	F43				X			
	G43							
	H43							
	K43							
	E53							
	F53							
	G53		X					MS Nriker
	H53							MS at Ca from 70 SiC 77
C	K53							
	B34							
	E34							
	F34							
	G34							
	H34							
	B44							
	C44							
	E44							
	F44							
	G44							
	H44							
	R54							
	C54							
	E54							
	F54							
	G54							
	H54							
	C64							
	E64							
	F64							
	G64							
B	C26							
	E26							
	F26							
	G26							
	H26							
	B26							
	C36							

28

TEM Asbestos Structure Count (Page 3 of 3)

Report number: 137805

SAMPLE NO: SSAP7-02-0.00 BPC X 9,200

Grid	Grid Opening	Number of structures primary	Number of structures Total	Class	Type of Structure	Width Mm	Length Mm	Comments
	E 36							
	F 36							
	G 36							
	H 36							
	K 36							
	B 56							
	C 56							
	E 56							
	F 56							
	G 56							
	H 56							
	C 61							
	F 61							
	F 61							
E	E 21							
	G 21							
	B 31							
	C 31							
	F 31							
	F 31							
	G 31							
	H 31							
	B 41							
	C 41							
	E 41							MD May 11, Co-Mentz Si O
	F 41							Not sub
	G 41							
	H 41							
	C 51							
	E 51							
	F 51							
	G 51							
	H 51							
	C 61							
	E 61							
	F 61							

Filter Lot Blank

Count (Page of) NIOSH 7402/ISO

Prep Time: NA

Report number: 137022 Filter Blank 1

Filter Type: MCE 385 mm²

Sample number: 0005200

Date Sample was Ruri: NA

File name: Northgate
Sample Description: NA mg

Magnification: 9,200 X

Preparation date: 6/8/10 By JAP

Grid opening dimension: 0.0094 mm²

Analysis date: 7/9/10 By BE

Level of Analysis: (C): CD, CDX

Grid loading: Very slight Condition of Grid: Good
(A): ADX, ADQ

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
A	C26							
	E27							
	E28							
	F23							
	F26							
	G27							
	C31							
	F34							
	F36							
	E34							
	F38							
	F38							
	G31							
	G34							
	H31							
	B38							
	C41							
	C44							
	F41							
	E44							
	F44							
	F44							
	G41							
	B44							
	H41							
	H44							
	B44							
	K44							
	C51							
	C54							
	E51							
	E54							

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX
 (A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	F51							
	F54							
	G51							
	G54							
	H51							
	H54							
	K51							
	G61							
B	C26							
	E23							
	E26							
	F23							
	F26							
	G23							
	G26							
	H23							
	C33							
	C36							
	E33							
	E36							
	F33							
	F36							
	H33							
	H36							
	K33							
	K36							
	B46							
	C43							
	C46							
	E43							
	E46							
	F43							

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX
 (A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	F46							
	G43							
	G46							
	H43							
	H46							
	K43							
	K46							
	C53							
	C56							
	E53							
	E56							
	F53							
	F56							
	G53							
	G56							
	H53							
C	B34							
	C31							
	C34							
	E31							
	F34							
	F31							
	F34							
	G31							
	G34							
	H31							
	H34							
	B41							
	T044							
	C41							
	F44							
	F41							

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX

(A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	E44							
	F41							
	F44							
	G41							
	G44							
	H41							
	H44							
	K41							
	B51							
	B54							
	C51							
	C54							
	F51							
	F54							
	G51							
	G54							
	H51							
	H54							
	C61							
	C64							
	E64							
	E61							
13	C23							
	C26							
	E23							
	F26							
	F23							
	G23							
	G26							
	H23							

TEM-10A (2002)

0 grid torn where replaced in grid bag

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX

(A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	B36							
	C33							
	C36							
	E33							
	E36							
	F33							
	F36							
	G33							
	G36							
	H33							
	H36							
	I46							
	C43							
	C46							
	E43							
	E46							
	F43							
	F46							
	G43							
	G46							
	H43							
	H46							
	K43							
	K46							
	M56							
	C53							
	C56							
	E53							
	E56							
	F53							
	F56							
	G53							

Count (Page 1 of 1) NIOSH 7402/ISO

Report number : 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By (A): ADX, ADQ Level of Analysis: (C): CD, CDX

Grid loading *Very Right* Condition of Grid *Best*

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
E	B31							
	B34							
	C21							
	C34							
	C31							
	K34							
	K31							
	E34							
	G31							
	G34							
	H31							
	H34							
	B41							
	D214							
	C41							
	C44							
	E41							
	E44							
	F41							
	F44							
	G41							
	G44							
	H41							
	H44							
	K41							
	K44							
	B54							
	C51							
	C54							
	E51							
	E54							
	F51							

0.09 fibers/μm² C54

Report number : 137822 Filter Blank1
 Sample number: 00105200
 File name: Northgate
 Sample Description: NA mg

Filter Type: MCE 385 mm2 Prep Time: NA
 Date Sample was Run: NA
 Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP
 Analysis date: By
 (A): ADX, ADQ
 Grid loading Condition of Grid

Grid opening dimension:0.0094 mm²
 Level of Analysis: (C): CD, CDX

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	F54							
	G51							
	C54							
	H51							
	L54							
	K51							
	E61							
	E64							

TEM ASBESTOS ANALYSIS

Client Sand blank
 Sample No. 5-12-10

EMS Lab No. _____ of _____
 Page _____ of _____

RECEIVING

TYPE OF SAMPLE
 Air Water
 Soil Bulk
 Other Sand

METHOD OF ANALYSIS
 EPA 600/4-83-013 ISO

LEVEL OF ANALYSIS
 Chromic
 Amphibole

ASPECT RATIO
 3:1 5:1
 EPA/600/R-94/134 100:1 100:2

LENGTHS
 All Sizes (EPA)
 (µm) ≥ 0.5
 ≥ 1.0
 ≥ 2.50
 PCM Range*
 *≥ 0.25 µm width
 ≥ 5.0 µm length)

FILTER TYPE / AREA (µm²)
 MCE 385
 PC 314
 MCN 107
 Other _____

PORE SIZE
 0.45 µm 0.8 µm
 0.1 µm 0.22 µm
 Other _____

GD Area (µm²) 0.094
 No. of GD to Analyze 200
67/912

PREP

DIRECT PREP
INDIRECT PREP

Volume _____ liters
 Working Volume _____ ml
 Weight 5.0 grams
 Ashed Area _____ %

Prepared By JAP
 Date 5/12/10

ANALYSIS

MICROSCOPE
 H600A - Serial No. 542-36-01
 H600B - Serial No. 542-05-06
 H600C - Serial No. 542-24-03

ENERGY DISPERSIVE X-RAY SYSTEM
 KeveX - Model No. 3200-0106-0365
 KeveX - Model No. 3600-0206-0146
 Quantum System

Grid Address: 19 260 X
Screen Magnification: 225
Camera Constant: 225
Accelerating Voltage: 10 100KV
Beam Current: 10 µA
K-Factor: 1.4
Analyst: Zedls Date 5/13/10

TEM - 1A (1-08)

Grid Opening	Structure Number	Structure	Dimensions (µm)		Fiber Classification										EDS Analysis				Comments								
			Width	Length	NA	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	AIR	AQ	ADQ	AZQ		AZZ	Na	Mg	Si	Ca	Fe		
C23		Asp																									
C26																											
E23																											
E28																											
R23																											
R28																											
G23																											
H23																											
C3-1																											
C3-1																											
E3-1																											
E3-1																											
E3-1																											
F3-1																											

OBSERVATIONS:

Condition of the Grid:

Clean Debris: Very Light Light Moderate Heavy Very Heavy
 Gypsum: Very Light Light Moderate Heavy Very Heavy
 Good Scrapy Undissolved Filler Folded

TEM ASBESTOS ANALYSIS

Client Sand blaw
 Sample No. S-12-10

EMS Lab No. _____ of _____
 Page 3

RECEIVING

ANALYSIS

MICROSCOPE

- H600A - Serial No. 542-36-01
- H600B - Serial No. 542-05-06
- H600C - Serial No. 542-24-03
- ENERGY DISPERSIVE X-RAY SYSTEM
- Kerz - Model No. 390-0106-0365
- Kerz - Model No. 390-0206-0146
- Quantum System

Grid Address: A
 Screen Magnification: X
 Camera Constant: _____
 Accelerating Voltage: 100KV
 Beam Current: 1A
 K-Factor: _____
 Analyst: P. Adik Date: S-13-10

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification										EDS Analysis					Comments						
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ		Ns	Mg	Si	Ca	Fe	
241		U-24																								
242		U-24																								
243		U-24																								
244		U-24																								
245		U-24																								
246		U-24																								
247		U-24																								
248		U-24																								
249		U-24																								
250		U-24																								
251		U-24																								
252		U-24																								
253		U-24																								
254		U-24																								
255		U-24																								
256		U-24																								
257		U-24																								
258		U-24																								
259		U-24																								
260		U-24																								

OBSERVATIONS:

- Clean
 Debris:
 Gypsum:
 Very Light
 Very Light
 Light
 Light
 Moderate
 Moderate
 Heavy
 Heavy
 Very Heavy
 Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand blank EMS Lab No. _____ of _____
 Sample No. S-12-10 Page 1

RECEIVING

ANALYSIS

Grid Address: B3
 Screen Magnification: 9200 X
 Camera Constant: 28.2
 Accelerating Voltage: 100KV
 Beam Current: 10 µA
 E-Pactor: 1.4
 Analyte: Radon
 Date: 5/18/10

MICROSCOPE
 H500A - Serial No. 542-36-01
 H600B - Serial No. 542-05-08
 H600C - Serial No. 542-24-03

ENERGY DISPERSIVE X-RAY SYSTEM
 Kevex - Model No. 300-0106-0365
 Kevex - Model No. 300-0206-0146
 Quantum System

TEM - 1B (1-08)

Grid Opening	Structure Number	Structure	Dimensions (µm)		Fiber Classification											EDS Analysis					Comments					
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ	Na		Mg	Si	Ca	Fe	
L23		W20																								
C26																										
E23																										
E26																										
I-26																										
A23																										
A26																										
I-23																										
C31																										
C34																										
E31																										
E37																										
F31																										

OBSERVATIONS:

- Clean
- Debris:
- Gypsum:
- Very Light
- Light
- Moderate
- Heavy
- Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand blank
 Sample No. S-12-10

EMS Lab No. 7 of 7

RECEIVING

ANALYSIS

Grid Address: B3
 Screen Magnification: 9,200 X
 Camera Constant: 28.2
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 K-Filter: Ly
 Analyte: Radn

MICROSCOPE
 H600A - Serial No. 542-36-01
 H600B - Serial No. 542-05-06
 H600C - Serial No. 542-24-03
 ENERGY DISPERSIVE X-RAY SYSTEM
 Error - Model No. 300-0106-0365
 Error - Model No. 300-0206-0146
 Quantum System

Date 5/18/10

TEM - 1B (1-08)

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification													EDS Analysis					Comments					
			Width	Length	NAW	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZK	Na	Mg	Si		Ca	Fe			
CH1		N59																										
CA9																												
E07																												
E49																												
F41																												
F44																												
G41																												
H41																												
H44																												
K41																												
K44																												
L41																												
L44																												
M41																												
M44																												
N41																												
N44																												
O41																												
O44																												
P41																												
P44																												
Q41																												
Q44																												
R41																												
R44																												
S41																												
S44																												
T41																												
T44																												
U41																												
U44																												
V41																												
V44																												
W41																												
W44																												
X41																												
X44																												
Y41																												
Y44																												
Z41																												
Z44																												

OBSERVATIONS:

- Clean
- Debris:
- Gypsum:
- Very Light
- Light
- Moderate
- Moderate
- Heavy
- Heavy
- Very Heavy
- Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand blank EMS Lab No. 5 of 5
 Sample No. S-12-10 Page 5

RECEIVING

ANALYSIS

MICROSCOPE
 H600A - Serial No. 542-36-01
 H600B - Serial No. 542-05-06
 H600C - Serial No. 542-24-03
 ENERGY DISPERSIVE X-RAY SYSTEM
 Kentz - Model No. 3200-0106-0365
 Kentz - Model No. 3500-0206-0146
 Quantum System
 Grid Address: B5
 Screen Magnification: 9,200 X
 Camera Constant: 28.2
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 K-Factor: 1.9
 Analyst: Radly Date: 5/18/10

TEM - 1B (1-08)

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification												EDS Analysis					Comments								
			Width	Length	NAM	TM	CM	CD	CO	CMQ	COQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ	Na	Mg		Si	Ca	Fe					
US-1																														
B5-1		N3D																												
AS-1																														
E6-1																														
E6-1																														
E6-1																														
E6-1																														
E6-1																														
E6-1																														
E6-1																														

OBSERVATIONS:

- Clean
- Debris:
- Gypsum:
- Very Light
- Light
- Moderate
- Heavy
- Very Heavy

TEM ASBESTOS ANALYSIS

Client END DANK
Sample No. 5-12-10

EMS Lab No. _____
Page 1 of _____

MICROSCOPE

- HE00A - Serial No. 542-36-01
- HE00B - Serial No. 542-05-06
- HE00C - Serial No. 542-24-03
- ENERGY DISPERSIVE X-RAY SYSTEM
- Kevex - Model No. 3300-0106-0365
- Kevex - Model No. 3600-0206-0146 Quantum System

ANALYSIS

Gel Address: C
Screen Magnification: 9200 X
Camera Constant: 282
Accelerating Voltage: 100KV
Beam Current: 10 μA
K-Filter: 1.4
Analyst: Redl

Date 5/13/10

RECEIVING

TEM - 1B (1-08)

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification												EDS Analyzers				Comments							
			Width	Length	NAI	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	AUX	AQ	ADQ	AZQ	AZQ	Na		Mg	Si	Ca	Fe			
E23																												
E24																												
E23																												
E24																												
E23																												
E24																												
E23																												
E24																												
E23																												
E24																												
E23																												
E24																												
E23																												
E24																												
E23																												
E24																												
E23																												
E24																												
E23																												
E24																												

OBSERVATIONS:
Clean
Debris:
Gypsum:
Condition of the Grid:

Very Light
Light
Moderate
Heavy
Very Heavy

Very Light
Light
Moderate
Heavy
Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand Bank
 Sample No. 5-12-10

EMS Lab No. _____
 Page _____ of _____

RECEIVING

ANALYSIS

Grid Address: _____
 Screen Magnification: 9200 X
 Camera Constant: 283.5
 Accelerating Voltage: 100 KV
 Beam Current: 10 μA
 K-Factor: 1.4
 Analyst: Reddy Date: 5/13/10

- MICROSCORE
- H600A - Serial No. 542-36-01
 - H600B - Serial No. 542-05-06
 - H600C - Serial No. 542-24-03
 - ENERGY DISPERSIVE X-RAY SYSTEM
 - Kevex - Model No. 3300-0106-0365
 - Kevex - Model No. 3600-0206-0146 Quantum System

TEM - 1B (1-08)

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification														EDS Analysis					Comments							
			Width	Length	NAI	TM	CM	CD	CO	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ	Na	Mg	Si	Ca		Fe						
V3-11		NSD																													
V3-1																															
V3-11																															
V3-3																															
V3-4																															
V3-4																															
V3-3																															
V3-6																															
V3-3																															
V3-6																															
V3-3																															
V3-3																															
V3-6																															
V3-3																															
V3-3																															
V3-6																															

OBSERVATIONS:

- Clean Debris: Very Light Light Moderate Heavy Very Heavy
- Gravel: Sand: Silt: Clay:

TEM ASBESTOS ANALYSIS

Client Send Bank
 Sample No. 5-12-10

EMS Lab No. _____
 Page 2 of _____

RECEIVING

ANALYSIS

Grid Address: C
 Screen Magnification: 9200 X
 Camera Constant: 2872
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 E-Filter: 119

- MICROSCOPE
- H60A - Serial No. 542-36-01
 - H60B - Serial No. 542-05-06
 - H60C - Serial No. 542-24-03
 - ENERGY DISPENSIVE X-RAY SYSTEM
 - Evera - Model No. 3200-0106-0365
 - Evera - Model No. 3600-0206-0146
 - Quantum System

Analyst: Redu Date: 5/13/10

TEM - 1B (1-08)

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification										EDS Analysis				Comments							
			Width	Length	NAM	TM	CM	CD	CQ	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ		AZZ	Ni	Mg	Si	Ca	Fe	
K38		N410																								
C44																										
E41																										
E44																										
G41																										
H41																										
I44																										
K41																										
K44																										
E43																										

OBSERVATIONS:

- Clean
- Debris: Granular
- Very Light
- Light
- Moderate
- Heavy
- Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand Bank
 Sample No. S-12-10

EMS Lab No. _____
 Page 1 of _____

RECEIVING

ANALYSIS

Grid Address: _____
 Screen Magnification: 9200 X
 Camera Constant: 2872
 Accelerating Voltage: 100KV
 Beam Current: 10 mA
 K-Factor: 1.4

- MICROSCOPE
- H600A - Serial No. 542-36-01
 - H600B - Serial No. 542-05-06
 - H600C - Serial No. 542-24-03
- ENERGY DISPERSIVE X-RAY SYSTEM
- Kenca - Model No. 3200-0106-0365
 - Kenca - Model No. 3200-0206-0146
Quantum System

Analyst Redu Date 5/13/10

TEM - 1B (1-08)

Grid Opening	Structure Number	Structure	Dimensions (mm)		NAM	TM	CM	CD	CQ	CMQ	CDQ	Fiber Classification							EDS Analysis					Comments													
			Width	Length								UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ	Na	Mg	Si	Ca		Fe												
Ku76		239																																			
Ku3																																					
Fu76																																					
Uu3																																					
Wu76																																					
Wu3																																					
Wu76																																					
Wu3																																					
Wu76																																					
Wu3																																					
Wu76																																					
Wu3																																					
Wu76																																					
Wu3																																					
Wu76																																					
Wu3																																					

OBSERVATIONS:

- Clean
- Debris:
- Very Light
- Light
- Moderate
- Heavy
- Very Heavy

TEM ASBESTOS ANALYSIS

Client Sand Bank
 Sample No. S-12-10

EMS Lab No. _____
 Page 3 of _____

RECEIVING

ANALYSIS

Grid Address C
 Screen Magnification 9200 X
 Camera Constant 2872
 Accelerating Voltage: 100KV
 Beam Current: 10 μ A
 K-Factor 1.9

Microscope
 H600A - Serial No. 542-36-01
 H600B - Serial No. 542-05-06
 H600C - Serial No. 542-24-03
 ENERGY DISPERSIVE X-RAY SYSTEM
 Enerx - Model No. 3200-0106-0365
 Enerx - Model No. 3600-0206-0146
 Quantum System

Analyst Redu Date 5/13/10

TEM - 1B.(1-08)

Grid Opening	Structure Number	Structure	Dimensions (mm)		Fiber Classification												EDS Analysis					Comments						
			Width	Length	NAM	TM	CM	CD	CO	CMQ	CDQ	UF	AD	AX	ADK	AQ	ADQ	AZQ	AZZ	Ni	Mg		Si	Ca	Fe			
US-4		0020																										
US-1																												
US-1																												
US-3																												
US-6																												
US-3																												
US-6																												
US-3																												
US-6																												
US-3																												
US-6																												

OBSERVATIONS:

- Clean
- Debris: Curved
- Very Light Less than 1 inch
- Light 1 inch
- Moderate 1 inch
- Heavy 1 inch
- Very Heavy Less than 1 inch

Count (Page / of) NIOSH 7402/ISO

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: LOT 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: 7/9/10 By Level of Analysis: (C): CD, CDX

Grid loading *Very Right* (A): ADX, ADQ Condition of Grid *Good*

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
A	C23							
	C26							
	E23							
	E26							
	F23							
	F26							
	G23							
	G26							
	H23							
	H26							
	I23							
	E33							
	C36							
	E33							
	E36							
	F33							
	F36							
	G33							
	G36							
	H33							
	H36							
	K33							
	K36							
	E43							
	E46							
	F43							
	F46							
	G43							
	G46							
	H43							
	H46							
	I43							

TEM-10A (2002)

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX
 (A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	V42							
	B56							
	C53							
	C56							
	E53							
	E56							
	F53							
	F56							
B	C23							
	C26							
	E23							
	E26							
	F23							
	F26							
	C31							Background
	E34							
	E31							
	F34							
	F31							
	E34							
	B36							
	C33							
	C36							
	E33							
	E36							
	F33							
	F36							
	B44							
	C41							
	C44							
	E41							
	E44							

TEM-10A (2002)

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX
 (A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	F41							
	F44							
	G41							
	G44							
	H41							
	H44							
	B46							
	C43							
	C46							
	E43							
	E46							
	F43							
	F46							
	G43							
	G46							
	F51							
C	E21							
	E24							
	E21							
	B26							
	C23							
	C26							
	E23							
	E26							
	F23							
	F26							
	G23							
	G26							
	H23							
	H26							
	B33							
	B36							
	C33							

TEM-10A (2002)

Count (Page 4 of) NIOSH 7402/ISO

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By (A): ADX, ADQ Level of Analysis: (C): CD, CDX

Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	C36							
	E33							
	E36							
	F33							
	F36							
	G33							
	G36							
	H33							
	H36							
	K33							
	B43							013
	B46							
	C43							
	C46							
	E43							
	E46							
	F43							
	F46							
	G43							
	G46							
	H43							
	H46							
	K43							
	C52							
	C56							
D	E21							
	E24							
	F21							
	B34							
	C31							
	C34							
	E31							

TEM-10A (2002)

Count (Page of) NIOSH 7402/ISO

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX

(A): ADX, ADQ
 Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	F34							
	F31							
	F34							
	G31							
	G34							
	H31							
	H34							
	B41							
	E41							
	E44							
	F41							
	F44							
	G41							
	G44							
	H41							
	H44							
	K41							
	K44							
	B54							
	C51							
	C54							
	E51							
	E54							
	F51							
	F54							
	B56							
	C53							
	C56							
	E53							
	E56							
	F53							
	F56							

TEM-10A (2002)

Report number: 137822 Filter Blank1 Filter Type: MCE 385 mm2 Prep Time: NA
 Sample number: 00105200 Date Sample was Run: NA
 File name: Northgate
 Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
 Analysis date: By Level of Analysis: (C): CD, CDX

(A): ADX, ADQ

Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
6	C23							
	C24							
	E23							
	E24							
	F23							
	F24							
	G23							
	G24							
	H23							
	H24							
	B33							
	C33							
	C34							
	E33							
	E34							
	F33							
	F34							
	G33							
	B43							
	C43							
	E43							
	E44							
	F43							
	F44							
	G43							
	C44							
	H43							
	H44							
	K43							
	E53							
	F53							
	F54							

TEM-10A (2002)

Count (Page of) NIOSH 7402/ISO

Report number : 137822 Filter Blank2 Filter Type: MCE 385 mm2 Prep Time: NA
Sample number: 00105200 Date Sample was Run: NA
File name: Northgate
Sample Description: NA mg Magnification: 9,200 X

Preparation date: 6/8/2010 By JAP Grid opening dimension: 0.0094 mm²
Analysis date: By (A): ADX, ADQ Level of Analysis: (C): CD, CDX

Grid loading Condition of Grid

Grid	Grid Opening	Number of structures Primary	Number of structures Total	Class	Type of Structure	Width mm	Length mm	Comments
	G53							
	G56							
	H53							
	H56							
	K57							
	C64							
	E61							
	E64							
	F61							
	F64							

TEM-10A (2002)

Spot Size Measurements

Scope: #60B
Date: May 2010
Name: R

Conditions of Measurements

High Voltage: 100K
Beam Current: 10 μ A
Magnification: 19,200
Condenser Aperture Size: #2


Measurements from a photo 8.5

Shortest diameter: 8.5 mm
Longest diameter: 9 mm
Average: 8.75 mm

Spot Size Calculation

Spot size in μ m = $\frac{(\text{average spot size in mm}) \times 1000 \mu\text{m} \times 0.4125}{\text{Magnification}}$ 188

Note: 1.65/4 = 0.4125 (see the Hitachi Fax)



TEM CAMERA CONSTANT DETERMINATION

TEM H600B

Measured and Calculated by ls Date May 2010

$$\text{Camera Constant (mm A)} = D (\text{mm}) \times 1/2 \times d (\text{A})$$

where D (mm) is the diameter of a gold ring and

d (A) is the d-spacing in Angstroms for a particular reflection

$$\text{CC (1*)} = (24.1 \text{ mm}) \times 1/2 \times 2.355 = 28.34$$

$$\text{CC (2*)} = (27.8 \text{ mm}) \times 1/2 \times 2.039 = 28.34$$

$$\text{CC (3*)} = (39.3 \text{ mm}) \times 1/2 \times 1.442 = 28.34$$

$$\text{CC (4*)} = (45.9 \text{ mm}) \times 1/2 \times 1.230 = 28.33$$


$$\text{Average Camera Constant} = \sqrt{28.3}$$

* 1 is the first largest diameter ring. 2 the second, etc.

$$\text{Average Camera Constant} = (\text{CC}<1> + \dots + \text{CC}<n>) \times 1/n$$

For gold:

d(A)	nk1
2.355	(111)
2.039	(200)
1.442	(220)
1.230	(311)
1.1774	(222)



08/07/01
csl

DATE: May 2010
 WEEKLY CALIBRATION 3m
 MONTHLY CALIBRATION 3m
 AFTER SERVICE CALIBRATION _____

A-600/B-600/C-600

BY: R

Measurement	Number of Spacing Flourescent Screen Magnification	Distance (mm)	Number of Spacing Film Magnification
1	25,000x 53/16 = 19,260	12,000x 51/12 = 9,180	9,180
2	53/16 = 19,260	51/12 = 9,270	9,270
3	53/16 = 19,080	51.5/12 = 9,270	9,270
4	53/16 = 19,180	51/12 = 9,180	9,180
5	53.5/16 = 19,260	51/12 = 9,180	9,180
6		51/12 = 9,180	9,180
7	ave 19,200		
8		ave 9,200	
9			
10			
AVERAGE:			


OPERATING VOLTAGE 100 KV

54,864 lines/inch or 2,160 lines/mm or 0.463µm/line

28,800 lines/inch or 1,134 lines/mm or 0.882µm/line

15,240 lines/inch or 600 lines/mm or 1.67µm/line

16.94 µm for one bar and one opening for Ni screen on



SCOPE B

K = [Cn/C(Si)] / [In/I(Si)]
C(Si) = 18.74

n	Cn	RUN 1		RUN 2		RUN 3		RUN 4		RUN 5		RUN 6	
		I(Si)=	Kn	I(Si)=	Kn	I(Si)=	Kn	I(Si)=	Kn	I(Si)=	Kn	I(Si)=	Kn
Na	1.81	22860	1.3034	12101	1.0674	15953	1.5627	16554	1.4112	16203	1.5587	7464	1.8251
Mg	7.57	6992	1.3207	3738	1.3077	4447	1.4491	4902	1.3641	4714	1.3885	1983	1.5205
Al	6.54	7768	1.027	4152	1.0171	5455	1.0206	5761	1.0028	5708	0.9906	2576	1.0112
Si	18.74	22860	1	12101	1	15953	1	16554	1	16203	1	7464	1
K	0.97	1453	0.8144	827	0.7574	1311	0.6299	1333	0.6428	1195	0.7018	584	0.6615
Ca	8.26	6570	1.5336	3406	1.566	5845	1.203	5222	1.3973	4998	1.4289	2852	1.1535
Ti	3.02	2235	1.6483	1170	1.6668	1821	1.4118	1867	1.4289	1753	1.4895	928	1.2962
Mn	0.14	10	17.078	22	4.1092	12	9.9316	29	4.2645	2	60.523	22	2.5346
Fe	9.51	5898	1.9669	2935	2.0923	4934	1.6408	4856	1.73	4473	1.8383	2351	1.6111
O	43.83			7849	3.6059	7051	5.2917	10526	3.6783	9433	4.0174	3333	5.2377

** NVLAP REQUIREMENTS **

- 1.0 < K(Na) wrt Si < 4.0
- 1.0 < K(Mg) & K(Fe) wrt Si < 2.0
- 1.0 < K(Al) & K(Ca) wrt Si < 1.75


K(Mg)/K(Fe) < 1.5

stdev < 10% for Mg, Al, Si, Fe
stdev < 20% for Na
wrt mean value of k-factor wrt Si

SCOPE B

RUN 7	RUN 8	RUN 9	RUN 10	RUN 11	RUN 12	RUN 13
I(SI)= In	I(SI)= In	I(SI)= In	I(SI)= In	I(SI)= In	I(SI)= In	I(SI)= In
849	1.4365	950	1.6094	1.5879	1.5893	4628
3523	1.4478	4331	1.4765	1.4442	1.542	1.5412
4458	0.9885	5717	0.9863	1.3715	7479	1.3705
12627	1	15830	1	1.0162	9260	0.9563
1099	0.5947	1505	0.5444	1	25374	1
4553	1.2224	6257	1.1151	0.6414	2318	0.5666
1480	1.3749	1994	1.2794	1.4064	9832	1.1375
4	23.583	7	16.894	1.3895	3196	1.2794
3889	1.6477	5899	1.3618	1.7048	8884	1.4494
6102	4.8398	5950	6.2225	3.6262	13315	4.4571

Full scale counts: 303
 EDS RESOLUTION FOR 1600B-5.19.10-RS(1)
 Cursor: 5.388 KeV
 218 Counts



Auto Manual FWHM Fc55 Bench Test

Element: Line:

Atomic Symbol: Line:

Ratio Peaks

Additional Measurements: Measure FWHM and FWTM


Measure Zero Peak

Acquisition Check: G Liveness (f) Max Time:

Peak Count No. Traks:

Time Constant: (Slow)

Peak #	Min. Channel	Max. Channel	FWHM (eV)	Avg. FWHM (eV)
1	5.895	5991	148.79	148.79
2	5.895	5930	155.00	151.89
3	5.894	3178	155.63	153.21
4	5.892	3379	149.17	152.20
5	5.891	3438	155.40	152.84
Avg:		3583	152.84	---
Sigma:		368	3.54	---
RMS:		10.0%	2.3%	---



Auto | Manual FWHM | Fe55 Bench Test |

Elements
 Atomic Symbol Mn Line K
 Atomic Symbol K Line K
 Ratio Peaks

Additional Measurements
 Measure Zero Peak Measure FWHM and FWTM

Acquisition Criteria
 Lifetime (s) Max Time: 50
 Peak Count No. Trials: 5

Time Constant: 50 (Slow)

Trial #	Min Centroid	Net Counts	FWHM (eV)	Avg. FWHM
1	5.896	1277	126.16	126.16
2	5.900	5295	151.73	138.95
3	5.897	6460	146.02	141.30
4	5.898	5860	146.26	142.54
5	5.899	5291	133.62	140.76
Avg:				140.76
Sigma:				10.52
RMS:				7.5%

137865



Laboratory Submittal Form

Date: _____ Time: _____ Relinquished by: _____
 Client: Northgate Date of Shipment: _____
 Address: 1100 Quail Street, Suite 102 Shipped from: _____ Carrier: _____
 Newport Beach, CA 92660 Client P.O. No: 2027.01
 Telephone: 949-260-9293 Client Project ID: COC# 02027.01.2129
 Contact: _____
 Results via: Fax No: _____ Email address: _____ Verbal
 (Complete written reports will follow all analyses, in addition to any prior verbal, fax, or email results)

Turnaround Time: _____ Sample Preservatives: _____
 Number of Samples: 6 Sampler's Name: _____
 Date & Time of Sample Collection: _____ Holding Times: _____ Signature: _____
 Type: Water Waste Water Soil Filter Impinger Sorbent Tube Other

EMS Only	Client Sample No.	Description/Location	Analysis	Volume/Weight
137865-6-2-0	SSAL6-02-0.00BPC		Elutriator	
-6-2-33	SSAL6-02-0.33BPC			
-6-1-0	SSAL6-01-0.00BPC			
-6-1-32	SSAL6-01-0.33BPC			
-7-2-33	SSAP7-02-0.33BPC			
-7-2-0	SSAP7-02-0.00BPC			
7	SEE ATTACHMENT			
8	[Crossed out area]			
9				
10				
11				
12				
13				
14				
15				
16				
17				

137865

For EMS Only
 Laboratory Number: _____ Received by: *Meg Ory* Time: 9:50
 Date of Package Delivery: 5/20/2010 Shipping Bill Retained? YES
 Condition of Package on Receipt: OK Condition of Custody Seal: YES
 Number of Samples: 6 Chain of Custody Signature: _____
 Disposition of Samples: EMS LABS Misc. Info: SF 7/06

137865

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed and accurate.



1100 Quail Street, Suite 102
Newport Beach, CA 92660 (949) 260-9293

Required Ship to Lab:
Lab Name: EMS Laboratories, Inc.

Address: 117 W Bellevue Dr
Pasadena, CA 91105

Lab Pk: Tony Kolk
Phone/Fax: 626-568-4065

Lab PM email: akolk@emslabs.com

Applicable Lab Quote #:

Required Project Information:

Site ID #: TRONOX LLC, HENDERSON

Project #: 2027.01

Site Address: 560 W Lake Mead Drive

City: Henderson State: Zip NV, 89015

Site PM Name: Derrick Willis

Phone/Fax: (949)375-7004

Site PM Email: derrick.willis@ngem.com

Required Invoice Information:

Send Invoice to:

Address: PO Box 55

City/State: Henderson, NV 89009

Phone #: (949) 260-9293

PO #:

Send EDD to: Frank.Hagar@ngem.com

CC Hardcopy report to: PDF Electronic Version Only - FTP Upload

CC Hardcopy report to:

COC # 02027.01.2129

Total # of Samples: 6

Regular	Rush	Event Complete?
N		
UNPRES		
PHB-Asbestos		
X		
X		
X		
X		
X		
X		

ITEM #	SAMPLE ID Samples IDs MUST BE UNIQUE	SAMPLE LOCATION	MATRIX CODE	G=GRAB C=COMP	SAMPLE TYPE	SAMPLE DATE	SAMPLE TIME	#OF CONTAINERS	Comments/Lab Sample I.D.
	SSAL8-02-0.00BPC	SSAL8-02	SO	C	N	05/18/2010	11:55	3	
	SSAL8-02-0.33BPC	SSAL8-02	SO	C	N	05/18/2010	11:55	3	
	SSAL8-01-0.00BPC	SSAL8-01	SO	C	N	05/18/2010	08:10	3	
	SSAL8-01-0.33BPC	SSAL8-01	SO	C	N	05/18/2010	08:10	3	
	SSAP7-02-0.33BPC	SSAP7-02	SO	C	N	05/18/2010	08:30	3	
	SSAP7-02-0.00BPC	SSAP7-02	SO	C	N	05/18/2010	08:30	3	

Additional Comments/Special Instructions:

Francisco Barron 05/18/10 14:18
 5/18/10 14:18
 Francisco Barron
 EMS Labs
 SPROGRO

Sample Receipt Conditions

Temp in OC	Samples on Ice?	Sample Intact?	Trip Blank?
Y/N	Y/N	Y/N	Y/N
Y/N	Y/N	Y/N	Y/N
Y/N	Y/N	Y/N	Y/N

Company: Francisco Barron
 Tracking #: 1418
 Signature: Francisco Barron
 Date Signed: 5/18/10

COC # 02027.01:2129 Revised 2010-5-25

Total # of Samples: 6
 Event Complete?

ITEM #	Required Project Information:				Required Invoice Information:				Comments/Lab Sample ID.	Regul	Rush	X	Mark One
	Lab Name	Site ID #	Project #	Site Address	Address	PO Box	City/State	Phone #					
	117 W Bellevue Dr	2027.01	TRONOX LLC, HENDERSON	860 W Lake Mead Drive	PO Box 86	Henderson, NV 89009	(949) 260-9293						
	Lab #:	Site PM Name	State, Zip	City	State, Zip								
	Lab PM email	Phone/Fax											
	Applicable Lab Quote #	Site PM Email											

Required Project Information:				Required Invoice Information:				Required Receipt Conditions:			
Sample ID	Sample Location	Matrix Code	G-RAB C-COMP	Sample Type	Sample Date	Sample Time	# of Containers	Temp in OC	Sample on Ice?	Sample Intact?	Trip Blank?
SSAL6-02-0.00BPC	SSAL6-02	SO	C	N	05/19/2010	11:55	3				
SSAL6-02-0.33BPC	SSAL6-02	SO	C	N	05/19/2010	11:55	3				
SSAL6-01-0.00BPC	SSAL6-01	SO	C	N	05/19/2010	09:10	3				
SSAL6-01-0.33BPC	SSAL6-01	SO	C	N	05/19/2010	09:10	3				
SSAF7-02-0.33BPC	SSAF7-02	SO	C	N	05/19/2010	08:30	3				
SSAF7-02-0.00BPC	SSAF7-02	SO	C	N	05/19/2010	08:30	3				

Additional Comments/Special Instructions:
 Modification by Joni Fisher NGEIM; modifications shown in bold font

Company: Francisco Barron
 Tracking #: [Signature]
 Date: [Blank]
 Time: [Blank]

SAMPLE LOG-IN SHEET

Lab Name EMS Labs		Page <u>1</u> of <u>1</u>			
Received By (Print name) Meaghan Truong		Log in Date 5-20-10			
Received By (Signature) <i>Meaghan Truong</i>					
		Sample Delivery Group No. 5-20-10			
Remarks 1. Custody Seal(s) <input checked="" type="radio"/> Present / <input type="radio"/> Absent Intact/Broken 2. Custody Seal Nos 580206, 580207 3. Chain of Custody Records <input checked="" type="radio"/> Present / <input type="radio"/> Absent 4. Traffic Reports or Packing List <input checked="" type="radio"/> Present / <input type="radio"/> Absent 5. Air Bill Air Bill Sticker <input checked="" type="radio"/> Present / <input type="radio"/> Absent 6. Air Bill No. 7935 5779 7441 7. Sample Tags <input checked="" type="radio"/> Present / <input type="radio"/> Absent Sample Tag Numbers <input checked="" type="radio"/> Listed / <input type="radio"/> Not Listed 8. Sample Condition <input checked="" type="radio"/> Intact / <input type="radio"/> Broken / <input type="radio"/> Leaking Chain of Custody 9. Does information on custody records, traffic reports and sample tags agree? <input checked="" type="radio"/> yes / <input type="radio"/> no 10. Date Received by Lab 5-20-10 11. Time Received 9:50	EPA SAMPLE #	Corresponding Sample Tag#	Assigned Tag#	Remarks Condition of Sample, Shipment etc.	
		137865	SSAL6-02-000 BPC	137865-6-0	Good
		137865	SSAL6-02-0.33 BPC	137865-6-33	Good
		137865	SSAL6-01-0.00 BPC	137865-6-1-0	Good
		137865	SSAL6-01-0.33 BPC	137865-6-1-33	Good
		137865	SSAPT-02-0.33 BPC	137865-7-2-33	Good
		137865	SSAPT-02-0.00 BPC	137865-7-2-0	Good
Sample Transfer					
Fraction	Fraction				
Area	Area				
By	By				
On	On				
Contract Client and Attach Records of Resolution					
Received By		Logbook No.			
Date		Logbook Page No.			