
To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: Ryan Sullivan, Vice President Service and O&M

Date: October 20, 2017

Subject: NERT – GWETS Operation Monthly Report – September 2017

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during September 2017.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in September 2017. Flow from PC-119, PC-120, PC-121, and PC-133 was routed to the IX system, bypassing all flow meters associated with the FBR plant. The flow rate to the IX system averaged approximately 321 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 1,070 gpm during September 2017. At the end of the month, the GW-11 Pond volume was at 36.4 million gallons (MG), which would allow 18.1 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond increased approximately 1.6 MG from the end of August 2017. Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 1.4 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 114 mg/L for the month, with a maximum concentration of 140 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of August 2017 averaged 124 mg/l, with a maximum concentration of 250 mg/l. Fluctuations in the influent perchlorate concentrations are due to the changes in the AP-5 treatment feed rate and not a result of groundwater changes.

Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. These tables also include data associated with the AP-5 decant liquids. Figure 2 graphically presents historical perchlorate and chromium mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate

Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11

ETI continued to withdraw water from the GW-11 pond while combining this flow with Lift Station flow in the TK-101 tanks for equalization purposes. The average flow rate for September from the GW-11 pond was approximately 48 gpm.

The Trust plans to re-evaluate the use of GW-11 as an equalization pond following completion of the Algae Treatment Pilot Test.

2. Biological Plant

Treatment of AP-5 water through the FBR Biological plant resumed on August 31st at 8:30am at a flow rate of 0.5 gpm. Flow rate increased incrementally through September with a flow rate on Sept. 30th of 1.5 gpm. ETI maintains plans on gradually increasing the AP-5 feed rate as allowed by permit.

There was one planned diversion into GW-11 for the month of September and two unplanned diversions. Below is a description of the events that occurred:

Unplanned Diversions:

- Effluent Diversion to GW-11 on September 1st at 2:41 am to 2:52am am due to high water level in the final effluent tank (T-621). This diversion was initiated to avoid an automated plant shutdown resulting from a high water level alarm. Total amount diverted during this time was 16,250 gallons.
- Influent Diversion to GW-11 on September 16th at 1:45pm to 2:43pm due to a loss of flow from Lift Station 2 due to a VFD fault. The fault was a result of a bad electrical contactor in the control box. The contactor was replaced on the 19th of September.

Planned Diversions

- Effluent Diversion to GW-11 on September 28th at 8:46am to 10:38am due to a maintenance replacement of the "pig launcher" valve. Total amount diverted at this time was 117,892 gallons.

3. Spills

There were no spills in the month of September.

4. Maintenance

- Major maintenance performed by ETI in the month included:
 - I. Ladders were installed to better access the sludge boxes on the DAF's.
 - II. The 10hp motor was replaced on the west turbine pump at LS3.
 - III. The sand filter was taken offline to install a new seal around the feed pipe through the wall of the sand filter.

- IV. The 30 hp motor was replaced on the 601 pump skid.
 - V. A new swing check valve was installed on the discharge of the FBR recycle pump for FBR 4.
 - VI. A new seal water solenoid valve was installed on the recycle pump on FBR 4.
 - VII. A new y-strainer was installed on the sand filter reject tank.
 - VIII. The static mixer was pulled between the Aeration tank and the DAF to inspect for possible obstructions.
 - IX. ART-9 was pulled and inspected for any damage and to check the depth of the pump. New wire connectors were installed.
 - X. New automatic air drains were installed around the plant.
 - XI. New caustic pumps and stands were fabricated and installed.
 - XII. The new pig launcher valve was installed.
 - XIII. Inspected the wiring in the panel at LS2 and replace the contactor.
- Preventative Maintenance completed or being performed by ETI in the month included:
 - I. All ORP and pH probes were calibrated and standardized.
 - II. The GW-11 transducer was pulled, inspected and cleaned. No faults were found.
 - III. The sump pumps were inspected and the containments were cleaned out.
 - IV. The seal water flowmeters were cleaned out for all the recycle pumps.
 - V. Gaskets were replaced on the LS2 piping.
 - VI. The motors were greased around the plant.
 - VII. Completed the assembly of the spare media return pumps and bed height control pumps.

GWETS Upgrades and Facility Projects

The following is a summary of the initiatives in-progress during the reporting period at the direction of the Trust:

1. **Ammonia Pretreatment** - The Trust is currently evaluating options to reduce ammonia concentrations in the AP decant.

Equipment Availability Tracking

ETI operators continue to update the equipment tracking form on a weekly basis or whenever there is a change in the status of key equipment. During regular site visits, Tetra Tech field personnel verify the entries on the form, including both the operating status and confirmation of the inventory of required shelf spares. The equipment tracking form is included as Attachment B.

GWETS Staffing

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP)

Tables

Operational Metrics

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) ^{5 6}	Chromium (TR) (mg/L) ^{5 6}	Chromium(VI) (mg/L) ^{5 6}
SWF Total Extraction ²	805 ¹	8.5	0.00052	0.00062
AWF Total Extraction ²	457 ¹	81	0.18	0.17
IWF Total Extraction ²	63 ¹	612	8.0	7.7
AP Area Total Extraction ³	12 ¹	825	NA	0.032
GWTP Effluent ⁴	76	635	1.1	ND
GW-11 Influent ²	0.05	78	0.091	0.041
FBR Influent ^{4 7}	1,070	114	0.079	0.036
T-205 Effluent (AP-5 Wash Water) ^{7 8}	0.9	34,370	NA	NA

Notes:

TR = Total Recoverable; NA = Not Analyzed; ND = Not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Sum of daily average flow for individual wells.

2: Perchlorate and chromium TR sampled monthly, values reported from TestAmerica.

3: Perchlorate, chromium TR and chromium (VI) sampled twice weekly, values reported from TestAmerica.

4: Perchlorate, chromium TR and chromium (VI) sampled weekly, values reported from TestAmerica.

5: All concentrations reported are monthly flow weighted averages.

6: ND analytical values are treated as zero values in the flow weighted average calculations.

7: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.

8: Flow weighted average concentration based on internal process control samples analyzed by ETI.

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) ¹	Chromium (TR) (lbs/month) ¹	Chromium (VI) (lbs/month) ¹
SWF Total Extraction	2,477	0.15	0.18
AWF Total Extraction	13,418	29	28
IWF Total Extraction	13,940	182	177
AP Area Total Extraction	3,519	NA	0.14
GWTP Effluent	18,875	34	0.00
GW-11 Influent	1.5	0.00	0.00
FBR Influent ²	44,210	31	14
T-205 Effluent (AP-5 Wash Water) ^{2 3}	11,312	NA	NA

Notes:

TR = Total Recoverable; NA = Not Analyzed.


1: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).

2: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.

3: Flow weighted average concentration based on internal process control samples analyzed by ETI.


Figures

Operational Metrics



Note: Measurements switched from manual to transducer on 06/20/17. The pond volume fluctuations between 05/30 and 06/20 reflect the decreasing manual measurement accuracy at lower pond levels.

Figure 2 - Historical Perchlorate Mass Flux



Attachment A

NPDES Tracking Sheet (Prepared by ENVIRON)

Treated Effluent at Outfall 001																					
Continuous		Daily Samples, composited weekly				Weekly Grab Samples										Weekly, collected separately			Quarterly		
Flow Rate		Perchlorate				pH	Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)	Total Suspended Solids (TSS)		Total Ammonia as N		Total Phosphorus as P		BOD ₅ (inhibited)			Total Dissolved Solids (TDS)
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (µg/L)	30-Day Avg. (lbs/day)		Daily Min. (S.U.)	Daily Max. (S.U.)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (mg/L)	Daily Max. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	Daily Max. (mg/L)	
2.52	2.88	18	0.38		6.5	9.0	10	100	5,000	10,000	20	135	2,839	20*	10*	25	40	525		8,000	
January 2017	1.38	1.42	1.3	0.014	6.75	7.13	0.13	30	510	9,600	0.60	62	370	4.8	1.1	2.4	4.3	28			
February 2017	1.50	1.80	9	0.09	6.72	7.16	0.13	36	530	4,200	0.59	25	280	4.0	1.1	5.7	8.4	68		5,400	
March 2017	1.76	1.86	0.5	0.0073	6.65	6.80	0.13	9.5	540	4,700	1.6	27	340	8	1.2	2.8	5.4	41			
April 2017	1.82	1.93	0.5	0.0076	6.70	6.88	0.13	20	570	4,000	1.3	24	330	3.0	3.6	2.8	4.1	42			
May 2017	1.84	1.91	0.5	0.0077	6.68	7.00	0.13	10	580	3,300	2.0	28	310	3.2	2.4	1.7	2.8	26		4,900	
June 2017	1.62	1.94	0.5	0.0066	6.81	7.10	0.13	21	620	2,200	1.9	31	240	2.2	0.68	1.20	2.30	16			
July 2017	1.75	2.14	10	0.14	6.58	7.16	0.13	7.2	620	2,100	8.1	21	170	16	0.8	1.5	2.0	23			
August 2017	1.72	1.97	0.5	0.0073	6.64	7.15	0.13	14	620	5,200	1.2	62	500	9	4	1.4	2.1	22		4,400	
September 2017 (month to date)	1.92	2.01	0.5	0.0080	6.50	6.86	0.13	6.6	600	3,500	2.1	42	310	4.4	1.4	2.3	3.6	36			
October 2017 (month to date)	1.91	1.94	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		NA	

Daily Grab Sample Dates	Composite Sample Date	µg/L	lbs/day	Sample Date	S.U.	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	Sample Date	mg/L			
1/1 - 1/7	1/7/2017	ND (<2.5)	1.3	0.014	1/3/2017	6.76	ND (<0.25)	8.0	280	3,100	ND (<0.50)	26	300	--	0.35	4.0	--	0.046	0.53	1/4/2017	2.2	25		
1/8 - 1/14	1/14/2017	ND (<2.5)	1.3	0.015	1/11/2017	7.03	ND (<0.25)	30	410	9,600	0.60	62	728	--	0.60	7.0	--	0.13	1.5	1/11/2017	ND (<0.50)	0.25	2.9	
1/15 - 1/21	1/21/2017	ND (<2.5)	1.3	0.015	1/16/2017	7.13	ND (<0.25)	17	510	3,400	ND (<0.50)	27	313	--	0.23	2.7	--	0.078	0.91	1/18/2017	4.3	50		
1/22 - 1/28	1/28/2017	ND (<2.5)	1.3	0.014	1/24/2017	6.89	ND (<0.25)	29	480	3,100	ND (<0.50)	22	247	--	0.37	4.2	--	0.079	0.89	1/25/2017	2.9	33		
1/29 - 2/4	2/4/2017	ND (<2.5)	1.3	0.014	1/30/2017	6.75	ND (<0.25)	16	390	3,100	0.52	23	263	--	0.52	5.9	--	0.13	1.5	2/1/2017	3.9	45		
2/5 - 2/11	2/11/2017	34*	34	0.32	2/6/2017	7.00	ND (<0.25)	21	460	4,200	ND (<0.50)	25	234	ND (<0.10)	0.050	0.47	--	0.13	1.2	2/10/2017	8.4	79		
2/12 - 2/18	2/18/2017	ND (<1.0)	0.5	0.0068	2/13/2017	7.16	ND (<0.25)	36	320	340	ND (<0.50)	19	24	260	329	--	0.12	1.6	--	0.11	1.5	2/15/2017	5.2	71
2/19 - 2/25	2/25/2017	ND (<1.0)	0.5	0.0072	2/21/2017	6.73	ND (<0.25)	10	480	3,900	0.59	19	273	--	0.59	8.5	--	0.059	0.85	2/22/2017	5.4	78		
2/26 - 3/4	3/4/2017	ND (<1.0)	0.5	0.0074	2/27/2017	6.72	ND (<0.25)	8.9	530	3,400	ND (<0.50)	19	282	--	0.36	5.3	--	0.046	0.68	3/1/2017	2.7	40		
3/5 - 3/11	3/11/2017	ND (<1.0)	0.5	0.0074	3/6/2017	6.78	ND (<0.25)	7.9	490	1,800	1.6	17	253	--	1.0	15	--	0.11	1.6	3/8/2017	2.3	34		
3/12 - 3/18	3/18/2017	ND (<1.0)	0.5	0.0074	3/13/2017	6.75	ND (<0.25)	6.7	540	2,300	1.2	21	309	--	0.50	7.4	--	0.058	0.85	3/15/2017	1.9	28		
3/19 - 3/25	3/25/2017	ND (<1.0)	0.5	0.0074	3/20/2017	6.65	ND (<0.25)	9.5	490	4,700	ND (<0.50)	27	398	--	0.32	4.7	--	0.073	1.08	3/22/2017	1.8	27		
3/26 - 4/1	3/31/2017	ND (<1.0)	0.5	0.0071	3/27/2017	6.80	ND (<0.25)	7.1	540	2,900	1.2	27	384	--	0.26	3.7	--	0.10	1.4	3/29/2017	5.4	77		
4/2 - 4/8	4/8/2017	ND (<1.0)	0.5	0.0074	4/3/2017	6.72	ND (<0.25)	17	570	3,500	0.87	20	296	ND (<0.10)	0.05	0.74	--	0.066	0.98	4/5/2017	2.3	34		
4/9 - 4/15	4/15/2017	ND (<1.0)	0.5	0.0074	4/10/2017	6.70	ND (<0.25)	12	570	3,900	1.2	24	354	--	0.16	2.4	--	0.16	2.4	4/12/2017	1.9	28		
4/16 - 4/22	4/22/2017	ND (<1.0)	0.5	0.0078	4/17/2017	6.88	ND (<0.25)	20	530	4,000	ND (<0.50)	23	358	--	0.25	3.9	--	0.62	9.6	4/19/2017	4.1	64		
4/23 - 4/29	4/29/2017	ND (<1.0)	0.5	0.0078	4/24/2017	6.82	ND (<0.25)	11	520	2,900	1.3	21	330	--	0.31	4.9	--	0.084	1.3	4/26/2017	2.7	42		
4/30 - 5/6	5/6/2017	ND (<1.0)	0.5	0.0078	5/1/2017	6.76	ND (<0.25)	7.6	490	1,800	ND (<0.50)	19	296	--	0.11	1.7	--	0.55	8.6	5/3/2017	1.2	19		
5/7 - 5/13	5/13/2017	ND (<1.0)	0.5	0.0078	5/8/2017	6.68	ND (<0.25)	8.5	450	3,000	0.64	19	296	--	0.17	2.6	--	0.033	0.51	5/10/2017	1.5	23		
5/14 - 5/20	5/20/2017	ND (<1.0)	0.5	0.0073	5/15/2017	6.69	ND (<0.25)	9.0	540	3,300	1.0	16	234	--	0.31	4.5	--	0.081	1.18	5/17/2017	0.94	14		
5/21 - 5/27	5/27/2017	ND (<1.0)	0.5	0.0077	5/22/2017	6.93	ND (<0.25)	6.1	580	2,400	ND (<0.50)	18	278	--	0.15	2.3	--	0.074	1.14	5/24/2017	2.8	43		
5/28 - 6/3	6/3/2017	ND (<1.0)	0.5	0.0079	5/29/2017	7.00	ND (<0.25)	10	500	2,700	2.0	28	444	--	0.29	4.6	--	0.046	0.73	5/31/2017	2.0	32		
6/4 - 6/10	6/10/2017	ND (<1.0)	0.5	0.0075	6/5/2017	6.81	ND (<0.25)	5.8	540	2,200	ND (<0.50)	20	299	--	0.15	2.2	--	0.048	0.72	6/7/2017	0.68	10.2		
6/11 - 6/17	6/17/2017	ND (<1.0)	0.5	0.0063	6/12/2017	6.93	ND (<0.25)	21	560	2,200	1.9	31	389	--	0.26	3.3	--	0.056	0.70	6/14/2017	0.97	12.2		
6/18 - 6/24	6/24/2017	ND (<1.0)	0.5	0.0062	6/19/2017	6.89	ND (<0.25)	6.3	620	770	ND (<0.50)	9.0	112	--	0.22	2.7	--	0.059	0.74	6/21/2017	0.85	10.6		
6/25 - 7/1	7/1/2017	ND (<1.0)	0.5	0.0066	6/26/2017	7.10	ND (<0.25)	7.9	560	1,400	0.88	12	157	ND (<0.10)	0.05	0.66	--	0.044	0.58	6/30/2017	2.3	30		
7/2 - 7/8	7/8/2017	16**	16	0.21	7/3/2017	7.16	ND (<0.25)	2.6	520	680	1.6	9.3	125	ND (<0.10)	0.05	0.67	--	0.042	0.56	7/5/2017	2.0	25		
7/9 - 7/15	7/15/2017	15**	15	0.22	7/10/2017	6.77	ND (<0.25)	7.2	590	2,100	ND (<0.50)	21	293	--	0.20	2.8**	--	0.099	1.4	7/12/2017	1.2	18		
7/16 - 7/22	7/22/2017	8.8**	8.8	0.13	7/17/2017	6.80	ND (<0.25)	4.1	530	1,100	ND (<0.50)	11	165	--	0.13	2.0**	--	0.043	0.65	7/19/2017	1.2	21		
7/23 - 7/29	7/29/2017	ND (<1.0)	0.5	0.0077	7/24/2017	6.80	ND (<0.25)	2.9	540	710	1.5	3.2	49	--	0.59	9.0**	--	0.050	0.76	7/26/2017	1.7	27		
7/30 - 8/5	8/5/2017	ND (<1.0)	0.5	0.0066	7/31/2017	6.58	ND (<0.25)	2.6	620	670	8.1	16	238	--	7.0	104**	--	0.042	0.62	8/2/2017	1.6	24		
8/6 - 8/12	8/12/2017	ND (<1.0)	0.5	0.0074	8/7/2017	6.84	ND (<0.25)	ND (<2.5)	410	580	1.2	2.8	41	--	0.13	1.9**	--	0.032	0.47	8/9/2017	1.3	20		
8/13 - 8/19	8/19/2017	ND (<1.0)	0.5	0.0076	8/14/2017	6.64	ND (<0.25)	13	470	4,300	ND (<0.50)	52	800	--	0.12	1.8**	--	0.076	1.2	8/16/2017	1.8	27		
8/20 - 8/26	8/26/2017	ND (<1.0)	0.5	0.0067	8/21/2017	7.05	ND (<0.25)	14	580	5,200	0.90	62	872	ND (<0.10)	0.05	0.70**	--	0.18	2.5	8/23/2017	ND (<0.50)	0.25	2.2	
8/27 - 9/2	9/2/2017	ND (<1.0)	0.5	0.0081	8/28/2017	7.15	ND (<0.25)	7.7	620	2,300	1.2	18	276	ND (<0.10)	0.05	0.77**	--	0.18	2.8	8/30/2017	2.1	35		
9/3 - 9/9	9/9/2017	ND (<1.0)	0.5	0.0081	9/5/2017	6.65	ND (<0.25)	6.6	580	3,500	ND (<0.50)	42	681	--	0.23	3.5	--	0.14	2.3	9/6/2017	0.75	12		
9/10 - 9/16	9/16/2017	ND (<1.0)	0.5	0.0079	9/11/2017	6.72	ND (<0.25)	3.5	580	960	2.1	14	224	--	0.19	3.0	--	0.053	0.85	9/13/2017	3.6	58		

Attachment B

Equipment Tracking Form

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
Main Plant Equipment						
1		Seep Wells and Lift Station 1				
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running			
1.03		Lift Station 1 Lift Pump B	Standby			
1.04		Area in and around Lift Station 1	Running			
2		Athens Road Wells and Lift Station 3				
2.01		Athens Road Well Field, 9 wells	Running		2	Art-9 was pulled and inspected. The pigtail was also replaced.
2.02		Lift Station 3 Lift Pump A	Standby		2	The motor was replaced on the turbine.
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running			
3		Lift Station 2 and Transmission Pipelines				
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby		3	New seal water tubing was installed on the pump. A new gasket was also installed on the discharge of the pump.
3.05		Area in and around Lift Station 2	Running		1	The LS was taken down to inspect all the wiring in the electrical panel. The discharge piping was also corrected. A new flow tube was also installed.
4		Interceptor Wells and Cr Treatment Plant				
4.01		IWF Well Field, 30 wells	Running			
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation			
4.05		Filter Press	Running			
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Running			
4.08		Interceptor Booster Pump B	Standby			
4.09		Area In And Around GWTP	Running			
5		Equalization Area and GW-11 Pond				
5.01	PID10A	Pond GW-11	In operation			
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			
5.05	PID10A	Area in and Around EQ	In operation		2	A new SS 8" ball valve was installed on the pig launcher.

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
5.06	PID10A	Raw Water Feed Pump - P102A				
5.07	PID10A	Raw Water Feed Pump - P102B				
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running			
6		First Stage FBRs A, 1 & 2				
6.01	PID14	FBR A			3	A new positioner was installed on the feed valve.
6.02	PID14	Separator Tank - 1401				
6.03	PID14	Media Return Pump - P 1401				
6.04	PID14	P1401A				
6.05	PID01A	P1401B				
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012	Running			
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
7		First Stage FBRs 3 & 4				
7.01	PID01B	FBR 3	Running			
7.02	PID01B	FBR 4	Running		2	A new positioner was installed on the feed valve. A new solenoid was installed on the seall water line.
7.03	PID02B	First Stage Separator Tank - T2012	Running			
7.04	PID01B	Media Return Pump - P2012	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
7.05	PID01B	First Stage FBR Pump - P1013	Running			
7.06	PID01B	First Stage FRB Pump - P1014	Running		2	A new swing check valve was installed on the discharge of the recycle pump.
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723				
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
8		Second Stage FBRs 5 & 6				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running			
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
9		Second Stage FBRs 7 & 8				
9.01	PID03B	FBR 7	Running			
9.02	PID03B	FBR 8	Running		3	The airlines were cleared of debris.
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Running			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			
10		Aeration and DAF System				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Bio filter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump				
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running		3	New air blowdown valves were installed.
10.13	PID05	DAF Float Pump - P502	Running		3	The pump was rebuilt.
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running		3	New air blowdown valves were installed.
10.16	PID05	DAF Float Pump - P552	Running		3	The pump was rebuilt.
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			
11		Pumping System (Old Effluent)				
11.01	PID06	Effluent Tank 601	In operation		2	A new motor was installed and a new motor was ordered to have as a spare.
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602	Standby			
12		Sand Filter System				
12.01	PID17	Sand Filter			1	The unit was drained and new expansion links were installed around the main header to stop and possible leaks.
12.02	PID17	Filter Reject Tank	In operation		3	A new y-strainer was installed on the reject tank to remove sand before entering the reject tank.
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
13		Effluent Tank and Pumping				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
13.04	PID10C	Area Around Effluent and North D-1	Running			
14		Solids Collection and Pressing System				
14.01	PID16	Sludge Storage Tank	In operation		1	The system was taken offline to inspect for solid build up inside the vessel. The tank was flushed and the system was put back online.
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation			
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902				
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			
		Chemical Systems				
15		Electron Donor System				
15.01	PID07B	Electron Donor Tank	In operation			
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation		1	New pumps were installed to better control the pH system.
23	PID07C	Ferric Chloride System	In operation			
24	PID07B	Polymer Systems - DAF	In operation			
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
		Utility Systems				
26		Compressed Air System				

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
26.01	PID08	West Compressor	Running		1	The air end went down. A new air end was ordered and will be installed by Air Center.
26.02	PID08	East Compressor	Running			
26.03	PID08	O2 Compressor	Running			
26.04	PID08	Compressed Air Receiver Tank	In operation			
26.05	PID08	Air Dryer	Running			
26.06	PID08	Oil Removal Filter	In operation			
26.07	PID08	Particulate Filter	In operation			
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			
29		Well Control System/ Allen Bradley Controls	In operation			
30		MCC FBR Pad	In operation			
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			
Miscellaneous Systems						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
Shelf Spares						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			Spares are on the shelf.

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant