

---

**To:** Nevada Division of Environmental Protection  
Nevada Environmental Response Trust

---

**Cc:** Nevada Environmental Response Trust Stakeholders

---

**From:** Ryan Sullivan, Vice President Service and O&M

---

**Date:** December 21, 2017

---

**Subject:** NERT – GWETS Operation Monthly Report – November 2017

---

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during November 2017.

### Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in November 2017. Flow from PC-119, PC-120, PC-121, and PC-133 was routed to the IX system, bypassing all flow meters associated with the FBR plant. The flow rate to the IX system averaged approximately 183 gallons per minute (gpm) during November 2017. The flow rate to the FBR plant averaged approximately 1,042 gpm. At the end of the month, the GW-11 Pond volume was at 34.4 million gallons (MG), which would allow 19.5 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond remained approximately the same from the end of October 2017. Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 0.46 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 279 mg/L for the month, with a maximum concentration of 310 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of October 2017 averaged 180 mg/l, with a maximum concentration of 270 mg/l. Fluctuations in the influent perchlorate concentrations are due to the changes in the AP-5 treatment feed rate and not a result of groundwater changes.

### Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. These tables also include data associated with the AP-5 decant liquids. Figure 2 graphically presents historical perchlorate and chromium mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

## Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

### 1. GW-11

There were no operational issues with GW-11 in the month of November.

### 2. Biological Plant

Treatment of AP-5 water through the FBR Biological plant continued in the month of November starting at a flow rate of 6.5 gpm. Flow rate increased incrementally through November with a flow rate on Nov. 30<sup>th</sup> of 7.5 gpm.

There was one Influent diversion into GW-11 for the month of November, two events that prevented the operation of a portion of the extraction wells, two Effluent diversions into GW-11, and one event that caused the FBR plant to be taken out of feeding mode while keeping the extraction wells operational. Below is a description of the events that occurred:

#### Diversion Events

- Influent Diversion to GW-11 on Nov. 16<sup>th</sup> at 9:15am to 2:40pm due to maintenance activities on the plant compressed air system. Effluent flow was returned to the outfall at 3:55pm.
- Effluent Diversion to GW-11 on Nov. 13<sup>th</sup> at 11:23am to 12:08pm due to complications in retrieving the line "pig". Approximately 49,788 gallons diverted.
- Effluent Diversion to GW-11 on Nov. 30<sup>th</sup> at 10:45am to 1:00pm due to maintenance on the Effluent line combo valves. Approximately 158,920 gallons diverted.

#### Unplanned Event

- The extraction wells within eastern leg of the IWF were prevented from operating on Nov. 10<sup>th</sup> at 1:57pm to 2:15pm due to maintenance on the electrical contactor for well I-O.
- The FBR plant was placed into Recycle mode due to a malfunctioning level control valve on the P-601 effluent pump on Nov. 21<sup>st</sup> from 6:35am to 7:01am. The valve was repaired and the plant returned to Feeding mode. A replacement valve actuator and positioner have been ordered.
- The IWF extraction wells were prevented from operating on Nov. 27<sup>th</sup> at 2:31am to 2:37am and 4:00am to 4:08am due to high TK-5 influent tank levels at the GWTP. The root cause of the high level was due to an obstruction between the Degassifier tank and the Clarifier tank causing the Degassifier to overflow into the sump. This started a feedback loop that lead to the high level alarm. The obstruction has been removed and flow returned to normal.

### 3. Spills

There were no reportable spills during the reporting period.

#### 4. Maintenance

- Major maintenance performed by ETI in the month included:
  - I. Replaced the seal water lines on the Lift Station 2 turbine pumps with Stainless Steel tubing.
  - II. An airlift at the Sandfilter was taken offline to remove debris from the reject line and to rebuild and install a new airlift.
  - III. New blowdown valves were installed on the filter presses in the D-1 Building.
  - IV. A new hose was installed on the discharge of the GWTP pump.
  - V. A temporary A/C was installed on the MCC at Lift Station 2 until the original unit was repaired.
  - VI. New airlines near the DAF and the 601 tank were installed.
  - VII. Replaced the o-ring on the discharge of the swing check valve of P-102B.
  - VIII. Concrete was poured in the E-hut to eliminate the trip hazards.
  - IX. Insulation was installed on the FBR slam valves to prevent freezing of the actuators.
  - X. Replaced the Phosphoric acid pump for FBR 2 with the shelf spare.
  
- Preventative Maintenance completed or being performed by ETI in the month included:
  - I. Inspected the turbine pumps for any wear on the units.
  - II. Replaced the packing on the turbine pumps at LS1.
  - III. All sump pumps were inspected and the pits were cleaned.
  - IV. All ORP and pH probes were inspected, standardized, and calibrated.
  - V. An inspection of the combo valves on the effluent pipeline was conducted.
  - VI. While the Sandfilter was offline, an inspection of the unit was conducted and minor repairs were made.
  - VII. The west press was pressure washed and put back online.

#### GWETS Upgrades and Facility Projects

The following is a summary of the initiatives in-progress during the reporting period at the direction of the Trust:

1. **Ammonia Pretreatment** - The Trust is currently evaluating options to reduce ammonia concentrations in the AP decant.

#### Equipment Availability Tracking

ETI operators continue to update the equipment tracking form on a weekly basis or whenever there is a change in the status of key equipment. During regular site visits, Tetra Tech field personnel verify the entries on the form, including both the operating status and confirmation of the inventory of required shelf spares. The equipment tracking form is included as Attachment B.

#### GWETS Staffing

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

# Tables

---

*Operational Metrics*

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) <sup>5 6</sup>	Chromium (TR) (mg/L) <sup>5 6</sup>	Chromium(VI) (mg/L) <sup>5 6</sup>
SWF Total Extraction <sup>2</sup>	745 <sup>1</sup>	9.8	ND	0.00060
AWF Total Extraction <sup>2</sup>	461 <sup>1</sup>	93	0.17	0.17
IWF Total Extraction <sup>2</sup>	61 <sup>1</sup>	764	8.3	7.7
AP Area Total Extraction <sup>3</sup>	12 <sup>1</sup>	822	NA	0.030
GWTP Effluent <sup>4</sup>	62	728	0.22	ND
GW-11 Influent <sup>2</sup>	7.7	52	0.077	0.039
FBR Influent <sup>4 7</sup>	1,042	279	0.085	0.014
T-205 Effluent (AP-5 Wash Water) <sup>7 8</sup>	7.0	31,077	NA	NA

## Notes:

TR = Total Recoverable; NA = Not Analyzed; ND = Not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Sum of daily average flow for individual wells.

2: Perchlorate and chromium TR sampled monthly, values reported from TestAmerica.

3: Perchlorate, chromium TR and chromium (VI) sampled twice weekly, values reported from TestAmerica.

4: Perchlorate, chromium TR and chromium (VI) sampled weekly, values reported from TestAmerica.

5: All concentrations reported are monthly flow weighted averages.

6: ND analytical values are treated as zero values in the flow weighted average calculations.

7: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.

8: Flow weighted average concentration based on mass flow meter readings.

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) <sup>1</sup>	Chromium (TR) (lbs/month) <sup>1</sup>	Chromium (VI) (lbs/month) <sup>1</sup>
SWF Total Extraction	2,635	ND	0.16
AWF Total Extraction	15,529	28	29
IWF Total Extraction	16,832	183	170
AP Area Total Extraction	3,425	NA	0.12
GWTP Effluent	16,385	4.9	ND
GW-11 Influent	145	0.21	0.11
FBR Influent <sup>2</sup>	105,096	29	4.7
T-205 Effluent (AP-5 Wash Water) <sup>2 3</sup>	78,856	NA	NA

## Notes:

TR = Total Recoverable; NA = Not Analyzed.

1: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).


2: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.

3: AP-5 Wash Water concentrations and mass flux are estimates based on mass flow meter readings.

# Figures

---


*Operational Metrics*



Note: Measurements switched from manual to transducer on 06/20/17. The pond volume fluctuations between 05/30 and 06/20 reflect the decreasing manual measurement accuracy at lower pond levels.



Figure 2 - Historical Perchlorate Mass Removed From Environment



# Attachment A

---

*NPDES Tracking Sheet (Prepared by ENVIRON)*

Treated Effluent at Outfall 001																					
Continuous		Daily Samples, composited weekly		Weekly Grab Samples										Weekly, collected separately			Quarterly				
Flow Rate		Perchlorate		pH	Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)	Total Suspended Solids (TSS)		Total Ammonia as N		Total Phosphorus as P		BOD <sub>5</sub> (inhibited)			Total Dissolved Solids (TDS)		
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (µg/L)	30-Day Avg. (lbs/day)	Daily Min. (S.U.)	Daily Max. (S.U.)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (mg/L)	Daily Max. (mg/L)	Daily Average (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)		30-Day Avg. (lbs/day)		30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	Daily Max. (mg/L)		
2.52	2.88	18	0.38	6.5	9.0	10	100	5,000	10,000	20	135	2,839		20*		10*		25	40	525	8,000
January 2017	1.38	1.42	1.3	0.014	6.75	7.13	0.13	30	510	9,600	0.60	32	370	4.8	1.1	2.4	4.3	28			
February 2017	1.50	1.80	9	0.09	6.72	7.16	0.13	36	530	4,200	0.59	21	280	4.0	1.1	5.7	8.4	68			5,400
March 2017	1.76	1.86	0.5	0.0073	6.65	6.80	0.13	9.5	540	4,700	1.6	23	340	8	1.2	2.8	5.4	41			
April 2017	1.82	1.93	0.5	0.0076	6.70	6.88	0.13	20	570	4,000	1.3	22	330	3.0	3.6	2.8	4.1	42			
May 2017	1.84	1.91	0.5	0.0077	6.68	7.00	0.13	10	580	3,300	2.0	20	310	3.2	2.4	1.7	2.8	26			4,900
June 2017	1.62	1.94	0.5	0.0066	6.81	7.10	0.13	21	620	2,200	1.9	18	240	2.2	0.68	1.2	2.3	16			
July 2017	1.75	2.14	10	0.14	6.58	7.16	0.13	7.2	620	2,100	1.1	12	170	16	0.8	1.5	2.0	23			
August 2017	1.72	1.97	0.5	0.0073	6.64	7.15	0.13	14	620	5,200	8.2	34	500	9	4	1.4	2.1	22			4,400
September 2017	1.92	2.01	1.3	0.021	6.50	6.86	0.13	6.6	600	3,500	2.1	19	310	3.4	1.3	2.3	3.6	36			
October 2017	1.92	2.02	0.5	0.0080	6.57	6.90	0.13	8.5	680	3,700	11	11	180	96	1.2	2.0	2.7	32			
November 2017 (month to date)	1.81	2.00	0.9	0.014	6.55	6.81	0.29	6.0	830	4,900	14	16	240	160	1.3	3.5	4.2	54			4,400
December 2017 (month to date)	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

Daily Grab Sample Dates	Composite Sample Date	µg/L	lbs/day	Sample Date	S.U.	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	Sample Date	mg/L		
1/1 - 1/7	1/7/2017	ND (<2.5)	1.3	0.014	1/3/2017	6.76	ND (<0.25)	8.0	280	3,100	ND (<0.50)	26	300	--	0.35	4.0	--	0.046	0.53	1/4/2017	2.2	2.5	
1/8 - 1/14	1/14/2017	ND (<2.5)	1.3	0.015	1/11/2017	7.03	ND (<0.25)	30	410	9,600	0.60	62	728	--	0.60	7.0	--	0.13	1.5	1/11/2017	ND (<0.50)	0.25	2.9
1/15 - 1/21	1/21/2017	ND (<2.5)	1.3	0.015	1/16/2017	7.13	ND (<0.25)	17	510	3,400	ND (<0.50)	27	313	--	0.23	2.7	--	0.078	0.91	1/18/2017	4.3	50	
1/22 - 1/28	1/28/2017	ND (<2.5)	1.3	0.014	1/24/2017	6.89	ND (<0.25)	29	480	3,100	ND (<0.50)	22	247	--	0.37	4.2	--	0.079	0.89	1/25/2017	2.9	33	
1/29 - 2/4	2/4/2017	ND (<2.5)	1.3	0.014	1/30/2017	6.75	ND (<0.25)	16	390	3,100	0.52	23	263	--	0.52	5.9	--	0.13	1.5	2/1/2017	3.9	45	
2/5 - 2/11	2/11/2017	34*	34	0.32	2/6/2017	7.00	ND (<0.25)	21	460	4,200	ND (<0.50)	25	234	ND (<0.10)	0.050	0.47	--	0.13	1.2	2/10/2017	8.4	29	
2/12 - 2/18	2/18/2017	ND (<1.0)	0.5	0.0068	2/13/2017	7.16	ND (<0.25)	36	320	340	ND (<0.50)	19	24	260	329	0.12	1.6	--	0.11	1.5	2/15/2017	5.2	71
2/19 - 2/25	2/25/2017	ND (<1.0)	0.5	0.0072	2/21/2017	6.73	ND (<0.25)	10	480	3,900	0.59	19	273	--	0.59	8.5	--	0.059	0.85	2/22/2017	5.4	78	
2/26 - 3/4	3/4/2017	ND (<1.0)	0.5	0.0074	2/27/2017	6.72	ND (<0.25)	8.9	530	3,400	ND (<0.50)	19	282	--	0.36	5.3	--	0.046	0.68	3/1/2017	2.7	40	
3/5 - 3/11	3/11/2017	ND (<1.0)	0.5	0.0074	3/6/2017	6.78	ND (<0.25)	7.9	490	1,800	1.6	17	253	--	1.0	15	--	0.11	1.6	3/8/2017	2.3	34	
3/12 - 3/18	3/18/2017	ND (<1.0)	0.5	0.0074	3/13/2017	6.75	ND (<0.25)	6.7	540	2,300	1.2	21	309	--	0.50	7.4	--	0.058	0.85	3/15/2017	1.9	28	
3/19 - 3/25	3/25/2017	ND (<1.0)	0.5	0.0074	3/20/2017	6.65	ND (<0.25)	9.5	490	4,700	ND (<0.50)	27	398	--	0.32	4.7	--	0.073	1.08	3/22/2017	1.8	27	
3/26 - 4/1	3/31/2017	ND (<1.0)	0.5	0.0071	3/27/2017	6.80	ND (<0.25)	7.1	540	2,900	1.2	27	384	--	0.26	3.7	--	0.10	1.4	3/29/2017	5.4	77	
4/2 - 4/8	4/8/2017	ND (<1.0)	0.5	0.0074	4/3/2017	6.72	ND (<0.25)	17	570	3,500	0.87	20	296	ND (<0.10)	0.05	0.74	--	0.066	0.98	4/5/2017	2.3	34	
4/9 - 4/15	4/15/2017	ND (<1.0)	0.5	0.0074	4/10/2017	6.70	ND (<0.25)	12	570	3,900	1.2	24	354	--	0.16	2.4	--	0.16	2.4	4/12/2017	1.9	28	
4/16 - 4/22	4/22/2017	ND (<1.0)	0.5	0.0078	4/17/2017	6.88	ND (<0.25)	30	530	4,000	ND (<0.50)	23	358	--	0.25	3.9	--	0.62	9.6	4/19/2017	4.1	64	
4/23 - 4/29	4/29/2017	ND (<1.0)	0.5	0.0078	4/24/2017	6.82	ND (<0.25)	11	520	2,900	1.3	21	330	--	0.31	4.9	--	0.084	1.3	4/26/2017	2.7	42	
4/30 - 5/6	5/6/2017	ND (<1.0)	0.5	0.0078	5/1/2017	6.76	ND (<0.25)	7.6	490	1,800	ND (<0.50)	19	296	--	0.11	1.7	--	0.55	8.6	5/3/2017	1.2	19	
5/7 - 5/13	5/13/2017	ND (<1.0)	0.5	0.0078	5/8/2017	6.68	ND (<0.25)	8.5	450	3,000	0.64	19	296	--	0.17	2.6	--	0.033	0.51	5/10/2017	1.5	23	
5/14 - 5/20	5/20/2017	ND (<1.0)	0.5	0.0073	5/15/2017	6.69	ND (<0.25)	9.0	540	3,300	1.0	16	234	--	0.31	4.5	--	0.081	1.18	5/17/2017	0.94	14	
5/21 - 5/27	5/27/2017	ND (<1.0)	0.5	0.0077	5/22/2017	6.93	ND (<0.25)	6.1	580	2,400	ND (<0.50)	18	278	--	0.15	2.3	--	0.074	1.14	5/24/2017	2.8	43	
5/28 - 6/3	6/3/2017	ND (<1.0)	0.5	0.0079	5/29/2017	7.00	ND (<0.25)	10	500	2,700	2.0	28	444	--	0.29	4.6	--	0.046	0.73	5/31/2017	2.0	32	
6/4 - 6/10	6/10/2017	ND (<1.0)	0.5	0.0075	6/5/2017	6.81	ND (<0.25)	5.8	540	2,200	ND (<0.50)	20	299	--	0.15	2.2	--	0.048	0.72	6/7/2017	0.68	10.2	
6/11 - 6/17	6/17/2017	ND (<1.0)	0.5	0.0063	6/12/2017	6.93	ND (<0.25)	21	560	2,200	1.9	31	389	--	0.26	3.3	--	0.056	0.70	6/14/2017	0.97	12.2	
6/18 - 6/24	6/24/2017	ND (<1.0)	0.5	0.0062	6/19/2017	6.89	ND (<0.25)	6.3	620	770	ND (<0.50)	9.0	112	--	0.22	2.7	--	0.059	0.74	6/21/2017	0.85	10.6	
6/25 - 7/1	7/1/2017	ND (<1.0)	0.5	0.0066	6/26/2017	7.10	ND (<0.25)	7.9	560	1,400	0.88	12	157	ND (<0.10)	0.05	0.66	--	0.044	0.58	6/30/2017	2.3	30	
7/2 - 7/8	7/8/2017	16**	16	0.21	7/3/2017	7.16	ND (<0.25)	2.6	520	680	1.6	9.3	125	ND (<0.10)	0.05	0.67	--	0.042	0.56	7/5/2017	2.0	25	
7/9 - 7/15	7/15/2017	15**	15	0.22	7/10/2017	6.77	ND (<0.25)	7.2	590	2,100	ND (<0.50)	21	293	--	0.20	2.8**	--	0.099	1.4	7/12/2017	1.2	18	
7/16 - 7/22	7/22/2017	8.8**	8.8	0.13	7/17/2017	6.80	ND (<0.25)	4.1	530	1,100	ND (<0.50)	11	165	--	0.13	2.0**	--	0.043	0.65	7/19/2017	1.2	21	
7/23 - 7/29	7/29/2017	ND (<1.0)	0.5	0.0077	7/24/2017	6.80	ND (<0.25)	2.9	540	710	1.5	3.2	49	--	0.59	9.0**	--	0.050	0.76	7/26/2017	1.7	27	
7/30 - 8/5	8/5/2017	ND (<1.0)	0.5	0.0066	7/31/2017	6.58	ND (<0.25)	2.6	620	670	8.1	16	238	--	7.0	104**	--	0.042	0.62	8/2/2017	1.6	24	
8/6 - 8/12	8/12/2017	ND (<1.0)	0.5	0.0074	8/7/2017	6.84	ND (<0.25)	ND (<2.5)	410	580	1.2	2.8	41	--	0.13	1.9**	--	0.032	0.47	8/9/2017	1.3	20	
8/13 - 8/19	8/19/2017	ND (<1.0)	0.5	0.0076	8/14/2017	6.64	ND (<0.25)	13	470	4,300	ND (<0.50)	52	800	--	0.12	1.8**	--	0.76	12	8/16/2017	1.8	27	
8/20 - 8/26	8/26/2017	ND (<1.0)	0.5	0.0067	8/21/2017	7.05	ND (<0.25)	14	580	5,200	0.90	62	872	ND (<0.10)	0.05	0.70**	--	0.18	2.5	8/23/2017	ND (<0.50)	0.25	2.2
8/27 - 9/2	9/2/2017	ND (<1.0)	0.5	0.0081	8/28/2017	7.15	ND (<0.25)	7.7	620	2,300	1.2	18	276	ND (<0.10)	0.05	0.77**	--	0.18	2.8	8/30/2017	2.1	35	
9/3 - 9/9	9/9/2017	ND (<1.0)	0.5	0.0081	9/5/2017																		

# Attachment B

---

*Equipment Tracking Form*

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>Main Plant Equipment</b>						
<b>1 Seep Wells and Lift Station 1</b>						
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running		2	The packing was replaced on the turbine.
1.03		Lift Station 1 Lift Pump B	Standby			
1.04		Area in and around Lift Station 1	Running			
<b>2 Athens Road Wells and Lift Station 3</b>						
2.01		Athens Road Well Field, 9 wells	Running			
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running			
<b>3 Lift Station 2 and Transmission Pipelines</b>						
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running		3	The A/C unit was repaired. The motor and condenser was replaced.
<b>4 Interceptor Wells and Cr Treatment Plant</b>						
4.01		IWF Well Field, 30 wells	Running		2	A new motor and pump was installed on I-G.
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation		3	The piping connecting the de-gassifier and the clarifier was flushed.
4.05		Filter Press	Running		2	A new discharge hose was installed on the press pump.
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Running			
4.08		Interceptor Booster Pump B	Standby			
4.09		Area In And Around GWTP	Running			
<b>5 Equalization Area and GW-11 Pond</b>						
5.01	PID10A	Pond GW-11	In operation			
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			
5.05	PID10A	Area in and Around EQ	In operation			
5.06	PID10A	Raw Water Feed Pump - P102A				

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
5.07	PID10A	Raw Water Feed Pump - P102B				
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running			
<b>6</b>		<b>First Stage FBRs A, 1 &amp; 2</b>				
6.01	PID14	FBR A				
6.02	PID14	Separator Tank - 1401				
6.03	PID14	Media Return Pump - P 1401				
6.04	PID14	P1401A				
6.05	PID01A	P1401B				
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012	Running			
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
<b>7</b>		<b>First Stage FBRs 3 &amp; 4</b>				
7.01	PID01B	FBR 3	Running			
7.02	PID01B	FBR 4	Running			
7.03	PID02B	First Stage Separator Tank - T2012	Running			
7.04	PID01B	Media Return Pump - P2012	Running			
7.05	PID01B	First Stage FBR Pump - P1013	Running			
7.06	PID01B	First Stage FRB Pump - P1014	Running			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723				
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
<b>8</b>		<b>Second Stage FBRs 5 &amp; 6</b>				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running			
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
<b>9</b>		<b>Second Stage FBRs 7 &amp; 8</b>				
9.01	PID03B	FBR 7	Running			
9.02	PID03B	FBR 8	Running			
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Running			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made  
 2= Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>10</b>		<b>Aeration and DAF System</b>				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Bio filter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump				
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running		2	A hole was patched on the DAF sludge tank.
10.15	PID05	DAF Pressure Pump - P551	Running			
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			
<b>11</b>		<b>Pumping System (Old Effluent)</b>				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602	Standby			
<b>12</b>		<b>Sand Filter System</b>				
12.01	PID17	Sand Filter			2	The unit was taken offline to clear debris from the reject line. Airlift #3 was rebuilt.
12.02	PID17	Filter Reject Tank	In operation			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
<b>13</b>		<b>Effluent Tank and Pumping</b>				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			
13.04	PID10C	Area Around Effluent and North D-1	Running			
<b>14</b>		<b>Solids Collection and Pressing System</b>				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant



Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902				
14.07	PID09	West Press	Standby		4	Press was pressure washed.
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			
<b>Chemical Systems</b>						
15		<b>Electron Donor System</b>				
15.01	PID07B	Electron Donor Tank	In operation			
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23	PID07C	Ferric Chloride System	In operation			
24	PID07B	Polymer Systems - DAF	In operation			
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
<b>Utility Systems</b>						
26		<b>Compressed Air System</b>				
26.01	PID08	West Compressor	Running			
26.02	PID08	East Compressor	Running		1	The compressor is down due to a blown air cooler. Parts are to arrive by the end of Dec.
26.03	PID08	O2 Compressor	Running			
26.04	PID08	Compressed Air Receiver Tank	In operation			
26.05	PID08	Air Dryer	Running			
26.06	PID08	Oil Removal Filter	In operation			
26.07	PID08	Particulate Filter	In operation			
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
29		Well Control System/ Allen Bradley Controls	In operation			
30		MCC FBR Pad	In operation			
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			
<b>Miscellaneous Systems</b>						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
<b>Shelf Spares</b>						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			Spares are on the shelf.

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant