

---

**To:** Nevada Division of Environmental Protection  
Nevada Environmental Response Trust

---

**Cc:** Nevada Environmental Response Trust Stakeholders

---

**From:** Ryan Sullivan, Vice President Service and O&M

---

**Date:** January 22, 2018

---

**Subject:** NERT – GWETS Operation Monthly Report – December 2017

---

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during December 2017.

### Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in December 2017. Flow from PC-119, PC-120, PC-121, and PC-133 was routed to the IX system, bypassing all flow meters associated with the FBR plant. The flow rate to the IX system averaged approximately 183 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 1,070 gpm during December 2017. At the end of the month, the GW-11 Pond volume was at 36.0 million gallons (MG), which would allow 18.4 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond increased approximately 1.6 MG from the end of November 2017. Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 0.92 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 259 mg/L for the month, with a maximum concentration of 290 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of November 2017 averaged 279 mg/l, with a maximum concentration of 310 mg/l. Fluctuations in the influent perchlorate concentrations are due to the changes in the AP-5 treatment feed rate and not a result of groundwater changes.

### Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. These tables also include data associated with the AP-5 decant liquids. Figure 2 graphically presents historical perchlorate and chromium mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

## Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

### 1. GW-11

There were no operational issues with GW-11 in the month of December.

### 2. Biological Plant

Treatment of AP-5 water through the FBR Biological plant continued in the month of December starting at a flow rate of 7.5 gpm. AP-5 treatment maintained an average flow rate of 6.91 gpm for the month of December.

There were six Influent diversion events into GW-11 for the month of December, one Effluent diversion into GW-11, and four maintenance events that temporarily prevented the operation of the Athens Well Field. Below is a description of the events that occurred:

#### Diversion Events

- Influent Diversions to GW-11 on Dec. 2<sup>nd</sup> at 3:45pm to 5:15pm, Dec. 19<sup>th</sup> at 6:23am to 6:42am and 7:00am to 7:23am, and Dec. 20<sup>th</sup> at 12:17pm to 12:33pm due to a malfunctioning level control valve at the P-601 pump. The P-601 pump is located in between the DAF and the Sand Filter processes, and is used to transfer effluent from the DAF thru the Sand Filter and into the final Effluent tank. The replacement part arrived on Dec. 20<sup>th</sup> and the equipment was repaired with the effluent flow returning to the outfall at 12:33pm. Approx. 148,000 gallons were added to GW-11.
- Influent Diversions to GW-11 on Dec. 12<sup>th</sup> at 8:24am to 9:53am and Dec. 13<sup>th</sup> at 8:45am to 8:59am due to ongoing airline maintenance activities. Approx. 186,000 gallons were added to GW-11.
- Effluent Diversion to GW-11 on Dec. 29<sup>th</sup> at 1:16pm to 1:34pm due to high turbidity in the effluent. Adjustments to the plant operations were made and the Effluent flow was returned to the outfall at 1:34pm. Approx. 148,861 gallons of Effluent were added to GW-11.

#### Unplanned Event

- The Athens Well Field was prevented from operating due to a malfunctioning wet well level indicator at Lift Station 3 on four occasions from Dec 23<sup>rd</sup> at 10:43am to 12:19pm, Dec 26<sup>th</sup> at 12:56pm to 1:27pm, Dec 28<sup>th</sup> at 7:42pm to 8:35pm, and Dec 31<sup>st</sup> at 9:31am to 10:06am. Troubleshooting across all events revealed an internal malfunction in the instrumentation and the transmitter was replaced on Dec. 31<sup>st</sup> at 7:05pm.

### 3. Spills

There were no reportable spills during the reporting period.

#### 4. Maintenance

- Major maintenance performed by ETI in the month included:
  - I. The packing was replaced on the turbines at LS1 with a new material.
  - II. The seal water roto-meters were cleaned out.
  - III. An outside contractor completed service on the front gate.
  - IV. All ORP probes were flushed and standardized.
  - V. Infrared testing was performed on the electrical boxes as well as inspected for loose connections.
  - VI. The media return lines were flushed.
  - VII. The airlifts were pulled on the sandfilter and inspected for damages.
  - VIII. Ingersol-Rand performed service on the compressors while also addressing a repair.
  
- Preventative Maintenance completed or being performed by ETI in the month included:
  - I. Concrete coating was applied to all new containment structures.
  - II. A new actuator was installed on the 601 flow control valve.
  - III. A new guide and rails were installed on the front gate to reduce the amount of sagging on the gate.
  - IV. New airlines were installed that feed FBR 3/4 skid.
  - V. A new Phosphoric acid feed pump was installed for FBR A.
  - VI. The DAF polymer pump was cleared of debris and put back into service.
  - VII. New step ladders were assembled for better access to the chemical feed skids.
  - VIII. The A/C unit was repaired by an outside contractor on the LS2 MCC.

#### **GWETS Upgrades and Facility Projects**

The following is a summary of the initiatives in-progress during the reporting period at the direction of the Trust:

No open projects at this time.

#### **Equipment Availability Tracking**

ETI operators continue to update the equipment tracking form on a weekly basis or whenever there is a change in the status of key equipment. During regular site visits, Tetra Tech field personnel verify the entries on the form, including both the operating status and confirmation of the inventory of required shelf spares. The equipment tracking form is included as Attachment B.

#### **GWETS Staffing**

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

# Tables

---

*Operational Metrics*

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) <sup>5 6</sup>	Chromium (TR) (mg/L) <sup>5 6</sup>	Chromium(VI) (mg/L) <sup>5 6</sup>
SWF Total Extraction <sup>2</sup>	748 <sup>1</sup>	11	0.0012	0.0011
AWF Total Extraction <sup>2</sup>	466 <sup>1</sup>	79	0.16	0.18
IWF Total Extraction <sup>2</sup>	60 <sup>1</sup>	667	8.0	7.8
AP Area Total Extraction <sup>3</sup>	12 <sup>1</sup>	813	NA	0.034
GWTP Effluent <sup>4</sup>	79	744	0.62	ND
GW-11 Influent <sup>2</sup>	0.04	55	0.24	0.064
FBR Influent <sup>4 7</sup>	1,070	259	0.037	0.024
T-205 Effluent (AP-5 Wash Water) <sup>7 8</sup>	6.8	28,189	NA	NA

## Notes:

TR = Total Recoverable; NA = Not Analyzed; ND = Not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Sum of daily average flow for individual wells.

2: Perchlorate and chromium TR sampled monthly, values reported from TestAmerica.

3: Perchlorate, chromium TR and chromium (VI) sampled twice weekly, values reported from TestAmerica.

4: Perchlorate, chromium TR and chromium (VI) sampled weekly, values reported from TestAmerica.

5: All concentrations reported are monthly flow weighted averages.

6: ND analytical values are treated as zero values in the flow weighted average calculations.

7: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.

8: Flow weighted average concentration based on mass flow meter readings.

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) <sup>1</sup>	Chromium (TR) (lbs/month) <sup>1</sup>	Chromium (VI) (lbs/month) <sup>1</sup>
SWF Total Extraction	3,041	0.33	0.30
AWF Total Extraction	13,720	27	30
IWF Total Extraction	14,987	180	176
AP Area Total Extraction	3,599	NA	0.15
GWTP Effluent	21,780	18	ND
GW-11 Influent	0.90	0.00	0.00
FBR Influent <sup>2</sup>	103,468	15	9.6
T-205 Effluent (AP-5 Wash Water) <sup>2 3</sup>	71,301	NA	NA

## Notes:

TR = Total Recoverable; NA = Not Analyzed.

1: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).


2: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.

3: AP-5 Wash Water concentrations and mass flux are estimates based on mass flow meter readings.

# Figures

---


*Operational Metrics*



Note: Measurements switched from manual to transducer on 06/20/17. The pond volume fluctuations between 05/30 and 06/20 reflect the decreasing manual measurement accuracy at lower pond levels.



Figure 2 - Historical Perchlorate Mass Removed From Environment



# Attachment A

---

*NPDES Tracking Sheet (Prepared by ENVIRON)*

Treated Effluent at Outfall 001																						
Continuous		Daily Samples, composited weekly		Weekly Grab Samples										Weekly, collected separately			Quarterly					
Flow Rate		Perchlorate		pH		Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)		Total Suspended Solids (TSS)		Total Ammonia as N		Total Phosphorus as P		BOD <sub>5</sub> (inhibited)			Total Dissolved Solids (TDS)	
30-Day Avg. (MGD)		Daily Maximum (MGD)		30-Day Avg. (µg/L)		30-Day Avg. (lbs/day)		Daily Min. (S.U.)	Daily Max. (S.U.)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (mg/L)	Daily Average (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (mg/L)	30-Day Avg. (mg/L)	30-Day Avg. (mg/L)	Daily Max. (mg/L)	
2.52		2.88		18		0.38		6.5	9.0	10	100	5,000	10,000	20	135	2,839	20*	10*	25	40	525	8,000
January 2017	1.38	1.42	1.3	0.014	6.75	7.13	0.13	30	510	9,600	0.60	32	370	4.8				1.1	2.4	4.3	28	
February 2017	1.50	1.80	9	0.09	6.72	7.16	0.13	36	530	4,200	0.59	21	280	4.0				1.1	5.7	8.4	68	5,400
March 2017	1.76	1.86	0.5	0.0073	6.65	6.80	0.13	9.5	540	4,700	1.6	23	340	8				1.2	2.8	5.4	41	
April 2017	1.82	1.93	0.5	0.0076	6.70	6.88	0.13	20	570	4,000	1.3	22	330	3.0				3.6	2.8	4.1	42	
May 2017	1.84	1.91	0.5	0.0077	6.68	7.00	0.13	10	580	3,300	2.0	20	310	3.2				2.4	1.7	2.8	26	4,900
June 2017	1.62	1.94	0.5	0.0066	6.81	7.10	0.13	21	620	2,200	1.9	18	240	2.2				0.68	1.2	2.3	16	
July 2017	1.75	2.14	10	0.14	6.58	7.16	0.13	7.2	620	2,100	8.1	12	170	16				0.8	1.5	2.0	23	
August 2017	1.72	1.97	0.5	0.0073	6.64	7.15	0.13	14	620	5,200	1.2	34	500	9				4	1.4	2.1	22	4,400
September 2017	1.92	2.01	1.3	0.021	6.50	6.86	0.13	6.6	600	3,500	2.1	19	310	3.4				1.3	2.3	3.6	36	
October 2017	1.92	2.02	0.5	0.0080	6.57	6.90	0.13	8.5	680	3,700	11	11	180	96				1.2	2.0	2.7	32	
November 2017	1.81	2.00	0.8	0.012	6.55	6.81	0.29	6.0	830	4,900	14	16	240	160				1.3	3.5	4.2	54	4,400
December 2017	1.78	1.84	0.5	0.0074	6.73	6.88	0.13	12	700	2,500	15	18	270	180				2.8	3.7	4.5	53	
January 2018 (month to date)	1.84	1.85	0.5	0.0077	6.86	7.02	0.13	6.6	600	2,800	14	15	190	180				1.3	2.2	2.2	NA	NA

Daily Grab Sample Dates	Composite Sample Date	µg/L	lbs/day	Sample Date	S.U.	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	Sample Date	mg/L			
1/1 - 1/7	1/7/2017	ND (<2.5)	1.3	0.014	1/3/2017	6.76	ND (<0.25)	8.0	280	3,100	ND (<0.50)	26	300	--	0.35	4.0	--	0.046	0.53	1/4/2017	2.2	25		
1/8 - 1/14	1/14/2017	ND (<2.5)	1.3	0.015	1/11/2017	7.03	ND (<0.25)	30	410	9,600	0.60	62	728	--	0.60	7.0	--	0.13	1.5	1/11/2017	ND (<0.50)	0.25	2.9	
1/15 - 1/21	1/21/2017	ND (<2.5)	1.3	0.015	1/16/2017	7.13	ND (<0.25)	17	510	3,400	ND (<0.50)	27	313	--	0.23	2.7	--	0.078	0.91	1/18/2017	4.3	50		
1/22 - 1/28	1/28/2017	ND (<2.5)	1.3	0.014	1/24/2017	6.89	ND (<0.25)	29	480	3,100	ND (<0.50)	22	247	--	0.37	4.2	--	0.079	0.89	1/25/2017	2.9	33		
1/29 - 2/4	2/4/2017	ND (<2.5)	1.3	0.014	1/30/2017	6.75	ND (<0.25)	16	390	3,100	0.52	23	263	--	0.52	5.9	--	0.13	1.5	2/1/2017	3.9	45		
2/5 - 2/11	2/11/2017	34*	34	0.32	2/6/2017	7.00	ND (<0.25)	21	460	4,200	ND (<0.50)	25	234	ND (<0.10)	0.050	0.47	--	0.13	1.2	2/10/2017	8.4	79		
2/12 - 2/18	2/18/2017	ND (<1.0)	0.5	0.0068	2/13/2017	7.16	ND (<0.25)	36	320	340	ND (<0.50)	19	24	260	329	--	0.12	1.6	--	0.11	1.5	2/15/2017	5.2	71
2/19 - 2/25	2/25/2017	ND (<1.0)	0.5	0.0072	2/21/2017	6.73	ND (<0.25)	10	480	3,900	0.59	19	273	--	0.59	8.5	--	0.059	0.85	2/22/2017	5.4	78		
2/26 - 3/4	3/4/2017	ND (<1.0)	0.5	0.0074	2/27/2017	6.72	ND (<0.25)	8.9	530	3,400	ND (<0.50)	19	282	--	0.36	5.3	--	0.046	0.68	3/1/2017	2.7	40		
3/5 - 3/11	3/11/2017	ND (<1.0)	0.5	0.0074	3/6/2017	6.78	ND (<0.25)	7.9	490	1,800	1.6	17	253	--	1.0	1.5	--	0.11	1.6	3/8/2017	2.3	34		
3/12 - 3/18	3/18/2017	ND (<1.0)	0.5	0.0074	3/13/2017	6.75	ND (<0.25)	6.7	540	2,300	1.2	21	309	--	0.50	7.4	--	0.058	0.85	3/15/2017	1.9	28		
3/19 - 3/25	3/25/2017	ND (<1.0)	0.5	0.0074	3/20/2017	6.65	ND (<0.25)	9.5	490	4,700	ND (<0.50)	27	398	--	0.32	4.7	--	0.073	1.08	3/22/2017	1.8	27		
3/26 - 4/1	3/31/2017	ND (<1.0)	0.5	0.0071	3/27/2017	6.80	ND (<0.25)	7.1	540	2,900	1.2	27	384	--	0.26	3.7	--	0.10	1.4	3/29/2017	5.4	77		
4/2 - 4/8	4/8/2017	ND (<1.0)	0.5	0.0074	4/3/2017	6.72	ND (<0.25)	17	570	3,500	0.87	20	296	ND (<0.10)	0.05	0.74	--	0.066	0.98	4/5/2017	2.3	34		
4/9 - 4/15	4/15/2017	ND (<1.0)	0.5	0.0074	4/10/2017	6.70	ND (<0.25)	12	570	3,900	1.2	24	354	--	0.16	2.4	--	0.16	2.4	4/12/2017	1.9	28		
4/16 - 4/22	4/22/2017	ND (<1.0)	0.5	0.0078	4/17/2017	6.88	ND (<0.25)	20	530	4,000	ND (<0.50)	23	358	--	0.25	3.9	--	0.62	9.6	4/19/2017	4.1	64		
4/23 - 4/29	4/29/2017	ND (<1.0)	0.5	0.0078	4/24/2017	6.82	ND (<0.25)	11	520	2,900	1.2	21	330	--	0.31	4.9	--	0.084	1.3	4/26/2017	1.2	19		
4/30 - 5/6	5/6/2017	ND (<1.0)	0.5	0.0078	5/1/2017	6.76	ND (<0.25)	7.6	490	1,800	ND (<0.50)	19	296	--	0.11	1.7	--	0.55	8.6	5/3/2017	1.2	19		
5/7 - 5/13	5/13/2017	ND (<1.0)	0.5	0.0078	5/8/2017	6.68	ND (<0.25)	8.5	450	3,000	0.64	19	296	--	0.17	2.6	--	0.033	0.51	5/10/2017	1.5	23		
5/14 - 5/20	5/20/2017	ND (<1.0)	0.5	0.0073	5/15/2017	6.69	ND (<0.25)	9.0	540	3,000	1.0	16	234	--	0.31	4.5	--	0.081	1.18	5/17/2017	0.94	14		
5/21 - 5/27	5/27/2017	ND (<1.0)	0.5	0.0077	5/22/2017	6.93	ND (<0.25)	6.1	580	2,400	ND (<0.50)	18	278	--	0.15	2.3	--	0.074	1.14	5/24/2017	2.8	43		
5/28 - 6/3	6/3/2017	ND (<1.0)	0.5	0.0079	5/29/2017	7.00	ND (<0.25)	10	500	2,700	2.0	28	444	--	0.29	4.6	--	0.046	0.73	5/31/2017	2.0	32		
6/4 - 6/10	6/10/2017	ND (<1.0)	0.5	0.0075	6/5/2017	6.81	ND (<0.25)	5.8	540	2,200	ND (<0.50)	20	299	--	0.15	2.2	--	0.048	0.72	6/7/2017	0.68	10.2		
6/11 - 6/17	6/17/2017	ND (<1.0)	0.5	0.0063	6/12/2017	6.93	ND (<0.25)	21	560	2,200	1.9	31	389	--	0.26	3.3	--	0.056	0.70	6/14/2017	0.97	12.2		
6/18 - 6/24	6/24/2017	ND (<1.0)	0.5	0.0062	6/19/2017	6.89	ND (<0.25)	6.3	620	770	ND (<0.50)	9.0	112	--	0.22	2.7	--	0.059	0.74	6/21/2017	0.85	10.6		
6/25 - 7/1	7/1/2017	ND (<1.0)	0.5	0.0066	6/26/2017	7.10	ND (<0.25)	7.9	560	1,400	0.88	12	157	ND (<0.10)	0.05	0.66	--	0.044	0.58	6/30/2017	2.3	30		
7/2 - 7/8	7/8/2017	16**	16	0.21	7/3/2017	7.16	ND (<0.25)	2.6	520	680	1.6	9.3	125	ND (<0.10)	0.05	0.67	--	0.042	0.56	7/5/2017	2.0	25		
7/9 - 7/15	7/15/2017	15**	15	0.22	7/10/2017	6.77	ND (<0.25)	7.2	590	2,100	ND (<0.50)	21	293	--	0.20	2.8**	--	0.099	1.4	7/12/2017	1.2	18		
7/16 - 7/22	7/22/2017	8.8**	8.8	0.13	7/17/2017	6.80	ND (<0.25)	4.1	530	1,100	ND (<0.50)	11	165	--	0.13	2.0**	--	0.043	0.65	7/19/2017	1.2	21		
7/23 - 7/29	7/29/2017	ND (<1.0)	0.5	0.0077	7/24/2017	6.80	ND (<0.25)	2.9	540	710	1.5	3.2	49	--	0.59	9.0**	--	0.050	0.76	7/26/2017	1.7	27		
7/30 - 8/5	8/5/2017	ND (<1.0)	0.5	0.0066	7/31/2017	6.58	ND (<0.25)	2.6	620	670	8.1	16	238	--	7.0	104**	--	0.042	0.62	8/2/2017	1.6	24		
8/6 - 8/12	8/12/2017	ND (<1.0)	0.5	0.0074	8/7/2017	6.84	ND (<0.25)	ND (<2.5)	410	580	1.2	2.8	41	--	0.13	1.9**	--	0.032	0.47	8/9/2017	1.3	20		
8/13 - 8/19	8/19/2017	ND (<1.0)	0.5	0.0076	8/14/2017	6.64	ND (<0.25)	13	470	4,300	ND (<0.50)	52	800	--	0.12	1.8**	--	0.76	12	8/16/2017	1.8	27		
8/20 - 8/26	8/26/2017	ND (<1.0)	0.5	0.0067	8/21/2017	7.05	ND (<0.25)	14	580	5,200	0.90	62	872	ND (<0.10)</										

# Attachment B

---

*Equipment Tracking Form*

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>Main Plant Equipment</b>						
<b>1</b>		<b>Seep Wells and Lift Station 1</b>				
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running		2	New style packing was installed on the turbines.
1.03		Lift Station 1 Lift Pump B	Standby		2	New style packing was installed on the turbines.
1.04		Area in and around Lift Station 1	Running		4	New coating was installed around the additional containment.
<b>2</b>		<b>Athens Road Wells and Lift Station 3</b>				
2.01		Athens Road Well Field, 9 wells	Running		3	Corrected the wiring that controls the transducer.
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running		4	New coating was installed around the additional containment.
<b>3</b>		<b>Lift Station 2 and Transmission Pipelines</b>				
3.01		Influent Pipeline	In operation		3	Wrapped insulation on the manual flow control valve.
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby		3	New seals were installed on the swing check valve on the discharge of the discharge.
3.05		Area in and around Lift Station 2	Running		4	New coating was installed around the additional containment.
<b>4</b>		<b>Interceptor Wells and Cr Treatment Plant</b>				
4.01		IWF Well Field, 30 wells	Running			
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running		3	Switched pumps and replaced the hose.
4.04		Clarifier	In operation			
4.05		Filter Press	Running		3	A new discharge hose was installed on the press feed pump.
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Running			
4.08		Interceptor Booster Pump B	Standby			
4.09		Area In And Around GWTP	Running			
<b>5</b>		<b>Equalization Area and GW-11 Pond</b>				
5.01	PID10A	Pond GW-11	In operation			
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			
5.05	PID10A	Area in and Around EQ	In operation			
5.06	PID10A	Raw Water Feed Pump - P102A				
5.07	PID10A	Raw Water Feed Pump - P102B				

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running			
<b>6</b>		<b>First Stage FBRs A, 1 &amp; 2</b>				
6.01	PID14	FBR A				
6.02	PID14	Separator Tank - 1401				
6.03	PID14	Media Return Pump - P 1401				
6.04	PID14	P1401A				
6.05	PID01A	P1401B				
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running		4	The pump was flushed and the discharge valve was removed to clear debris that caused the clog.
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012	Running			
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running		3	The pump was replaced.
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running		3	The pump head was replaced.
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
<b>7</b>		<b>First Stage FBRs 3 &amp; 4</b>				
7.01	PID01B	FBR 3	Running		1	New airlines were installed for the flow control valves and slam valves.
7.02	PID01B	FBR 4	Running		1	New airlines were installed for the flow control valves and slam valves.
7.03	PID02B	First Stage Separator Tank - T2012	Running			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
7.04	PID01B	Media Return Pump - P2012	Running			
7.05	PID01B	First Stage FBR Pump - P1013	Running			
7.06	PID01B	First Stage FRB Pump - P1014	Running			
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723				
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
<b>8</b>		<b>Second Stage FBRs 5 &amp; 6</b>				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running		3	Replaced the pump with a rebuilt pump. The trunnions wore through.
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
<b>9</b>		<b>Second Stage FBRs 7 &amp; 8</b>				
9.01	PID03B	FBR 7	Running			
9.02	PID03B	FBR 8	Running			
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Running			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			
<b>10</b>		<b>Aeration and DAF System</b>				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Bio filter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump				
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running		2	Patched holes on the sludge tank.
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running			
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyor Drive	Standby			
10.18	PID05	Skimmer Drive	Running			
<b>11</b>		<b>Pumping System (Old Effluent)</b>				
11.01	PID06	Effluent Tank 601	In operation		2	New airlines were run and the actuator was replaced on the flow control valve.
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602	Standby			
<b>12</b>		<b>Sand Filter System</b>				
12.01	PID17	Sand Filter				
12.02	PID17	Filter Reject Tank	In operation			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
<b>13</b>		<b>Effluent Tank and Pumping</b>				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			
13.04	PID10C	Area Around Effluent and North D-1	Running			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant



Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>14</b>		<b>Solids Collection and Pressing System</b>				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation			
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902				
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			
		<b>Chemical Systems</b>				
<b>15</b>		<b>Electron Donor System</b>				
15.01	PID07B	Electron Donor Tank	In operation			
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23	PID07C	Ferric Chloride System	In operation			
24	PID07B	Polymer Systems - DAF	In operation		3	The polymer system was flushed and the check ball was replaced.
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
		<b>Utility Systems</b>				
<b>26</b>		<b>Compressed Air System</b>				
26.01	PID08	West Compressor	Running			
26.02	PID08	East Compressor	Running		1	The new air cooler was installed and the system was brought back online.
26.03	PID08	O2 Compressor	Running			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
26.04	PID08	Compressed Air Receiver Tank	In operation			
26.05	PID08	Air Dryer	Running			
26.06	PID08	Oil Removal Filter	In operation			
26.07	PID08	Particulate Filter	In operation			
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			
29		Well Control System/ Allen Bradley Controls	In operation			
30		MCC FBR Pad	In operation			
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			
<b>Miscellaneous Systems</b>						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
<b>Shelf Spares</b>						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			New pumps on order.
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			Spares are on the shelf.

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant