
To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: Ryan Sullivan, Vice President Service and O&M

Date: July 20, 2020

Subject: NERT – GWETS Operation Monthly Report – June 2020

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during June 2020.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in June 2020. Flow from PC-119, PC-120, PC-121, and PC-133 was routed to the IX system, bypassing all flow meters associated with the FBR plant. The flow rate to the IX system averaged approximately 181 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 1,019 gpm during June 2020. At the end of the month, the GW-11 Pond volume was at 34.0 million gallons (MG), which would allow 19.8 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond decreased by 2.0 MG from the end of May 2020. Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 0.29 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 98 mg/L for the month, with a maximum concentration of 100 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of May 2020 averaged 86 mg/L, with a maximum concentration of 89 mg/L. Fluctuations in the influent perchlorate concentrations are due to the changes in the AP-5 treatment feed rate and not a result of groundwater changes.

Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. These tables also include data associated with the AP-5 decant liquids. Figure 2 graphically presents historical perchlorate and chromium mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11

There were no operational issues with GW-11 in the month of June.

2. Biological Plant

Treatment of AP-5 water through the FBR Biological plant resumed in the month of May. Treatment began the month with a flow rate of 6.0 gpm and maintained that flow rate through the end of the month.

There were influent / effluent diversions during the reporting period generally associated with maintenance activities as well as extraction well short-term shutdown events. Below is a description of the events that occurred:

Diversion Events / Well Shutdowns

- Effluent diversion to GW-11 occurred on June 8, 2020 from 10:48am to 5:23pm as a precautionary measure due to concerns of effluent quality. Adjustments were made to the process and flow returned to the outfall. Approximately 425,000 gallons of effluent were diverted to GW-11.
- Well Field Shutdown of the Seep Well Field (SWF) occurred on June 10, 2020 from 11:44am to 12:17pm due to maintenance efforts on the wet well turbine pump. Maintenance was completed and the wells were brought back online.
- Effluent diversion to GW-11 occurred on June 23, 2020 from 11:36pm to 6:00am due to low GW-11 pond level. Approximately 393,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on June 26, 2020 from 11:00pm to 6:46am due to low GW-11 pond level. Approximately 477,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on June 29, 2020 from 12:28pm to 1:47pm due to maintenance efforts associated with repairs to the effluent GW-11 diversion valve. Approximately 88,000 gallons of effluent were diverted to GW-11.
- Effluent diversion to GW-11 occurred on June 30, 2020 from 9:05am to 1:39pm due to maintenance efforts associated with repairs to the effluent GW-11 diversion valve. Approximately 301,000 gallons of effluent were diverted to GW-11.

3. Spills

There were no reportable spills in the month of June.

4. Maintenance

- Major maintenance performed by ETI in the month included:
 - I. Replaced the trunnions on Media Return pump #1.
 - II. Installed the new turbine and motor at Lift Station 1 to replace the south turbine.
 - III. Rebuilt the media return pump #3 due to a damaged shaft and bearings.
 - IV. Installed a new contactor on the east press as well as a pressure switch and the temp/level switch.
 - V. Installed the rebuilt Fibroc pump on P-602.
 - VI. Replace the differential pressure transmitter on FBR 4 feed valve.
 - VII. Installed a new actuator on the effluent diversion valve at the EQ.
 - VIII. Replaced the Ferric Chloride feed pump after a motherboard error occurred.
 - IX. Patched the concrete containment at Lift Station 1.
 - X. Installed a new drawdown column on the DAF polymer feed line.

- Preventative Maintenance completed or being performed by ETI in the month included:
 - I. Completed the semi-annual maintenance on the North DAF. This included pressure washing the vessel, patching worn spots on the vessel, replacing the sludge pump, changing the sprockets on the skimmers, replacing links on the skimmer chain assembly, inspecting the screw, tightening the connections on the pressure pump, and replacing the air filter on the pressure tank.
 - II. Changed the oil on the turbine pump at Lift Station 2.
 - III. Cleaned the sight glasses on the media return pumps.
 - IV. Flushed the D-1 building west sump pit.
 - V. Cleaned the filters on the Air Conditioning units at Lift Station 3.
 - VI. Verified the floats function correctly on the Lift Station 3 wet well.
 - VII. Added oil to the east and west air compressors.
 - VIII. Flushed solids from the reject weirs on the sand filter.
 - IX. Flushed and calibrated the ORP/pH sensors.

GWETS Upgrades and Facility Projects

Unit 4 Chromium Water Treatment Plant – Envirogen received comments regarding the deliverable documents that were submitted to the Trust in July 2019 for this project. The revised documents dealing with the Controls Specification, Process Drawings, and Mechanical Details were re-submitted to the Trust in September. Envirogen is awaiting further direction from the Trust regarding this matter. The Trust has advised Envirogen that this project is on hold pending finalization and approval of the forthcoming Unit 4 Source Area In-Situ Bioremediation Work Plan.

GWETS Extension –The signed Work Authorization for engineering and fabrication of the GWETS Extension was returned to the Trust on January 28, 2020. Orders have been placed for the major equipment for the GWETS Extension. Envirogen is currently awaiting Trust comment on the O&M Work Authorization proposal for the GWETS Extension.

GWETS Staffing

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

Tables

Operational Metrics

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) ^{6 7}	Chromium (TR) (mg/L) ^{6 7}	Chromium(VI) (mg/L) ^{6 7}
SWF Total Extraction ¹	746 ⁵	7.1	0.0024	0.0026
AWF Total Extraction ¹	466 ⁵	68	0.15	0.16
IWF Total Extraction ¹	60 ⁵	450	6.5	6.1
AP Area Total Extraction ¹	11.0 ⁵	627	0.113	0.119
GWTP Effluent ²	62	440	0.21	ND
GW-11 Influent ¹	0.16	62	0.11	0.031
FBR Influent ^{2 3}	1,019	98	0.037	0.035
T-205 Effluent (AP-5 Wash Water) ^{3 4 8}	6.0	1,555	NA	NA

Notes:

TR = Total Recoverable; NA = Not Analyzed; ND = Not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

- 1: Perchlorate and chromium TR sampled monthly, values reported from TestAmerica.
- 2: Perchlorate, chromium TR, and chromium (VI) sampled weekly, values reported from TestAmerica.
- 3: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.
- 4: Flow weighted average concentration based on mass flow meter readings.
- 5: Sum of daily average flow for individual wells.
- 6: All concentrations reported are monthly flow weighted averages.
- 7: ND analytical values are treated as zero values in the flow weighted average calculations.
- 8: AP-5 sediment mixing and solids washing activities were completed on January 4, 2020. Wash water is still being transferred to T-205 to be processed

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) ³	Chromium (TR) (lbs/month) ³	Chromium (VI) (lbs/month) ³
SWF Total Extraction	1,902	0.65	0.69
AWF Total Extraction	11,359	25	27
IWF Total Extraction	9,742	141	132
AP Area Total Extraction	2,487	0.45	0.47
GWTP Effluent	9,910	4.7	ND
GW-11 Influent	3.6	0.006	0.0018
FBR Influent ¹	35,936	14	12.9
T-205 Effluent (AP-5 Wash Water) ^{1 2 4}	3,349	NA	NA

Notes:

TR = Total Recoverable; NA = Not Analyzed.

1: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.

2: AP-5 Wash Water concentrations and mass flux are estimates based on mass flow meter readings.

3: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).

4: AP-5 sediment mixing and solids washing activities were completed on January 4, 2020. Wash water is still being transferred to T-205 to be processed.

Figures

Operational Metrics

Figure 1 - GW-11 Pond Volume Through 6/30/2020





Figure 2 - Historical Perchlorate Mass Removed From Environment



Attachment A

NPDES Tracking Sheet (Prepared by Ramboll)

Treated Effluent at Outfall 001																			
Continuous		Daily Samples, composited weekly		Weekly Grab Samples										Weekly, collected separately			Quarterly		
Flow Rate		Perchlorate		pH	Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)	Total Suspended Solids (TSS)		Total Ammonia as N		Total Phosphorus as P		BOD ₅ (inhibited)			Total Dissolved Solids (TDS)
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (µg/L)	30-Day Avg. (lbs/day)	Daily Min. (S.U.)	Daily Max. (S.U.)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (mg/L)	Daily Max. (mg/L)	Daily Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	Daily Max. (mg/L)
2.52	2.88	18	0.38	6.5	9.0	10	100	5,000	10,000	20	135	2,839	20*	10*	25	40	525	8,000	
January 2020	1.82	1.89	3	0.04	6.61	6.87	1.1	19	290	540	0.85	5.0	80	6	3.3	1.3	2.1	20	
February 2020	1.85	1.91	1.3	0.019	6.68	6.91	ND (<0.25)	7.6	170	980	1.1	4.9	70	2.3	1.6	ND (<2.0)	ND (<2.0)	16	4,100
March 2020	1.86	1.91	1.3	0.019	6.55	7.11	0.36	5.4	220	1,100	ND (<0.50)	7	110	1.3	1.7	ND (<2.0)	ND (<2.0)	15	
April 2020	1.85	1.88	1.3	0.019	6.59	7.12	ND (<0.25)	6.4	160	1,300	ND (<0.50)	12	180	1.0	1.3	1.2	2.2	19	
May 2020	1.81	1.91	1.3	0.019	6.51	6.98	ND (<0.25)	6.8	150	830	11	9	130	8	2.4	ND (<2.0)	3.3	24	4,500
June 2020	1.80	1.90	1.3	0.018	6.66	7.01	ND (<0.25)	7.5	150	820	1.1	8	120	4.5	1.3	2.0	4.0	27	
July 2020 (month to date)	NA	NA	NA	NA	6.98	6.98	ND (<0.25)	5.8	87	930	1.6	12	NA	NA	NA	NA	NA	NA	NA

Daily Grab Sample Date	Composite Sample Date	µg/L	lbs/day	Sample Date	S.U.	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	Sample Date	mg/L		
12/29 - 1/4	1/4/2020	4.4	4.4	0.063	12/30/2019	6.63	ND (<0.25)	4.6	300	63	4.5	14	196	--	4.5	63	--	0.27	3.8	12/30/2019	ND (<2.0)	1.0	14		
1/5 - 1/11	1/11/2020	12	<0.079	6	0.09	1/6/2020	6.61	ND (<0.25)	2.7	290	58	0.85	4.9	70	--	0.85	12	--	0.22	3.1	1/8/2020	ND (<2.0)	1.0	15	
1/12 - 1/18	1/18/2020	ND (<2.5)	1.3	0.019	1/13/2020	6.63	ND (<0.25)	19	210	66	ND (<0.50)	3.2	49	--	0.25	3.8	ND (<0.025)	0.013	0.19	1/15/2020	ND (<2.0)	1.0	16		
1/19 - 1/25	1/25/2020	ND (<2.5)	1.3	0.019	1/20/2020	6.87	ND (<0.25)	5.8	210	140	ND (<0.50)	9.2	142	--	0.16	2.5	--	0.12	1.9	1/22/2020	2.1	32			
1/26 - 2/1	2/1/2020	ND (<2.5)	1.3	0.019	1/27/2020	6.76	1.1	ND (<2.5)	200	540	ND (<0.50)	2.7	41	--	0.35	5.4	--	0.51	7.8	1/29/2020	ND (<2.0)	1.0	15		
2/2 - 2/8	2/8/2020	ND (<2.5)	1.3	0.019	2/3/2020	6.91	ND (<0.25)	3.0	150	980	1.1	6.7	103	--	0.11	1.7	--	0.093	1.4	2/6/2020	ND (<2.0)	1.0	16	2/4/2020	
2/9 - 2/15	2/15/2020	ND (<2.5)	1.3	0.019	2/10/2020	6.68	ND (<0.25)	7.6	170	820	ND (<0.50)	6.4	97	--	0.18	2.7	--	0.095	1.4	2/12/2020	ND (<2.0)	1.0	15		
2/16 - 2/22	2/22/2020	ND (<2.5)	1.3	0.019	2/17/2020	6.87	ND (<0.25)	4.5	160	510	ND (<0.50)	3.0	46	--	0.15	2.3	--	0.12	1.8	2/19/2020	ND (<2.0)	1.0	15		
2/23 - 2/29	2/29/2020	ND (<2.5)	1.3	0.020	2/24/2020	6.81	ND (<0.25)	3.6	140	770	ND (<0.50)	3.5	54	--	0.17	2.6	--	0.11	1.7	2/26/2020	ND (<2.0)	1.0	16		
3/1 - 3/7	3/7/2020	ND (<2.5)	1.3	0.020	3/2/2020	7.01	ND (<0.25)	4.8	190	920	ND (<0.50)	5.8	91	--	0.17**	2.7	--	0.13	2.0	3/4/2020	ND (<2.0)	1.0	15		
3/8 - 3/14	3/14/2020	ND (<2.5)	1.3	0.019	3/9/2020	6.55	ND (<0.25)	4.7	220	890	ND (<0.50)	6.1	96	--	0.12**	1.9	--	0.11	1.7	3/12/2020	ND (<2.0)	1.0	15		
3/15 - 3/21	3/21/2020	ND (<2.5)	1.3	0.019	3/16/2020	7.11	ND (<0.25)	5.4	190	1,100	ND (<0.50)	11	173	ND (<0.10)	0.05**	0.79	--	0.077	1.2	3/18/2020	ND (<2.0)	1.0	16		
3/22 - 3/28	3/28/2020	ND (<2.5)	1.3	0.019	3/23/2020	6.74	ND (<0.25)	3.6	220	1,000	ND (<0.50)	6.2	97	--	0.14**	1.5	--	0.13	2.0	3/25/2020	ND (<2.0)	1.0	15		
3/29 - 4/4	4/4/2020	ND (<2.5)	1.3	0.019	3/30/2020	6.61	0.36	3.5	140	740	ND (<0.50)	5.5	86	ND (<0.10)	0.05**	0.76	--	0.082	1.3	4/1/2020	ND (<2.0)	1.0	15		
4/5 - 4/11	4/11/2020	ND (<2.5)	1.3	0.019	4/6/2020	7.12	ND (<0.25)	6.2	160	1,200	ND (<0.50)	12	187	--	0.19**	1.9	--	0.12	1.9	4/8/2020	ND (<2.0)	1.0	16		
4/12 - 4/18	4/18/2020	ND (<2.5)	1.3	0.019	4/13/2020	7.08	ND (<0.25)	6.4	110	1,300	ND (<0.50)	14	217	ND (<0.10)	0.05**	0.77	--	0.063	1.0	4/15/2020	2.2	34			
4/19 - 4/25	4/25/2020	ND (<2.5)	1.3	0.020	4/20/2020	6.93	ND (<0.25)	5.6	150	1,200	ND (<0.50)	13	203	ND (<0.10)	0.05**	0.78	--	0.084	1.3	4/22/2020	ND (<2.0)	1.0	16		
4/26 - 5/2	5/2/2020	ND (<2.5)	1.3	0.019	4/27/2020	6.59	ND (<0.25)	3.3	130	860	ND (<0.50)	8.4	129	ND (<0.10)	0.05**	0.77	--	0.074	1.1	4/29/2020	ND (<2.0)	1.0	15		
5/3 - 5/9	5/9/2020	ND (<2.5)	1.3	0.019	5/4/2020	6.98	ND (<0.25)	4.0	130	440	ND (<0.50)	5.1	81	--	0.15**	8.5	--	0.083	1.3	5/6/2020	ND (<2.0)	1.0	16	5/7/2020	
5/10 - 5/16	5/16/2020	ND (<2.5)	1.3	0.020	5/11/2020	6.51	ND (<0.25)	6.8	150	690	ND (<0.50)	9.4	146	--	0.14	2.2	--	0.12	1.9	5/13/2020	ND (<2.0)	1.0	16		
5/17 - 5/23	5/23/2020	ND (<2.5)	1.3	0.019	5/18/2020	6.98	ND (<0.25)	4.6	140	600	1.9	6.1	94	--	1.9	29	--	0.20	3.1	5/20/2020	ND (<2.0)	1.0	15		
5/24 - 5/30	5/30/2020	ND (<2.5)	1.3	0.017	5/26/2020	6.98	ND (<0.25)	6.6	120	830	11	14	208	--	0.51	7.8	--	0.22	3.3	5/27/2020	3.3	50			
5/31 - 6/6	6/6/2020	ND (<2.5)	1.3	0.018	6/1/2020	6.80	ND (<0.25)	7.5	110	740	0.58	11	162	--	0.58	8.5	--	0.12	1.8	6/3/2020	2.1	32			
6/7 - 6/13	6/13/2020	ND (<2.5)	1.3	0.018	6/9/2020	6.66	ND (<0.25)	3.8	110	410	ND (<0.50)	4.6	69	--	0.18	2.7	--	0.073	1.1	6/10/2020	ND (<2.0)	1.0	15		
6/14 - 6/20	6/20/2020	ND (<2.5)	1.3	0.019	6/15/2020	6.87	ND (<0.25)	5.3	150	820	1.1	7.8	117	--	0.16	2.4	--	0.013	0.19	6/17/2020	ND (<2.0)	1.0	15		
6/21 - 6/27	6/27/2020	ND (<2.5)	1.3	0.017	6/22/2020	6.92	ND (<0.25)	5.9	99	710	ND (<0.50)	8.4	125	--	0.26	3.9	--	0.12	1.8	6/24/2020	4.0	44			
6/28 - 7/4	7/4/2020	NA	NA	NA	7/1/2020	7.01	ND (<0.25)	5.9	99	710	ND (<0.50)	9.9	145	--	0.33	4.8	--	0.12	1.8	7/1/2020	ND (<2.0)	1.0	NA		
					7/6/2020	6.98	ND (<0.25)	5.8	87	930	1.6	12	NA	--	1.6	NA	--	0.25	NA	7/8/2020	NA	NA	NA		

Note: All analytical responsibilities are performed by TestAmerica Laboratories, Inc. (TestAmerica) in Irvine, California, unless otherwise indicated.
** Additional samples were collected and analyzed for ammonia during this week and results were included in the 30-day average loading calculation.

NA = Not Available To Date
ND = Not Detected above laboratory reporting limit; concentration in adjacent cell to right is one-half the reporting limit (per Permit condition)
J = Result is less than the reporting limit but greater than or equal to the method detection limit and the concentration is an approximate value.
-- = Analyte detected; see column adjacent to right
* Total phosphorus discharge limitation of 10 lbs/day applies between March 1 and October 31; Ammonia discharge limitation of 20 lbs/day applies between April 1 and September 30; no limits apply the rest of the year.
Last Updated: July 10, 2020

Attachment B

Equipment Tracking Form

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
Main Plant Equipment						
1 Seep Wells and Lift Station 1						
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running			
1.03		Lift Station 1 Lift Pump B	Standby		2	Installed a new turbine and motor to replace the south turbine. It is all the same configuration with updated parts. Patched the damaged concrete containment.
1.04		Area in and around Lift Station 1	Running			
2 Athens Road Wells and Lift Station 3						
2.01		Athens Road Well Field, 9 wells	Running			
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running			
3 Lift Station 2 and Transmission Pipelines						
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running		3	Oil change on the turbine
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running			
4 Interceptor Wells and Cr Treatment Plant						
4.01		IWF Well Field, 30 wells	Running			
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation			
4.05		Filter Press	Running		2	The hydraulic system has issues closing the press. A temporary manual hydraulic ram is in place until repairs can be made.
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Running			
4.08		Interceptor Booster Pump B	Standby			
4.09		Area In And Around GWTP	Running			
5 Equalization Area and GW-11 Pond						
5.01	PID10A	Pond GW-11	In operation			
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
5.05	PID10A	Area in and Around EQ	In operation		2	Replaced the actuator for the seep diversion valve.
5.06	PID10A	Raw Water Feed Pump - P102A				
5.07	PID10A	Raw Water Feed Pump - P102B				
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running		4	The gearbox actuator for the SLW flush valve was damaged. A different handle was installed until the new valve is installed.
6		First Stage FBRs A, 1 & 2				
6.01	PID14	FBR A				
6.02	PID14	Separator Tank - 1401				
6.03	PID14	Media Return Pump - P 1401				
6.04	PID14	P1401A				
6.05	PID01A	P1401B				
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running		3	Replaced the pump for blown trunnions. The 1hp motor was replaced.
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012			3	A new pressure sensor tube was replaced.
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
7		First Stage FBRs 3 & 4				
7.01	PID01B	FBR 3	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
7.02	PID01B	FBR 4	Running			
7.03	PID02B	First Stage Separator Tank - T2012	Running			
7.04	PID01B	Media Return Pump - P2012	Running			
7.05	PID01B	First Stage FBR Pump - P1013	Running		2	The suction spool pipe was replaced on the recycle pump.
7.06	PID01B	First Stage FRB Pump - P1014	Running			
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723				
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
8		Second Stage FBRs 5 & 6				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running		4	Replaced the belt.
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
9		Second Stage FBRs 7 & 8				
9.01	PID03B	FBR 7	Running			
9.02	PID03B	FBR 8	Running			
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running		4	Replaced the belt.
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2= Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			
10		Aeration and DAF System				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Bio filter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump				
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation		2	The air filter was changed on the N. tank during the Preventative Maintenance.
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running		2	The vessel was taken offline for semi-annual maintenance. The sprockets were replaced, new coating was applied in worn spots of the vessel, pressure washed.
10.15	PID05	DAF Pressure Pump - P551	Running			
10.16	PID05	DAF Float Pump - P552	Running		2	The pump was replaced during the PM.
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running		2	Two repairs were made to the skimmers.
11		Pumping System (Old Effluent)				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602	Standby		2	Replaced the pump with the old Fybroc pump.
12		Sand Filter System				
12.01	PID17	Sand Filter				
12.02	PID17	Filter Reject Tank	In operation			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
13		Effluent Tank and Pumping				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			
13.04	PID10C	Area Around Effluent and North D-1	Running			
14		Solids Collection and Pressing System				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation		3	The suction pipe was removed and cleared of debris.
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902				
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running		2	The pressure switch was adjusted along with the temp/level switch in the tank.
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			
		Chemical Systems				
15		Electron Donor System				
15.01	PID07B	Electron Donor Tank	In operation		2	The dampening of the flow meter was reset after a fault appeared on the transmitter.
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23	PID07C	Ferric Chloride	In operation			
24	PID07B	Polymer Systems - DAF	In operation		3	The pump was cleared of debris from the piping and a new fitting was installed on the suction from the tote.

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
25	PID09	<i>Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)</i>	In operation			
Utility Systems						
26		Compressed Air System				
26.01	PID08	<i>West Compressor</i>	Running			
26.02	PID08	<i>East Compressor</i>	Running			
26.03	PID08	<i>O2 Compressor</i>	Running			
26.04	PID08	<i>Compressed Air Receiver Tank</i>	In operation			
26.05	PID08	<i>Air Dryer</i>	Running			
26.06	PID08	<i>Oil Removal Filter</i>	In operation			
26.07	PID08	<i>Particulate Filter</i>	In operation			
27	PID16	<i>Oxygen System</i>	In operation			
28		<i>GWETS Plant Controls/ Siemens Controls</i>	In operation			
29		<i>Well Control System/ Allen Bradley Controls</i>	In operation			
30		<i>MCC FBR Pad</i>	In operation			
31		<i>MCC in D-1</i>	In operation			
32		<i>MCC in EQ area</i>	In operation			
Miscellaneous Systems						
33		<i>Operations Office/Network</i>	In operation			
34		<i>Laboratory Analyzers</i>	In operation			
35		<i>Security Systems</i>	In operation			
Shelf Spares						
		<i>Media Return Pump Rebuild Kit</i>	In stock			
		<i>pH Feed Pump</i>	In stock			
		<i>Nutrient Feed Pump</i>	In stock			
		<i>Electron Donor Feed Pump</i>	In stock			
		<i>Phosphoric Acid Feed Pump</i>	In stock			
		<i>Interceptor Well Pumps (4 each)</i>	In stock			
		<i>Seep Well Pump (1 each, same as Athens so total of 2)</i>	In stock			
		<i>Athens Road Well Pump (1 each, same as Seep so total of 2)</i>	In stock			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2= Important - Can still operate safely and in compliance with permits, but risks are increased
 3= Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4= Low - Minor repairs that in no way alter the performance of the plant