
To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: Ryan Sullivan, Vice President Service and O&M

Date: August 20, 2020

Subject: NERT – GWETS Operation Monthly Report – July 2020

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during July 2020.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in July 2020. Flow from PC-119, PC-120, PC-121, and PC-133 was routed to the IX system, bypassing all flow meters associated with the FBR plant. The flow rate to the IX system averaged approximately 181 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 1,035 gpm during July 2020. At the end of the month, the GW-11 Pond volume was at 34.8 million gallons (MG), which would allow 19.2 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond increased by 0.8 MG from the end of June 2020. Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 0.26 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 66 mg/L for the month, with a maximum concentration of 95 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of June 2020 averaged 98 mg/L, with a maximum concentration of 100 mg/L. Fluctuations in the influent perchlorate concentrations are due to the changes in the AP-5 treatment feed rate and not a result of groundwater changes.

Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. These tables also include data associated with the AP-5 decant liquids. Figure 2 graphically presents historical perchlorate and chromium mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11

There were no operational issues with GW-11 in the month of July.

2. Biological Plant

Treatment of AP-5 water through the FBR Biological plant was completed in the month of July. Treatment began the month with a flow rate of 6.0 gpm and maintained that flow rate until flows were terminated on July 14, 2020 at 9:15am.

There were influent / effluent diversions during the reporting period generally associated with GW-11 pond level maintenance as well as extraction well short-term shutdown events. Below is a description of the events that occurred:

Diversion Events / Well Shutdowns

- Effluent diversion to GW-11 occurred on July 2, 2020 from 12:56am to 5:25am due to low GW-11 pond level. Approximately 283,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 2, 2020 from 11:39pm to July 3, 2020 at 5:40am due to low GW-11 pond level. Approximately 340,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 7, 2020 from 11:32pm to July 8, 2020 at 5:30am due to low GW-11 pond level. Approximately 393,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 9, 2020 from 11:31pm to July 10, 2020 at 5:20am due to low GW-11 pond level. Approximately 408,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 10, 2020 from 5:57pm to 12:47pm due to maintenance efforts associated with repairs to the Sand Filter. Approximately 403,000 gallons of effluent were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 13, 2020 from 11:30pm to July 14, 2020 at 5:08am due to low GW-11 pond level. Approximately 395,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 15, 2020 from 11:30pm to July 16, 2020 at 5:30am due to low GW-11 pond level. Approximately 394,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 17, 2020 from 1:39pm to July 18, 2020 at 5:30am due to low GW-11 pond level. Approximately 270,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 19, 2020 from 2:26am to 8:33am due to low GW-11 pond level. Approximately 403,000 gallons of water were diverted to GW-11.
- Well Field Shutdown of the Interceptor Well Field (IWF) occurred on July 20, 2020 from 10:18am to 11:25am due to maintenance activities on the effluent flow meter.
- Effluent diversion to GW-11 occurred on July 20, 2020 from 11:48pm to July 21, 2020 at 5:20am due to low GW-11 pond level. Approximately 365,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 21, 2020 from 10:30pm to July 22, 2020 at 5:15am due to low GW-11 pond level. Approximately 384,000 gallons of water were diverted to GW-11.

- Effluent diversion to GW-11 occurred on July 22, 2020 from 10:01pm to July 23, 2020 at 5:18am due to low GW-11 pond level. Approximately 481,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 19, 2020 from 2:26am to 8:33am due to low GW-11 pond level. Approximately 403,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 23, 2020 from 10:26am to 1:35pm due to maintenance efforts associated with repairs to the effluent GW-11 diversion valve. Approximately 207,000 gallons of effluent were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 25, 2020 from 1:38am to 4:14am due to low GW-11 pond level. Approximately 170,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 26, 2020 from 4:08am to 6:19am due to low GW-11 pond level. Approximately 140,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 27, 2020 from 11:23pm to July 28, 2020 at 5:23am due to low GW-11 pond level. Approximately 305,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 31, 2020 from 12:57am to 6:00am due to low GW-11 pond level. Approximately 329,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on July 31, 2020 from 11:49pm to Aug 1, 2020 at 4:53am due to low GW-11 pond level. Approximately 345,000 gallons of water were diverted to GW-11.

3. Spills

There were no reportable spills in the month of July.

4. Maintenance

- Major maintenance performed by ETI in the month included:
 - I. Installed the rebuilt hydraulic cylinder on the GWTP filter press.
 - II. Rebuilt the media return pump for Separator 3.
 - III. Installed the new check valve and spool on the discharge piping of FBR 8 recycle pump.
 - IV. Installed a rebuilt motor on the north turbine at Lift Station 1.
 - V. Installed a new controller and contactor on the west air compressor.
 - VI. Replaced the 3 hp motor on extraction well ART-7b.
 - VII. Installed a new pump on the DAF polymer feed system.
 - VIII. Relocated the DAF turbidity meter and installed a metering pump.
- Preventative Maintenance completed or being performed by ETI in the month included:
 - I. Changed the oil on the Lift Station 2 motor.
 - II. Greased the bearings on the exhaust fans in the D-1 building.
 - III. Flushed the seal water roto-meters on the FBR Recycle pump skids.
 - IV. Cleaned and flushed the combo valves on the effluent pipeline.
 - V. Flushed the ORP lines and pH probes.
 - VI. Changed the packing on the turbine pumps at Lift Station 1.
 - VII. Pulled and inspected the Lift Station 1 flowmeter. A new unit has been ordered.
 - VIII. Added oil and inspected the belt on the east air compressor.

GWETS Upgrades and Facility Projects

Unit 4 Chromium Water Treatment Plant – Envirogen received comments regarding the deliverable documents that were submitted to the Trust in July 2019 for this project. The revised documents dealing with the Controls Specification, Process Drawings, and Mechanical Details were re-submitted to the Trust in September. Envirogen is awaiting further direction from the Trust regarding this matter. The Trust has advised Envirogen that this project is on hold pending finalization and approval of the forthcoming Unit 4 Source Area In-Situ Bioremediation Work Plan.

GWETS Extension –The signed Work Authorization for engineering and fabrication of the GWETS Extension was returned to the Trust on January 28, 2020. Orders have been placed for the major equipment for the GWETS Extension with deliveries expected during the third and fourth quarters of 2020. Envirogen is currently awaiting Trust comment on the O&M Work Authorization proposal for the GWETS Extension.

GWETS Staffing

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

Tables

Operational Metrics

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) ^{6 7}	Chromium (TR) (mg/L) ^{6 7}	Chromium(VI) (mg/L) ^{6 7}
SWF Total Extraction ¹	746 ⁵	7.1	0.0035	0.0029
AWF Total Extraction ¹	465 ⁵	65	0.15	0.15
IWF Total Extraction ¹	61 ⁵	437	6.4	6.5
AP Area Total Extraction ¹	10.4 ⁵	578	0.128	0.124
GWTP Effluent ²	62	449	1.6	ND
GW-11 Influent ¹	0.10	50	0.07	0.051
FBR Influent ^{2 3}	1,035	66	0.030	0.029
T-205 Effluent (AP-5 Wash Water) ^{3 4 8}	1.1	1,920	NA	NA

Notes:

TR = Total Recoverable; NA = Not Analyzed; ND = Not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

- 1: Perchlorate and chromium TR sampled monthly, values reported from TestAmerica.
- 2: Perchlorate, chromium TR, and chromium (VI) sampled weekly, values reported from TestAmerica.
- 3: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.
- 4: Flow weighted average concentration based on mass flow meter readings.
- 5: Sum of daily average flow for individual wells.
- 6: All concentrations reported are monthly flow weighted averages.
- 7: ND analytical values are treated as zero values in the flow weighted average calculations.
- 8: AP-5 sediment mixing and solids washing activities were completed on January 4, 2020. AP-5 tank processing was completed on 7/15/20.

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) ³	Chromium (TR) (lbs/month) ³	Chromium (VI) (lbs/month) ³
SWF Total Extraction	1,972	0.99	0.81
AWF Total Extraction	11,258	26	27
IWF Total Extraction	9,873	145	146
AP Area Total Extraction	2,242	0.50	0.48
GWTP Effluent	10,423	37	ND
GW-11 Influent	1.8	0.002	0.0018
FBR Influent ¹	25,410	11	11.3
T-205 Effluent (AP-5 Wash Water) ^{1 2 4}	755	NA	NA

Notes:

TR = Total Recoverable; NA = Not Analyzed.

1: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.

2: AP-5 Wash Water concentrations and mass flux are estimates based on mass flow meter readings.

3: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).

4: AP-5 sediment mixing and solids washing activities were completed on January 4, 2020. AP-5 tank processing was completed on 7/15/20.

Figures

Operational Metrics

Figure 1 - GW-11 Pond Volume Through 7/31/2020





Figure 2 - Historical Perchlorate Mass Removed From Environment



Attachment A

NPDES Tracking Sheet (Prepared by Ramboll)

Treated Effluent at Outfall 001																			
Continuous		Daily Samples, composited weekly		Weekly Grab Samples								Weekly, collected separately			Quarterly				
Flow Rate		Perchlorate		pH	Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)	Total Suspended Solids (TSS)	Total Ammonia as N	Total Phosphorus as P	BOD ₅ (inhibited)			Total Dissolved Solids (TDS)			
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (µg/L)	30-Day Avg. (lbs/day)	Daily Min. (S.U.)	Daily Max. (S.U.)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (mg/L)	Daily Average (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	Daily Max. (mg/L)			
2.52	2.88	18	0.38	6.5	9.0	10	100	5,000	10,000	20	135	2,839	20*	10*	25	40	525	8,000	
January 2020	1.82	1.89	3	0.04	6.61	6.87	1.1	19	290	540	0.85	5.0	80	6	3.3	1.3	2.1	20	
February 2020	1.85	1.91	<2.5	0.019	6.68	6.91	ND (<0.25)	7.6	170	980	1.1	4.9	70	2.3	1.6	ND (<2.0)	ND (<2.0)	16	4,100
March 2020	1.86	1.91	<2.5	0.019	6.55	7.11	0.36	5.4	220	1,100	ND (<0.50)	7	110	1.3	1.7	ND (<2.0)	ND (<2.0)	15	
April 2020	1.85	1.88	<2.5	0.019	6.59	7.12	ND (<0.25)	6.4	160	1,300	ND (<0.50)	12	180	1.0	1.3	1.6	2.6	24	
May 2020	1.81	1.91	<2.5	0.019	6.51	6.98	ND (<0.25)	7.4	160	830	11	9	130	10	2.4	1.6	3.3	24	4,500
June 2020	1.73	1.88	<2.5	0.018	6.66	7.01	ND (<0.25)	7.5	160	820	1.1	8	120	4.5	1.3	2.0	4.0	27	
July 2020	1.61	1.87	<2.5	0.017	6.49	7.12	ND (<0.25)	5.8	150	930	1.6	7	80	8	2.0	2.1	3.8	32	
August 2020 (month to date)	1.60	1.87	ND (<2.5)	0.017	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Daily Grab Sample Dates	Composite Sample Date	µg/L	lbs/day	Sample Date	S.U.	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	Sample Date	mg/L		
12/29 - 1/4	1/4/2020	4.4	0.063	12/30/2019	6.63	ND (<0.25)	4.6	300	63	4.5	14	196	--	4.5	63	--	0.27	3.8	12/30/2019	ND (<2.0)	1.0	14			
1/5 - 1/11	1/11/2020	12	0.09	1/6/2020	6.61	ND (<0.25)	2.7	290	58	0.85	4.9	70	--	0.85	12	--	0.22	3.1	1/8/2020	ND (<2.0)	1.0	15			
1/12 - 1/18	1/18/2020	ND (<2.5)	1.3	1/13/2020	6.63	ND (<0.25)	19	210	66	ND (<0.50)	3.2	49	--	0.25	3.8	ND (<0.025)	0.013	0.19	1/15/2020	ND (<2.0)	1.0	16			
1/19 - 1/25	1/25/2020	ND (<2.5)	1.3	1/20/2020	6.87	ND (<0.25)	5.8	210	140	ND (<0.50)	9.2	142	--	0.16	2.5	--	0.12	1.9	1/22/2020	2.1	32				
1/26 - 2/1	2/1/2020	ND (<2.5)	1.3	1/27/2020	6.76	1.1	ND (<2.5)	200	540	ND (<0.50)	2.7	41	--	0.35	5.4	--	0.51	7.8	1/29/2020	ND (<2.0)	1.0	15			
2/2 - 2/8	2/8/2020	ND (<2.5)	1.3	2/3/2020	6.91	ND (<0.25)	3.3*	3.0	150	980	1.1	6.7	103	--	0.11	1.7	--	0.093	1.4	2/6/2020	ND (<2.0)	1.0	16	2/4/2020	4,100
2/9 - 2/15	2/15/2020	ND (<2.5)	1.3	2/10/2020	6.68	ND (<0.25)	7.6	170	820	ND (<0.50)	6.4	97	--	0.18	2.7	--	0.095	1.4	2/12/2020	ND (<2.0)	1.0	15			
2/16 - 2/22	2/22/2020	ND (<2.5)	1.3	2/17/2020	6.87	ND (<0.25)	4.5	160	510	ND (<0.50)	3.0	46	--	0.15	2.3	--	0.12	1.8	2/19/2020	ND (<2.0)	1.0	15			
2/23 - 2/29	2/29/2020	ND (<2.5)	1.3	2/24/2020	6.81	ND (<0.25)	3.6	140	770	ND (<0.50)	3.5	54	--	0.17	2.6	--	0.11	1.7	2/26/2020	ND (<2.0)	1.0	16			
3/1 - 3/7	3/7/2020	ND (<2.5)	1.3	3/2/2020	7.01	ND (<0.25)	4.8	190	920	ND (<0.50)	5.8	91	--	0.17**	2.7	--	0.13	2.0	3/4/2020	ND (<2.0)	1.0	15			
3/8 - 3/14	3/14/2020	ND (<2.5)	1.3	3/9/2020	6.55	ND (<0.25)	4.7	220	890	ND (<0.50)	6.1	96	--	0.12**	1.9	--	0.11	1.7	3/12/2020	ND (<2.0)	1.0	15			
3/15 - 3/21	3/21/2020	ND (<2.5)	1.3	3/16/2020	7.11	ND (<0.25)	5.4	190	1,100	ND (<0.50)	11	173	ND (<0.10)	0.05**	0.79	--	0.077	1.2	3/18/2020	ND (<2.0)	1.0	16			
3/22 - 3/28	3/28/2020	ND (<2.5)	1.3	3/23/2020	6.74	ND (<0.25)	3.6	220	1,000	ND (<0.50)	6.2	97	--	0.14**	1.5	--	0.13	2.0	3/25/2020	ND (<2.0)	1.0	15			
3/29 - 4/4	4/4/2020	ND (<2.5)	1.3	3/30/2020	6.61	0.36	3.5	140	740	ND (<0.50)	5.5	86	ND (<0.10)	0.05**	0.76	--	0.082	1.3	4/1/2020	ND (<2.0)	1.0	15			
4/5 - 4/11	4/11/2020	ND (<2.5)	1.3	4/6/2020	7.12	ND (<0.25)	6.2	160	1,200	ND (<0.50)	12	187	--	0.19**	1.9	--	0.12	1.9	4/8/2020	2.6	41				
4/12 - 4/18	4/18/2020	ND (<2.5)	1.3	4/13/2020	7.08	ND (<0.25)	6.4	110	1,300	ND (<0.50)	14	217	ND (<0.10)	0.05**	0.77	--	0.063	1.0	4/15/2020	2.2	34				
4/19 - 4/25	4/25/2020	ND (<2.5)	1.3	4/20/2020	6.93	ND (<0.25)	5.6	150	1,200	ND (<0.50)	13	203	ND (<0.10)	0.05**	0.78	--	0.084	1.3	4/22/2020	ND (<2.0)	1.0	16			
4/26 - 5/2	5/2/2020	ND (<2.5)	1.3	4/27/2020	6.59	ND (<0.25)	3.3	130	860	ND (<0.50)	8.4	129	ND (<0.10)	0.05**	0.77	--	0.074	1.1	4/29/2020	ND (<2.0)	1.0	15			
5/3 - 5/9	5/9/2020	ND (<2.5)	1.3	5/4/2020	6.98	ND (<0.25)	7.4*	4.0	160	440	ND (<0.50)	5.1	81	--	0.15**	10.1	--	0.083	1.3	5/6/2020	ND (<2.0)	1.0	16	5/7/2020	4,500
5/10 - 5/16	5/16/2020	ND (<2.5)	1.3	5/11/2020	6.51	ND (<0.25)	6.8	150	690	ND (<0.50)	9.4	146	--	0.14	2.2	--	0.12	1.9	5/13/2020	ND (<2.0)	1.0	16			
5/17 - 5/23	5/23/2020	ND (<2.5)	1.3	5/18/2020	6.98	ND (<0.25)	4.6	140	600	1.9	6.1	94	--	1.9	29	--	0.20	3.1	5/20/2020	ND (<2.0)	1.0	15			
5/24 - 5/30	5/30/2020	ND (<2.5)	1.3	5/26/2020	6.98	ND (<0.25)	6.6	120	830	1.1	14	208	--	0.51	7.6	--	0.22	3.3	5/27/2020	3.3	50				
5/31 - 6/6	6/6/2020	ND (<2.5)	1.3	6/1/2020	6.80	ND (<0.25)	7.5	110	740	0.58	11	162	--	0.58	8.5	--	0.12	1.8	6/3/2020	2.1	32				
6/7 - 6/13	6/13/2020	ND (<2.5)	1.3	6/9/2020	6.66	ND (<0.25)	3.8	110	410	ND (<0.50)	4.6	69	--	0.18	2.7	--	0.073	1.1	6/10/2020	ND (<2.0)	1.0	15			
6/14 - 6/20	6/20/2020	ND (<2.5)	1.3	6/15/2020	6.87	ND (<0.25)	5.3	150	820	1.1	7.8	117	--	0.16	2.4	--	0.013	0.19	6/17/2020	ND (<2.0)	1.0	15			
6/21 - 6/27	6/27/2020	ND (<2.5)	1.3	6/22/2020	6.92	ND (<0.25)	7.3	160	780	ND (<0.50)	8.4	125	--	0.26	3.9	--	0.12	1.8	6/24/2020	4.0	44				
6/28 - 7/4	7/4/2020	ND (<2.5)	1.3	6/29/2020	7.01	ND (<0.25)	5.9	99	710	ND (<0.50)	9.9	145	--	0.33	4.8	--	0.12	1.8	7/1/2020	ND (<2.0)	1.0	15			
7/5 - 7/11	7/11/2020	ND (<2.5)	1.3	7/6/2020	6.98	ND (<0.25)	5.8	87	930	1.6	12	146	--	1.6	20	--	0.25	3.1	7/8/2020	ND (<2.0)	1.0	15			
7/12 - 7/18	7/18/2020	ND (<2.5)	1.3	7/13/2020	6.49	ND (<0.25)	4.1	120	680	ND (<0.50)	7.2	84	--	0.30	3.5	--	0.089	1.04	7/15/2020	2.5	38				
7/19 - 7/25	7/25/2020	ND (<2.5)	1.3	7/20/2020	7.10	ND (<0.25)	4.7	110	470	0.51	3.9	60	--	0.51	7.8	--	0.096	1.5	7/22/2020	3.8	59				
7/26 - 8/1	8/1/2020	ND (<2.5)	1.3	7/27/2020	7.12	ND (<0.25)	ND (<2.5)	150	510	ND (<0.50)	3.2	48	--	0.16	2.4	--	0.150	2.2	7/29/2020	NA	NA				
				8/3/2020	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	8/5/2020	NA	NA				

Note: All analytical responsibilities are performed by TestAmerica Laboratories, Inc. (TestAmerica) in Irvine, California, unless otherwise indicated.

* Additional Quarterly sample collected this week.

** Additional samples were collected and analyzed for ammonia during this week and results were included in the 30-day average loading calculation.

NA = Not Available To Date

ND = Not Detected above laboratory reporting limit; concentration in adjacent cell to right is one-half the reporting limit (per Permit condition)

J = Result is less than the reporting limit but greater than or equal to the method detection limit and the concentration is an approximate value.

-- = Analyte detected; see column adjacent to right

* Total phosphorus discharge limitation of 10 lbs/day applies between March 1 and October 31; Ammonia discharge limitation of 20 lbs/day applies between April 1 and September 30; no limits apply the rest of the year.

Last Updated: August 7, 2020

Attachment B

Equipment Tracking Form

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
Main Plant Equipment						
1 Seep Wells and Lift Station 1						
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running		2	Replace the 50 hp motor on the turbine and sent the old motor to be rebuilt.
1.03		Lift Station 1 Lift Pump B	Standby			
1.04		Area in and around Lift Station 1	Running			
2 Athens Road Wells and Lift Station 3						
2.01		Athens Road Well Field, 9 wells	Running		3	Pulled and replaced the 3hp motor on ART-7b.
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running			
3 Lift Station 2 and Transmission Pipelines						
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running		4	Changed the oil on the motor.
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running			
4 Interceptor Wells and Cr Treatment Plant						
4.01		IWF Well Field, 30 wells	Running		3	Pulled and inspected the piping on I-AD. No faults were found. A new bracket was installed on the discharge piping.
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation			
4.05		Filter Press	Running		2	The hydraulic cylinder was rebuilt and a new pump and filter were also installed. The seals were replaced and the airlines. The press is in good working order.
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Running		2	The flex coupling was replaced.
4.08		Interceptor Booster Pump B	Standby			
4.09		Area In And Around GWTP	Running			
5 Equalization Area and GW-11 Pond						
5.01	PID10A	Pond GW-11	In operation			
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
5.05	PID10A	Area in and Around EQ	In operation		2	The actuator for the outfall diversion valve had a failed closed position limit switch. A new actuator was ordered.
5.06	PID10A	Raw Water Feed Pump - P102A				
5.07	PID10A	Raw Water Feed Pump - P102B				
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running		4	The gearbox actuator for the SLW flush valve was damaged. A different handle was installed until the new valve is installed.
6		First Stage FBRs A, 1 & 2				
6.01	PID14	FBR A				
6.02	PID14	Separator Tank - 1401				
6.03	PID14	Media Return Pump - P 1401				
6.04	PID14	P1401A				
6.05	PID01A	P1401B				
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby		4	The seal water line was replaced.
6.11	PID01A	First Stage FBR Pump - P1012				
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
7		First Stage FBRs 3 & 4				
7.01	PID01B	FBR 3	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
7.02	PID01B	FBR 4	Running			
7.03	PID02B	First Stage Separator Tank - T2012	Running			
7.04	PID01B	Media Return Pump - P2012	Running			
7.05	PID01B	First Stage FBR Pump - P1013	Running			
7.06	PID01B	First Stage FRB Pump - P1014	Running			
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723				
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
8		Second Stage FBRs 5 & 6				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running			
8.05	PID03A	Second Stage FBR Pump - P3015	Running		4	Replaced the fittings and tubing on the seal water.
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
9		Second Stage FBRs 7 & 8				
9.01	PID03B	FBR 7	Running			
9.02	PID03B	FBR 8	Running			
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running		2	Installed the new swing check valve and the spool piece for the discharge of the pump.

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2= Important - Can still operate safely and in compliance with permits, but risks are increased
 3= Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4= Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
9.07	PID03B	Second Stage FBR Pump - P302A	Running			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			
10		Aeration and DAF System				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Bio filter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump				
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running			
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			
11		Pumping System (Old Effluent)				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602	Standby			
12		Sand Filter System				
12.01	PID17	Sand Filter			2	The sand filter was flushed with SLW.
12.02	PID17	Filter Reject Tank	In operation			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
13		Effluent Tank and Pumping				
13.01	PID10C	UV Effluent Tank	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2= Important - Can still operate safely and in compliance with permits, but risks are increased
 3= Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4= Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			
13.04	PID10C	Area Around Effluent and North D-1	Running			
14		Solids Collection and Pressing System				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation		3	A new SLW valve was installed to flush the tank and pumps.
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902				
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			
		Chemical Systems				
15		Electron Donor System				
15.01	PID07B	Electron Donor Tank	In operation			
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation		2	A new hose connecting the tote to the pump piping was replaced.
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23	PID07C	Ferric Chloride	In operation			
24	PID07B	Polymer Systems - DAF	In operation		3	The east pump was replaced.
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
		Utility Systems				
26		Compressed Air System				

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
26.01	PID08	West Compressor	Running		2	The contactor was replaced along with the controller. The unit still fails with a "motor rotation" fault. The unit is offline.
26.02	PID08	East Compressor	Running		2	The contactor was replaced. The unit is in good working order.
26.03	PID08	O2 Compressor	Running			
26.04	PID08	Compressed Air Receiver Tank	In operation			
26.05	PID08	Air Dryer	Running			
26.06	PID08	Oil Removal Filter	In operation			
26.07	PID08	Particulate Filter	In operation			
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			
29		Well Control System/ Allen Bradley Controls	In operation			
30		MCC FBR Pad	In operation			
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			
Miscellaneous Systems						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
Shelf Spares						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2= Important - Can still operate safely and in compliance with permits, but risks are increased
 3= Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4= Low - Minor repairs that in no way alter the performance of the plant