
To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: Ryan Sullivan, Vice President Service and O&M

Date: November 20, 2020

Subject: NERT – GWETS Operation Monthly Report – October 2020

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during October 2020.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in October 2020. Flow from PC-119, PC-120, PC-121, and PC-133 was routed to the IX system, bypassing all flow meters associated with the FBR plant. The flow rate to the IX system averaged approximately 182 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 1,029 gpm during October 2020. At the end of the month, the GW-11 Pond volume was at 34.8 million gallons (MG), which would allow 19.2 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond increased by 0.4 MG from the end of September 2020. Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 0.29 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 64 mg/L for the month, with a maximum concentration of 77 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of September 2020 averaged 59 mg/L, with a maximum concentration of 63 mg/L.

Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 graphically presents historical perchlorate and chromium mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate

Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11

There were no operational issues with GW-11 in the month of October.

2. Biological Plant

There were influent / effluent diversions during the reporting period generally associated with GW-11 pond level maintenance as well as extraction well short-term shutdown events. Below is a description of the events that occurred:

Diversion Events / Well Shutdowns

- Effluent diversion to GW-11 occurred on October 4, 2020 from 11:30pm to October 5, 2020 5:04am due to low GW-11 pond level. Approximately 365,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on October 9, 2020 from 11:49pm to October 10, 2020 4:34am due to low GW-11 pond level. Approximately 305,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on October 13, 2020 from 10:46pm to October 14, 2020 2:45am due to low GW-11 pond level. Approximately 250,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on October 16, 2020 from 9:38pm to October 17, 2020 2:55am due to low GW-11 pond level. Approximately 338,000 gallons of water were diverted to GW-11.
- Well Shutdown of IWF occurred on October 19, 2020 from 7:37am to October 19, 2020 7:47am due to ongoing maintenance activities at the GWTP influent tank. Maintenance was completed and the well field was brought back online.
- Well Shutdown of IWF occurred on October 22, 2020 from 8:15pm to October 22, 2020 8:40pm due to a power surge. The switches on the circuit breakers were reset and the well field was brought back online.
- Effluent diversion to GW-11 occurred on October 25, 2020 from 12:32am to October 25, 2020 5:22am due to low GW-11 pond level. Approximately 302,000 gallons of water were diverted to GW-11.
- Well Shutdown of IWF occurred intermittently on October 25, 2020 from 10:55am to 11:00am, 1:28pm to 1:33pm, 3:30pm to 3:35pm, 4:26pm to 4:32pm due to ongoing maintenance activities on the discharge piping for pump P-1A. Bypassing the Degassifier tank changed the flow characteristics for the GWTP. Adjustments were made and the well field was brought back online.
- Influent diversion to GW-11 occurred on October 26, 2020 from 2:19am to 2:59am due to electrical issues brought on by high wind conditions. Approximately 42,000 gallons of water were diverted to GW-11.
- Well Shutdown of ART-9 occurred on October 26, 2020 from 10:37am to 10:57am due to maintenance activities on the discharge piping. Maintenance was completed and the well was brought back online.
- Influent diversion to GW-11 occurred on October 27, 2020 from 5:42am to 2:30pm due to a pre-planned maintenance event. Approximately 130,000 gallons of water were diverted to GW-11.

- Well Shutdown of IWF occurred on October 27, 2020 from 6:25am to 7:52am due to a pre-planned maintenance event. Maintenance was completed and the well field was brought back online.

3. Spills

There were no reportable spills in the month of October.

4. Maintenance

- Major maintenance performed by ETI in the month included:
 - I. Replaced the wires at the South West pond corner for GW-11.
 - II. Replaced the O-ring on the Ferrous Sulfate feed check valve.
 - III. Replaced the piping on ART-8A on the sample port and installed a new bracket for bracing.
 - IV. Replaced the pressure switch on the FBR 2 recycle line.
 - V. Installed a new slam valve on the FBR 7 recycle line.
 - VI. Installed a splash guard around the containment at the GWTP sump pit area.
 - VII. Replaced the D-1 press feed pump.
 - VIII. Rebuilt the bed height pump for FBR 1.
 - IX. Installed a new seal water solenoid on FBR 6.
 - X. Replaced the power supply on the west press control panel.
- Preventative Maintenance completed or being performed by ETI in the month included:
 - I. Drained and inspected the DAF's, drained and inspected the Aeration tank, drained and inspected the 601 tank, and removed solids from the GWTP Influent tank.
 - II. Changed the oil at the Lift Station 2 turbine motor.
 - III. Verified the flow on the PC wells at the Seep Well Field.
 - IV. Cleaned out the combo valves on the effluent pipeline.
 - V. Oiled and greased the recycle motors and pumps.
 - VI. Removed the solids from the degassifier tank at the GWTP.
 - VII. Greased and inspected the front gate.

GWETS Upgrades and Facility Projects

Unit 4 Chromium Water Treatment Plant – Envirogen received comments regarding the deliverable documents that were submitted to the Trust in July 2019 for this project. The revised documents dealing with the Controls Specification, Process Drawings, and Mechanical Details were re-submitted to the Trust in September. Envirogen is awaiting further direction from the Trust regarding this matter. The Trust has advised Envirogen that this project is on hold pending finalization and approval of the forthcoming Unit 4 Source Area In-Situ Bioremediation Work Plan.

GWETS Extension –The signed Work Authorization for engineering and fabrication of the GWETS Extension was returned to the Trust on January 28, 2020. Orders have been placed for the major equipment for the GWETS Extension with deliveries expected during the third and fourth quarters of 2020. Envirogen is currently awaiting Trust comment on the O&M Work Authorization proposal for the GWETS Extension.

GWETS Staffing

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

Tables

Operational Metrics

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) ^{4 5}	Chromium (TR) (mg/L) ^{4 5}	Chromium(VI) (mg/L) ^{4 5}
SWF Total Extraction ¹	744 ³	8.8	0.0022	0.0027
AWF Total Extraction ¹	471 ³	67	0.14	0.14
IWF Total Extraction ¹	61 ³	433	6.3	6.4
AP Area Total Extraction ¹	9.5 ³	845	0.16	0.15
GWTP Effluent ²	62	498	0.48	ND
GW-11 Influent ¹	8.2	73	0.31	0.024
FBR Influent ²	1,029	64	0.023	0.014

Notes:

TR = Total Recoverable; NA = Not Analyzed; ND = Not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Perchlorate and chromium TR sampled monthly, values reported from Eurofins TestAmerica.

2: Perchlorate, chromium TR, and chromium (VI) sampled weekly, values reported from Eurofins TestAmerica.

3: Sum of daily average flow for individual wells.

4: All concentrations reported are monthly flow weighted averages.

5: ND analytical values are treated as zero values in the flow weighted average calculations.

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) ¹	Chromium (TR) (lbs/month) ¹	Chromium (VI) (lbs/month) ¹
SWF Total Extraction	2,437	0.62	0.75
AWF Total Extraction	11,757	24	25
IWF Total Extraction	9,877	143	146
AP Area Total Extraction	2,990	0.57	0.54
GWTP Effluent	11,498	11	ND
GW-11 Influent	223	0.95	0.073
FBR Influent ¹	24,386	8.7	5.3

Notes:

TR = Total Recoverable; NA = Not Analyzed.

1: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).

Figures

Operational Metrics

Figure 1 - GW-11 Pond Volume Through 10/31/2020





Figure 2 - Historical Perchlorate Mass Removed From Environment



Attachment A

NPDES Tracking Sheet (Prepared by Ramboll)

Treated Effluent at Outfall 001																		
Continuous		Daily Samples, composited weekly		Weekly Grab Samples								Weekly, collected separately		Quarterly				
Flow Rate		Perchlorate		pH	Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)	Total Suspended Solids (TSS)	Total Ammonia as N		Total Phosphorus as P		BOD ₅ (inhibited)		Total Dissolved Solids (TDS)	
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (µg/L)	30-Day Avg. (lbs/day)	Daily Min. (S.U.)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (mg/L)	Daily Average (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	Daily Max. (mg/L)	
2.52	2.88	18	0.38	6.5	9.0	10	100	5,000	10,000	20	135	2,899	20*	10*	25	40	525	8,000
January 2020	1.82	1.89	3	0.04	6.6	6.9	1.1	19	290	540	0.85	5.0	80	6	3.3	1.3	2.1	20
February 2020	1.85	1.91	ND (<2.5)	0.019	6.7	6.9	ND (<0.25)	7.6	170	980	1.1	4.9	70	2.3	1.6	ND (<2.0)	ND (<2.0)	16
March 2020	1.86	1.91	ND (<2.5)	0.019	6.6	7.1	0.36	5.4	220	1,100	ND (<0.50)	7	110	1.3	1.7	ND (<2.0)	ND (<2.0)	15
April 2020	1.85	1.88	ND (<2.5)	0.019	6.6	7.1	ND (<0.25)	6.4	160	1,300	ND (<0.50)	12	180	1.0	1.3	1.6	2.6	24
May 2020	1.81	1.91	ND (<2.5)	0.019	6.5	7.0	ND (<0.25)	7.4	160	830	11	9	130	10	2.4	1.6	3.3	24
June 2020	1.73	1.88	ND (<2.5)	0.018	6.7	7.0	ND (<0.25)	7.5	160	820	1.1	8	120	4.5	2.0	2.0	4.0	27
July 2020	1.62	1.87	ND (<2.5)	0.017	6.5	7.1	ND (<0.25)	5.8	150	930	1.6	7	80	8	2.0	1.9	3.8	29
August 2020	1.65	1.85	ND (<2.5)	0.017	6.7	7.3	ND (<0.25)	12	100	1,000	6.4	8	90	7	1.3	ND (<2.0)	ND (<2.0)	13
September 2020	1.74	1.90	1.7	0.025	6.7	7.2	ND (<0.25)	7.0	120	1,100	2.1	8	120	1.4	1.5	2.5	ND (<5.0)	35
October 2020 (month to date)	1.72	1.85	0.63	0.009	6.7	7.3	ND (<0.25)	22	120	970	0.46	16	210	1.9	4.3	ND (<5.0)	ND (<5.0)	38
November 2020 (month to date)	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Daily Grab Sample Dates	Composite Sample Date	µg/L	lbs/day	Sample Date	S.U.	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	Sample Date	mg/L			
12/19 - 1/4	1/4/2020	4.4	4.4	0.063	12/20/2019	6.6	ND (<0.25)	4.6	300	63	4.5	14	196	--	4.5	63	--	0.27	3.8	12/20/2019	ND (<2.0)	1.0	14	
1/5 - 1/11	1/11/2020	12	<0.079	6	0.09	6.6	ND (<0.25)	2.7	290	58	0.85	4.9	70	--	0.85	12	--	0.22	3.1	1/8/2020	ND (<2.0)	1.0	15	
1/12 - 1/18	1/18/2020	ND (<2.5)	1.3	0.019	1/13/2020	6.6	ND (<0.25)	19	210	66	ND (<0.50)	3.2	49	--	0.25	3.8	ND (<0.025)	0.013	0.19	1/15/2020	ND (<2.0)	1.0	16	
1/19 - 1/25	1/25/2020	ND (<2.5)	1.3	0.019	1/20/2020	6.9	ND (<0.25)	5.8	210	140	ND (<0.50)	9.2	142	--	0.16	2.5	--	0.12	1.9	1/22/2020	2.1	32		
1/26 - 2/1	2/1/2020	ND (<2.5)	1.3	0.019	1/27/2020	6.8	1.1	ND (<2.5)	200	540	ND (<0.50)	2.7	41	--	0.35	5.4	--	0.51	7.8	1/29/2020	ND (<2.0)	1.0	15	
2/2 - 2/8	2/8/2020	ND (<2.5)	1.3	0.019	2/3/2020	6.9	ND (<0.25)	3.3*	3.0	150	980	1.1	6.7	103	--	0.11	1.7	--	0.093	1.4	2/6/2020	ND (<2.0)	1.0	16
2/9 - 2/15	2/15/2020	ND (<2.5)	1.3	0.019	2/10/2020	6.7	ND (<0.25)	7.6	170	820	ND (<0.50)	6.4	97	--	0.18	2.7	--	0.095	1.4	2/12/2020	ND (<2.0)	1.0	15	
2/16 - 2/22	2/22/2020	ND (<2.5)	1.3	0.019	2/17/2020	6.9	ND (<0.25)	4.5	160	510	ND (<0.50)	3.0	46	--	0.15	2.3	--	0.12	1.8	2/19/2020	ND (<2.0)	1.0	15	
2/23 - 2/29	2/29/2020	ND (<2.5)	1.3	0.020	2/24/2020	6.8	ND (<0.25)	3.6	140	770	ND (<0.50)	3.5	54	--	0.17	2.6	--	0.11	1.7	2/26/2020	ND (<2.0)	1.0	16	
3/1 - 3/7	3/7/2020	ND (<2.5)	1.3	0.020	3/2/2020	7.0	ND (<0.25)	4.8	190	920	ND (<0.50)	5.8	91	--	0.17**	2.7	--	0.13	2.0	3/4/2020	ND (<2.0)	1.0	15	
3/8 - 3/14	3/14/2020	ND (<2.5)	1.3	0.019	3/9/2020	6.6	ND (<0.25)	4.7	220	890	ND (<0.50)	6.1	96	--	0.12**	1.9	--	0.11	1.7	3/12/2020	ND (<2.0)	1.0	15	
3/15 - 3/21	3/21/2020	ND (<2.5)	1.3	0.019	3/16/2020	7.1	ND (<0.25)	5.4	190	1,100	ND (<0.50)	11	173	ND (<0.10)	0.05**	0.79	--	0.077	1.2	3/18/2020	ND (<2.0)	1.0	16	
3/22 - 3/28	3/28/2020	ND (<2.5)	1.3	0.019	3/23/2020	6.7	ND (<0.25)	3.6	220	1,000	ND (<0.50)	6.2	97	--	0.14**	1.5	--	0.13	2.0	3/25/2020	ND (<2.0)	1.0	15	
3/29 - 4/4	4/4/2020	ND (<2.5)	1.3	0.019	3/30/2020	6.6	0.36	3.5	140	740	ND (<0.50)	5.5	86	ND (<0.10)	0.05**	0.76	--	0.082	1.3	4/1/2020	ND (<2.0)	1.0	15	
4/5 - 4/11	4/11/2020	ND (<2.5)	1.3	0.019	4/6/2020	7.1	ND (<0.25)	6.2	160	1,200	ND (<0.50)	12	187	--	0.19**	1.9	--	0.12	1.9	4/8/2020	2.6	41		
4/12 - 4/18	4/18/2020	ND (<2.5)	1.3	0.019	4/13/2020	7.1	ND (<0.25)	6.4	110	1,300	ND (<0.50)	14	217	ND (<0.10)	0.05**	0.77	--	0.063	1.0	4/15/2020	2.2	34		
4/19 - 4/25	4/25/2020	ND (<2.5)	1.3	0.020	4/20/2020	6.9	ND (<0.25)	5.6	150	1,200	ND (<0.50)	13	203	ND (<0.10)	0.05**	0.78	--	0.084	1.3	4/22/2020	ND (<2.0)	1.0	16	
4/26 - 5/2	5/2/2020	ND (<2.5)	1.3	0.019	4/27/2020	6.6	ND (<0.25)	3.3	130	860	ND (<0.50)	8.4	129	ND (<0.10)	0.05**	0.77	--	0.074	1.1	4/29/2020	ND (<2.0)	1.0	15	
5/3 - 5/9	5/9/2020	ND (<2.5)	1.3	0.019	5/4/2020	7.0	ND (<0.25)	7.4*	4.0	160	440	ND (<0.50)	5.1	81	--	0.15**	10.1	--	0.083	1.3	5/6/2020	ND (<2.0)	1.0	16
5/10 - 5/16	5/16/2020	ND (<2.5)	1.3	0.020	5/11/2020	6.5	ND (<0.25)	6.8	150	690	ND (<0.50)	9.4	146	--	0.14	2.2	--	0.12	1.9	5/13/2020	ND (<2.0)	1.0	16	
5/17 - 5/23	5/23/2020	ND (<2.5)	1.3	0.019	5/18/2020	7.0	ND (<0.25)	4.6	140	600	1.9	6.1	94	--	1.9	29	--	0.20	3.1	5/20/2020	ND (<2.0)	1.0	15	
5/24 - 5/30	5/30/2020	ND (<2.5)	1.3	0.017	5/26/2020	7.0	ND (<0.25)	6.6	120	830	11	14	208	--	0.51	7.6	--	0.22	3.3	5/27/2020	3.3	50		
5/31 - 6/6	6/6/2020	ND (<2.5)	1.3	0.018	6/1/2020	6.8	ND (<0.25)	7.5	110	740	0.58	11	162	--	0.58	8.5	--	0.12	1.8	6/3/2020	2.1	32		
6/7 - 6/13	6/13/2020	ND (<2.5)	1.3	0.018	6/9/2020	6.7	ND (<0.25)	3.8	110	410	ND (<0.50)	4.6	69	--	0.18	2.7	--	0.073	1.1	6/10/2020	ND (<2.0)	1.0	15	
6/14 - 6/20	6/20/2020	ND (<2.5)	1.3	0.019	6/15/2020	6.9	ND (<0.25)	5.3	150	820	1.1	7.8	117	--	0.16	2.4	--	0.013	0.19	6/17/2020	ND (<2.0)	1.0	15	
6/21 - 6/27	6/27/2020	ND (<2.5)	1.3	0.017	6/22/2020	6.9	ND (<0.25)	7.3	160	780	ND (<0.50)	8.4	125	--	0.26	3.9	--	0.12	1.8	6/24/2020	4.0	44		
6/28 - 7/4	7/4/2020	ND (<2.5)	1.3	0.017	6/29/2020	7.0	ND (<0.25)	5.9	99	710	ND (<0.50)	9.9	145	--	0.33	4.8	--	0.12	1.8	7/1/2020	ND (<2.0)	1.0	15	
7/5 - 7/11	7/11/2020	ND (<2.5)	1.3	0.017	7/6/2020	7.0	ND (<0.25)	5.8	87	930	1.6	12	146	--	1.6	20	--	0.25	3.1	7/8/2020	ND (<2.0)	1.0	15	
7/12 - 7/18	7/18/2020	ND (<2.5)	1.3	0.017	7/13/2020	6.5	ND (<0.25)	4.1	120	680	ND (<0.50)	7.2	84	--	0.30	3.5	--	0.089	1.04	7/15/2020	2.5	38		
7/19 - 7/25	7/25/2020	ND (<2.5)	1.3	0.016	7/20/2020	7.1	ND (<0.25)	4.7	110	470	0.51	3.9	60	--	0.51	7.8	--	0.096	1.5	7/22/2020	3.8	59		
7/26 - 8/1	8/1/2020	ND (<2.5)	1.3	0.017	7/27/2020	7.1	ND (<0.25)	ND (<2.5)	150	510	ND (<0.50)	3.2	48	--	0.16	2.4	--	0.150	2.2	7/29/2020	ND (<2.0)	1.0	15	
8/2 - 8/8	8/8/2020	ND (<2.5)	1.3	0.015	8/3/2020	6.7	ND (<0.25)	3.6	94	730	ND (<0.50)	8.1	98	--	0.20	2.4	--	0.077	0.93	8/5/2020	ND (<2.0)	1.0	12	
8/9 - 8/15	8/15/2020	ND (<2.5)	1.3	0.016	8/10/2020	6.9	ND (<0.25)	6.0*	9.6	1,000	6.4	19	170	--	6.4**	57	--	0.35	3.1	8/12/2020	ND (<2.0)	1.0	10	
8/16 - 8/22	8/22/2020	ND (<2.5)	1.3	0.019	8/17/2020	7.3	ND (<0.25)	17	85	88	ND (<0.50)	2.8	43	--	0.38**	5.8	--	0.11	1.7	8/19/2020	ND (<2.0)	1.0	15	
8/23 - 8/29	8/29/2020	ND (<2.5)	1.3	0.018	8/24/2020	6.8	ND (<0.25)	6.0	57	350	1.1	3.9	60	ND (<0.10)	0.05**	0.77	--	0.039	0.60	8/26/2020	ND (<2.0)	1.0	15	
8/30 - 9/5	9/5/2020	ND (<2.5)	1.3	0.019	8/31/2020	6.9	ND (<0.25)	4.4	81	610	1.2	6.3												

Attachment B

Equipment Tracking Form

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
Main Plant Equipment						
1 Seep Wells and Lift Station 1						
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running			
1.03		Lift Station 1 Lift Pump B	Standby			
1.04		Area in and around Lift Station 1	Running			
2 Athens Road Wells and Lift Station 3						
2.01		Athens Road Well Field, 9 wells	Running		3	Repaired a minor leak on ART-9 and replaced the piping on the sample tap on ART-8. Installed a bracket on the piping to help secure the turbulence.
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running			
3 Lift Station 2 and Transmission Pipelines						
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running			
4 Interceptor Wells and Cr Treatment Plant						
4.01		IWF Well Field, 30 wells	Running			
4.02		Ferrous Sulfate Feed System	Running		3	Replaced the O-ring on the ferrous check ball.
4.03		Polymer Feed System	Running		3	Replace the pump end.
4.04		Clarifier	In operation			
4.05		Filter Press	Running			
4.06		GWTP Effluent Tank	In operation		2	Removed the solids and reset the level indicator.
4.07		Interceptor Booster Pump A	Running			
4.08		Interceptor Booster Pump B	Standby		1	During the down day the suction piping was removed and cleaned out.
4.09		Area In And Around GWTP	Running			
5 Equalization Area and GW-11 Pond						
5.01	PID10A	Pond GW-11	In operation		3	Replaced the wiring on the SW pond corner motor electrical leads.
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
5.05	PID10A	Area in and Around EQ	In operation			
5.06	PID10A	Raw Water Feed Pump - P102A				
5.07	PID10A	Raw Water Feed Pump - P102B				
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running			
6		First Stage FBRs A, 1 & 2				
6.01	PID14	FBR A				
6.02	PID14	Separator Tank - 1401				
6.03	PID14	Media Return Pump - P 1401				
6.04	PID14	P1401A				
6.05	PID01A	P1401B				
6.06	PID01A	FBR 1	Running		3	Replaced the 6" butterfly valve for the feed flow diversion
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012			2	Replaced the pressure switch and tubing supplying the pressure. Replaced the seal water solenoid.
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
7		First Stage FBRs 3 & 4				
7.01	PID01B	FBR 3	Running			
7.02	PID01B	FBR 4	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
7.03	PID02B	First Stage Separator Tank - T2012	Running			
7.04	PID01B	Media Return Pump - P2012	Running			
7.05	PID01B	First Stage FBR Pump - P1013	Running			
7.06	PID01B	First Stage FRB Pump - P1014	Running		3	Replaced the 6" butterfly valve for the feed flow diversion
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723				
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
8		Second Stage FBRs 5 & 6				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running		3	Replaced the 6" butterfly valve for the feed flow diversion
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running			
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby		2	Replaced the seal water solenoid.
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
9		Second Stage FBRs 7 & 8				
9.01	PID03B	FBR 7	Running		2	Replaced the slam valve on the recycle line with new airline fittings and bypass valves.
9.02	PID03B	FBR 8	Running			
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2= Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			
10		Aeration and DAF System				
10.01	PID04	Aeration Tank	In operation		1	The aeration was drained and inspected on the controlled down day.
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Bio filter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump				
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running		2	The vessel was taken offline to make a few patch repairs to the vessel, pressure wash and inspect, and adjust the skimmer system.
10.12	PID05	DAF Pressure Pump - P501	Running		2	The air was turned off to the system and the pipe nipples and valve was replaced.
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running		2	The vessel was taken offline during the controlled down day to be cleaned and inspected. The vessel was brought back online.
10.15	PID05	DAF Pressure Pump - P551	Running			
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			
11		Pumping System (Old Effluent)				
11.01	PID06	Effluent Tank 601	In operation		2	The tank was drained, cleaned and inspected during the controlled down day.
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602	Standby			
12		Sand Filter System				

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
12.01	PID17	Sand Filter			2	The vessel was drained, and flushed down to the sand bed. The old air sparger system was removed and the vessel was inspected.
12.02	PID17	Filter Reject Tank	In operation			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
13		Effluent Tank and Pumping				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			
13.04	PID10C	Area Around Effluent and North D-1	Running			
14		Solids Collection and Pressing System				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation			
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902				
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			
		Chemical Systems				
15		Electron Donor System				
15.01	PID07B	Electron Donor Tank	In operation			
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation		2	The hose connection from the tote to the feed pump was replaced.
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2= Important - Can still operate safely and in compliance with permits, but risks are increased
 3= Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4= Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
22	PID07A	<i>pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)</i>	In operation			
23	PID07C	<i>Ferric Chloride</i>	In operation			
24	PID07B	<i>Polymer Systems - DAF</i>	In operation			
25	PID09	<i>Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)</i>	In operation			
Utility Systems						
26		Compressed Air System				
26.01	PID08	<i>West Compressor</i>	Running			
26.02	PID08	<i>East Compressor</i>	Running			
26.03	PID08	<i>O2 Compressor</i>	Running			
26.04	PID08	<i>Compressed Air Receiver Tank</i>	In operation			
26.05	PID08	<i>Air Dryer</i>	Running			
26.06	PID08	<i>Oil Removal Filter</i>	In operation			
26.07	PID08	<i>Particulate Filter</i>	In operation			
27	PID16	<i>Oxygen System</i>	In operation			
28		<i>GWETS Plant Controls/ Siemens Controls</i>	In operation			
29		<i>Well Control System/ Allen Bradley Controls</i>	In operation			
30		<i>MCC FBR Pad</i>	In operation			
31		<i>MCC in D-1</i>	In operation			
32		<i>MCC in EQ area</i>	In operation			
Miscellaneous Systems						
33		<i>Operations Office/Network</i>	In operation			
34		<i>Laboratory Analyzers</i>	In operation			
35		<i>Security Systems</i>	In operation			
Shelf Spares						
		<i>Media Return Pump Rebuild Kit</i>	In stock			
		<i>pH Feed Pump</i>	In stock			
		<i>Nutrient Feed Pump</i>	In stock			
		<i>Electron Donor Feed Pump</i>	In stock			
		<i>Phosphoric Acid Feed Pump</i>	In stock			
		<i>Interceptor Well Pumps (4 each)</i>	In stock			
		<i>Seep Well Pump (1 each, same as Athens so total of 2)</i>	In stock			
		<i>Athens Road Well Pump (1 each, same as Seep so total of 2)</i>	In stock			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2= Important - Can still operate safely and in compliance with permits, but risks are increased
 3= Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4= Low - Minor repairs that in no way alter the performance of the plant