
To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: Michael Del Vecchio, Director Engineering and Project Management

Date: December 20, 2023

Subject: NERT – GWETS Operation Monthly Report – November 2023

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during November 2023.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in November 2023. Flow from PC-115R, PC-119, PC-120, PC-121, and PC-133 were routed to the IX system, bypassing all flow meters associated with the FBR plant for the month of November. The flow rate to the IX system averaged approximately 302 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 939 gpm. At the end of the month, the filled GW-11 Pond volume was at 44.77 million gallons (MG), which would allow 12.3 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond increased since the end of October 2023; Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 2.0 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 50 mg/L for the month, with a maximum concentration of 53 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of October 2023 averaged 44 mg/L, with a maximum concentration of 47 mg/L.

Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 graphically presents historical perchlorate mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11

There were no operational issues with GW-11 in the month of November.

2. Biological Plant

There were influent / effluent diversions during the reporting period generally associated with maintenance activities as well as extraction well short-term shutdown events. Below is a description of the events that occurred:

Diversion Events / Well Shutdowns

- Influent diversion occurred on November 8, 2023 from 7:23pm to 8:06pm as a precautionary measure due to elevated levels of perchlorate in the FBRs. Adjustments were made to the process and the plant was brought back online. Approximately 45,000 gallons of water were added to the GW-11 pond.
- Influent diversion occurred on November 20, 2023 from 10:05am to 1:00pm due to scheduled maintenance on the 1302A VFD as well as the addition of sand to FBR 1. The maintenance was completed and the plant was brought back online. Approximately 183,000 gallons of water were added to the GW-11 Pond.
- Influent diversion occurred on November 27, 2023 from 8:18pm to November 28, 2023 at 2:25am due to a malfunctioning feed control valve. Troubleshooting was conducted, the valve was repaired, and the plant was brought back online. Approximately 375,000 gallons of water were added to the GW-11 Pond.
- Influent diversion occurred on November 28, 2023 from 8:41am to 9:58am due to a malfunctioning air compressor. Troubleshooting was conducted, the compressor function was resolved, and the plant was brought back online. Approximately 74,000 gallons of water were added to the GW-11 Pond.

3. IX Treatment Plant

During the month of February 2022, flooding conditions were observed adjacent to the SWF as a result of the City of Henderson's (CoH's) use of inactive Birding Ponds 10 through 13. The discharge to these ponds resulted in an increase in groundwater elevation adjacent to the SWF by approximately 5 feet. This increase in groundwater elevation caused flooding adjacent to the SWF extraction wells and within four extraction well vaults. Flooding conditions were observed again in September 2023 as a result of the CoH's use of inactive Birding Ponds 10 through 13 again in August and September 2023. ETI temporarily increased the pumping rate of extraction wells PC-120 and PC-121 to reduce flooding with the well vaults. Additionally, the concentration of perchlorate in shallow groundwater increased again resulting in increased loading to the IX treatment plant during September 2023. The CoH ceased

discharging water to Birding Ponds 10 through 13 in early October 2023. Both the groundwater elevation adjacent to the SWF and the perchlorate concentrations in groundwater are elevated and are expected to remain elevated for an extended period as result of CoH's August/September 2023 use of the inactive Birding Ponds assuming no additional significant usage by the CoH occurs.

4. Treatment System Extension (TSE)

During November 2023, operations at the TSE plant were idled resulting from the TIMET infiltration galleries being unable to accept treated water. Throughout the month of November representatives of NERT and TIMET participated in multiple discussions regarding operations of the TSE and TIMET facilities. Operations are anticipated to resume in Q1 2024.

5. Effluent Filtration System (EFS)

During November 2023, the EFS operated normally and produced approximately 390,000 gallons of filtered GWETS effluent which supported the utility water requirements of GWETS operations.

6. Chromium Treatment Subsystem (CTS)

During November 2023, the CTS operated normally and treated approximately 2,405,000 gallons of groundwater, with approximately 5,000 gallons extracted from the Unit 4 Source Area In-Situ Bioremediation Treatability Study.

7. Spills

There was one reportable spill in the Month of November.

- On November 22, 2023 at approximately 4:50 am the feed flow control valves for FBR 3 and 4 as well as the discharge/level control valve for Separator 2 malfunctioned causing the levels in FBR 3 and 4 and Separator 2 to rise above the tank tops causing an overflow. Approximately 20 gallons of partially treated water was released outside of containment. NDEP BWPC was notified in writing on December 1, 2023. All corrective actions identified in NERT's December 1, 2023 letter have been implemented.

8. Maintenance

- Major maintenance performed by ETI in the reporting month included:
 - I. Installed a new 7.5 hp motor on extraction well PC-116.
 - II. Installed new piping on extraction well E2-1.
 - III. Replaced the wire on the FBR1/2 pump skid to the HOA switches.
 - IV. Replaced the seal water solenoid valve and fuse on pump P-3015.
 - V. Installed a temporary light on the FBR pad.
 - VI. Installed a new flowmeter on AP Area extraction well E2-2.
 - VII. Loaded sand into FBR 1.
 - VIII. Pumped out the wells vaults due to power down at Lift Station 1 from PC-120 and PC-121.

- IX. Installed a rebuilt positioner and transducer on the level control valve for Separator 1.
 - X. Replaced the pH meters on FBR 1 and FBR 4.
- Preventative maintenance performed by ETI in the reporting month included:
 - I. Inspected and blew out the Lift Station MCC's.
 - II. Calibrated the level control valve for tank T-601.
 - III. Greased all rotating equipment.
 - IV. Installed new in-line air filters for the level control valves.
 - V. Flushed the pH and ORP lines for the FBR's.
 - VI. Checked for correct RPM on the recycle pump motors.
 - VII. Topped off the water for the utility carts.
 - VIII. Greased the turbines and changed the oil at Lift Station 1.
 - IX. Inspected the leads in the PLC racks around the plant.
 - X. Cleared water from the airlines on the slam valves.

Attachment B contains a summary of all maintenance activities completed during the reporting period.

Facility Projects

1. Facility Repair/Replacement Items – Envirogen and the Trust have finalized a list of facility items to be addressed in connection with Amendment 8 to the O&M Agreement. All work with the exception of the replacement of the DAF have been completed. Specific details on in-progress items are provided below:
 - I. (WA 23-03) Dissolved Air Flootation (DAF) Vessel replacement
 1. The replacement DAF was delivered in December 2023 and will be installed in March 2024.
 - II. Concrete Repair at various locations on FBR pad
 1. Scheduling work with selected contractor. Work is anticipated to be completed in February 2024.
2. Improved Biological Treatment Plant Efficiency – Consistent with Attachment D to the December 2021 GWETS Operation Monthly Report, Envirogen plans to take five FBRs out of service and maintain them in working condition should they be needed in the future. This action will reduce the use of electricity and water and still maintain sufficient treatment capacity to address current groundwater extracted from the IWF, AWF, and the SWF as well as groundwater to be extracted as part of the Unit 4 Source Area In-Situ Bioremediation Treatability Study. FBR A was placed into Offline mode on April 13, 2022. The electrical and mechanical components of the pump skid were inspected and removed when applicable. The removal of the sand media is complete. Final inspection of all internal components is also complete. The remaining FBRs scheduled to be taken out of service will be addressed in the 2nd quarter of 2024.

Tables

Operational Metrics

| Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics | | | | |
|---|--------------------------------------|---------------------------------|-----------------------------------|----------------------------------|
| Location ID | Average Flow Rate (gpm) ⁴ | Perchlorate (mg/L) ⁵ | Chromium (TR) (mg/L) ⁵ | Chromium(VI) (mg/L) ⁵ |
| SWF Total Extraction ¹ | 735 ³ | 4.4 | ND | 0.0012 |
| AWF Total Extraction ¹ | 410 ³ | 63 | 0.10 | 0.10 |
| IWF Total Extraction ¹ | 46 ³ | 357 | 6.0 | 5.3 |
| AP Area Total Extraction ¹ | 7.3 ³ | 575 | 0.18 | 0.19 |
| Chromium Treatment Subsystem Effluent ² | 57 | 415 | 1.4 | 0.00031 |
| GW-11 Influent ¹ | 0.19 | 30 | 0.049 | 0.051 |
| FBR Influent ² | 939 | 50 | 0.14 | 0.036 |
| Treatment System Extension Influent ^{2,3} | 0.0 | 0.0 | 0.0 | 0.0 |

Notes:

ND = Not detected above laboratory method detection limit (Cr(TR)=2.5 µg/L).

1: Perchlorate and chromium TR sampled monthly, values reported from Eurofins TestAmerica.

2: Perchlorate, chromium TR, and chromium (VI) sampled weekly, values reported from Eurofins TestAmerica.

3: TSE offline from 11/01 to 11/30.

4: Sum of daily average flow for individual wells.

5: All concentrations reported are monthly flow weighted averages.

| Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics | | | |
|---|--------------------------------------|--|--|
| Location ID | Perchlorate (lbs/month) ¹ | Chromium (TR) (lbs/month) ¹ | Chromium (VI) (lbs/month) ¹ |
| SWF Total Extraction | 972 | ND | 0.26 |
| AWF Total Extraction | 9,288 | 14 | 14 |
| IWF Total Extraction | 5,930 | 100 | 88 |
| AP Area Total Extraction | 1,514 | 0.47 | 0.49 |
| Chromium Treatment Subsystem Effluent | 8,577 | 30 | 0.0064 |
| GW-11 Influent | 2.1 | 0.0034 | 0.0035 |
| FBR Influent ¹ | 16,866 | 43 | 11 |
| Treatment System Extension Influent ^{1,2} | 0.0 | 0.0 | 0.0 |

Notes:

TR = Total Recoverable.


1: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).

2: TSE offline from 11/01 to 11/30.

Figures

Operational Metrics


Figure 1 - GW-11 Pond Volume Through 11/30/2023



Notes:

1. A transducer installed along the eastern berm provides water pressure measurements that are correlated to elevations for calculation of water depths.

Figure 2 - Historical Perchlorate Mass Removed From Environment



Attachment A

NPDES Tracking Sheet (Prepared by Ramboll)

Attachment B

Equipment Tracking Form

| Sub-System | P&ID | Description | Status ¹ | Checked | Criticality ² | Notes |
|------------|--------|--|---------------------|---------|--------------------------|--|
| | | Main Plant Equipment | | | | |
| 1 | | Seep Wells and Lift Station 1 | | | | |
| 1.01 | | Seep Well Field, 9 wells | Running | | 2 | Pulled and replaced the motor on PC-116. |
| 1.02 | | Lift Station 1 Lift Pump A | Running | | | |
| 1.03 | | Lift Station 1 Lift Pump B | Standby | | | |
| 1.04 | | Area in and around Lift Station 1 | Running | | 4 | Replaced A/C on the turbine cabinet. |
| 2 | | Athens Road Wells and Lift Station 3 | | | | |
| 2.01 | | Athens Road Well Field, 9 wells | Running | | | |
| 2.02 | | Lift Station 3 Lift Pump A | Standby | | | |
| 2.03 | | Lift Station 3 Lift Pump B | Running | | | |
| 2.04 | | Area in and around Lift Station 3 | Running | | | |
| 3 | | Lift Station 2 and Transmission Pipelines | | | | |
| 3.01 | | Influent Pipeline | In operation | | | |
| 3.02 | | Effluent Pipeline | Running | | | |
| 3.03 | | Lift Station 2 Lift Pump A | Running | | | |
| 3.04 | | Lift Station 2 Lift Pump B | Standby | | | |
| 3.05 | | Area in and around Lift Station 2 | Running | | | |
| 4 | | Interceptor Wells and Cr Treatment Plant | | | | |
| 4.01 | | IWF Well Field, 30 wells | Running | | | |
| 4.02 | | Ferrous Sulfate Feed System | Running | | | |
| 4.03 | | Polymer Feed System | Running | | 3 | Replaced the pump with a new diaphragm pump. |
| 4.04 | | Clarifier | In operation | | | |
| 4.05 | | Filter Press | Running | | | |
| 4.06 | | GWTP Effluent Tank | In operation | | | |
| 4.07 | | Interceptor Booster Pump A | Running | | | |
| 4.08 | | Interceptor Booster Pump B | Standby | | | |
| 4.09 | | Area In And Around GWTP | Running | | 4 | Installed a temporary light in the area. |
| 5 | | Equalization Area and GW-11 Pond | | | | |
| 5.01 | PID10A | Pond GW-11 | In operation | | | |
| 5.02 | PID10A | Pond Water Pump - P101A | Running | | | |
| 5.03 | PID10A | Pond Water Pump - P101B | Standby | | | |
| 5.04 | PID10A | Equalization Tanks | In operation | | | |
| 5.05 | PID10A | Area in and Around EQ | In operation | | | |
| 5.06 | PID10A | Raw Water Feed Pump - P102A | | | | |
| 5.07 | PID10A | Raw Water Feed Pump - P102B | | | | |
| 5.08 | PID10A | F-101 Filters | Running | | | |

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

| Sub-System | P&ID | Description | Status ¹ | Checked | Criticality ² | Notes |
|------------|--------|---|---------------------|---------|--------------------------|--|
| 5.09 | PID10B | Carbon Absorber - LGAC 201A | | | | |
| 5.10 | PID10B | Carbon Absorber - LGAC 201B | | | | |
| 5.11 | PID10B | Carbon Absorber - LGAC 201C | | | | |
| 6 | | First Stage FBRs A, 1 & 2 | | | | |
| 6.01 | PID14 | FBR A | | | | EQUIPMENT OFFLINE |
| 6.02 | PID14 | Separator Tank - 1401 | | | | EQUIPMENT OFFLINE |
| 6.03 | PID14 | Media Return Pump - P 1401 | | | | EQUIPMENT OFFLINE |
| 6.04 | PID14 | P1401A | | | | EQUIPMENT OFFLINE |
| 6.05 | PID01A | P1401B | | | | EQUIPMENT OFFLINE |
| 6.06 | PID01A | FBR 1 | Running | | 1 | The electrical was damaged in the conduit for the power supply for the HOA switches that power the pumps. New wire was pulled. |
| 6.07 | PID02A | FBR 2 | Running | | 1 | The electrical was damaged in the conduit for the power supply for the HOA switches that power the pumps. New wire was pulled. |
| 6.08 | PID01A | First Stage Separator Tank - T2011 | Running | | 3 | The positioner and transducer have been replaced. |
| 6.09 | PID01A | Media Return Pump - P2011 | Running | | | |
| 6.10 | PID01A | First Stage FBR Pump - P1011 | Standby | | | |
| 6.11 | PID01A | First Stage FBR Pump - P1012 | | | | |
| 6.12 | PID01A | First Stage FRB Pump - P101A | Running | | | |
| 6.13 | PID07A | FBR A pH Feed Pump - P71A | Off | | | |
| 6.14 | PID07A | FBR 1 pH Feed Pump - P711 | Off | | | |
| 6.15 | PID07A | FBR 2 pH Feed Pump - P712 | Off | | | |
| 6.16 | PID07A | FBR A Nutrient (Urea) Feed Pump - P72A | Off | | | |
| 6.17 | PID07A | FBR 1 Nutrient (Urea) Feed Pump - P721 | Off | | | |
| 6.18 | PID07A | FBR 2 Nutrient (Urea) Feed Pump - P722 | Off | | | |
| 6.19 | PID15 | FBR A Nutrient (Phos Acid) Feed Pump - P1520A | Running | | | Equipment offline |
| 6.20 | PID15 | FBR 1 Nutrient (Phos Acid) Feed Pump - P1521 | Running | | | |
| 6.21 | PID15 | FBR 2 Nutrient (Phos Acid) Feed Pump - P1522 | Running | | | |
| 6.22 | PID07B | FBR A Electron Donor Assembly Pump - P73A | Running | | | |
| 6.23 | PID07B | FBR 1 Electron Donor Assembly Pump - P731 | Running | | | |
| 6.24 | PID07B | FBR 2 Electron Donor Assembly Pump - P732 | Running | | | |
| 7 | | First Stage FBRs 3 & 4 | | | | |
| 7.01 | PID01B | FBR 3 | Running | | | |
| 7.02 | PID01B | FBR 4 | Running | | | |
| 7.03 | PID02B | First Stage Separator Tank - T2012 | Running | | 3 | Rebuilt and replaced the positioner and the transducer on the level control valve. |

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

| Sub-System | P&ID | Description | Status ¹ | Checked | Criticality ² | Notes |
|------------|--------|--|---------------------|---------|--------------------------|---|
| 7.04 | PID01B | Media Return Pump - P2012 | Running | | | |
| 7.05 | PID01B | First Stage FBR Pump - P1013 | Running | | | |
| 7.06 | PID01B | First Stage FRB Pump - P1014 | Running | | | |
| 7.07 | PID01B | First Stage FBR Pump - P102A | Running | | | |
| 7.08 | PID07A | FBR 3 pH Feed Pump - P713 | Running | | | |
| 7.09 | PID07A | FBR 4 pH Feed Pump - P714 | Running | | | |
| 7.10 | PID07A | FBR 3 Nutrient (Urea) Feed Pump - P723 | | | | |
| 7.11 | PID07A | FBR 4 Nutrient (Urea) Feed Pump - P 724 | Off | | | |
| 7.12 | PID15 | FBR 3 Nutrient (Phos Acid) Feed Pump - P1523 | Running | | | |
| 7.13 | PID15 | FBR 4 Nutrient (Phos Acid) Feed Pump - P1524 | Running | | | |
| 7.14 | PID07B | FBR 3 Electron Donor Assembly Pump - P733 | Running | | | |
| 7.15 | PID07B | FBR 4 Electron Donor Assembly Pump - P734 | Running | | 3 | Cleared the injection line and replaced the check valve. |
| 8 | | Second Stage FBRs 5 & 6 | | | | |
| 8.01 | PID03A | FBR 5 | Running | | 3 | Replaced the slam valve. |
| 8.02 | PID03A | FBR 6 | Running | | | |
| 8.03 | PID03C | Second Stage Separator Tank - T3011 | Running | | | |
| 8.04 | PID03A | Media Return Pump - P3011 | Running | | | |
| 8.05 | PID03A | Second Stage FBR Pump - P3015 | Running | | 3 | Replaced the solenoid for the seal water system. |
| 8.06 | PID03A | Second Stage FBR Pump - P3016 | Standby | | | |
| 8.07 | PID03A | Second Stage FBR Pump - P301A | Running | | | |
| 8.08 | PID07A | FBR 5 pH Feed Pump - P715 | Off | | | |
| 8.09 | PID07A | FBR 6 pH Feed Pump - P716 | Off | | | |
| 8.1 | PID07A | FBR 5 Nutrient (Urea) Feed Pump - P725 | Off | | | |
| 8.11 | PID07A | FBR 6 Nutrient (Urea) Feed Pump - P726 | Off | | | |
| 8.12 | PID07B | FBR 5 Electron Donor Assembly Pump - P735 | Running | | | |
| 8.13 | PID07B | FBR 6 Electron Donor Assembly Pump - P736 | Running | | | |
| 9 | | Second Stage FBRs 7 & 8 | | | | |
| 9.01 | PID03B | FBR 7 | Running | | | |
| 9.02 | PID03B | FBR 8 | Running | | | |
| 9.03 | PID03D | Second Stage Separator Tank - T3012 | Running | | | |
| 9.04 | PID03B | Media Return Pump - P3012 | Running | | 3 | Flushed the line forward to clear the large amount of solids in the line. |
| 9.05 | PID03B | Second Stage FBR Pump - P3017 | Running | | | |
| 9.06 | PID03B | Second Stage FBR Pump - P3018 | Running | | | |
| 9.07 | PID03B | Second Stage FBR Pump - P302A | Running | | | |
| 9.08 | PID07A | FBR 7 pH Feed Pump - P717 | Off | | | |
| 9.09 | PID07A | FBR 8 pH Feed Pump - P718 | Off | | | |

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

| Sub-System | P&ID | Description | Status ¹ | Checked | Criticality ² | Notes |
|------------|--------|--|---------------------|---------|--------------------------|--|
| 9.10 | PID07A | FBR 7 Nutrient (Urea) Feed Pump - P727 | Off | | | |
| 9.11 | PID07A | FBR 8 Nutrient (Urea) Feed Pump - P728 | Off | | | |
| 9.12 | PID07B | FBR 7 Electron Donor Assembly Pump - P737 | Running | | | |
| 9.13 | PID07B | FBR 8 Electron Donor Assembly Pump - P738 | Running | | | |
| 10 | | Aeration and DAF System | | | | |
| 10.01 | PID04 | Aeration Tank | In operation | | | |
| 10.02 | PID04 | Aeration Blower - B401 | Running | | | |
| 10.03 | PID04 | Bio filter | In operation | | | |
| 10.04 | PID04 | Nutrient Solution | Running | | | |
| 10.05 | PID04 | Bio filter Sump | | | | |
| 10.06 | PID04 | Nutrient Pump - P401 | Running | | | |
| 10.07 | PID04 | Bio filter Sump Pump - P402A | Standby | | | |
| 10.09 | PID04 | Bio filter Blower | Running | | | |
| 10.10 | PID05 | DAF Pressure Tanks | In operation | | 4 | Replaced the muffler on the air blowdown. |
| 10.11 | PID05 | DAF Vessel - D501 | Running | | | |
| 10.12 | PID05 | DAF Pressure Pump - P501 | Running | | | |
| 10.13 | PID05 | DAF Float Pump - P502 | Running | | | |
| 10.14 | PID05 | DAF Vessel - D551 | Running | | | |
| 10.15 | PID05 | DAF Pressure Pump - P551 | Running | | | |
| 10.16 | PID05 | DAF Float Pump - P552 | Running | | 3 | Swapped out the pump with a rebuilt pump. |
| 10.17 | PID05 | Screw Conveyer Drive | Standby | | | |
| 10.18 | PID05 | Skimmer Drive | Running | | | |
| 11 | | Pumping System (Old Effluent) | | | | |
| 11.01 | PID06 | Effluent Tank 601 | In operation | | | |
| 11.02 | PID06 | Effluent Pump - P601 | Running | | 3 | Reconnected the leads on the motor. |
| 11.03 | PID06 | Effluent Pump - P602 | | | | |
| 12 | | Sand Filter System | | | | |
| 12.01 | PID17 | Sand Filter | | | | |
| 12.02 | PID17 | Filter Reject Tank | In operation | | | |
| 12.03 | PID17 | Filter Reject Pump - P1701A | Standby | | | |
| 12.04 | PID17 | Filter Reject Pump - P1701B | Running | | | |
| 13 | | Effluent Tank and Pumping | | | | |
| 13.01 | PID10C | UV Effluent Tank | Running | | | |
| 13.02 | PID10C | Effluent Booster Pump - P1302A | Running | | | |
| 13.03 | PID10C | Effluent Booster Pump - P1302B | Standby | | 1 | Powered down the MCC and installed the new VFD on the motor. |
| 13.04 | PID10C | Area Around Effluent and North D-1 | Running | | | |
| 14 | | Solids Collection and Pressing System | | | | |

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

| Sub-System | P&ID | Description | Status ¹ | Checked | Criticality ² | Notes |
|-------------------------|------------------------------|--|---------------------|---------|--------------------------|---|
| 14.01 | PID16 | Sludge Storage Tank | In operation | | | |
| 14.02 | PID16 | Solids Storage Effluent Pump - P1601 | Running | | | |
| 14.03 | PID16 | Solids Cond. Tank | In operation | | | |
| 14.04 | PID09 | Sludge Mixer | Running | | | |
| 14.05 | PID09 | Filter Press Pump - P901 | Running | | 4 | Rebuilding the spare pump. |
| 14.06 | PID09 | Filter Press Pump - P902 | | | | |
| 14.07 | PID09 | West Press | Standby | | | |
| 14.08 | PID09 | East Press | Running | | | |
| 14.09 | PID09 | Filtrate Tank | In operation | | | |
| 14.10 | PID09 | Filtrate Tank Effluent (recycle) Pump - P903 | Running | | 4 | A new mechanical seal has been ordered for the pump. |
| Chemical Systems | | | | | | |
| 15 | Electron Donor System | | | | | |
| 15.01 | PID07B | Electron Donor Tank | In operation | | | |
| 15.02 | PID07B | Booster Pump P739A | Running | | | |
| 15.03 | PID07B | Booster Pump P739B | Standby | | | |
| 17 | PID07C | Micro Nutrient System | In operation | | | |
| 18 | PID07C | Hydrogen Peroxide System | In operation | | | |
| 19 | PID07C | De-Foam System | In operation | | | |
| 20 | PID15 | Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs) | In operation | | | |
| 21 | PID07A | Nutrient (Urea) System (Tank only - pumps included in FBRs) | In operation | | | |
| 22 | PID07A | pH System (Tank and effluent pH feed pump only - other pumps included in FBRs) | In operation | | | |
| 23 | PID07C | Ferric Chloride | In operation | | | |
| 24 | PID07B | Polymer Systems - DAF | In operation | | | |
| 25 | PID09 | Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder) | In operation | | | |
| Utility Systems | | | | | | |
| 26 | Compressed Air System | | | | | |
| 26.01 | PID08 | West Compressor | Running | | | |
| 26.02 | PID08 | East Compressor | Running | | 2 | Unit offline due to a failed motor starter. A new starter has been ordered. |
| 26.03 | PID08 | O2 Compressor | Running | | | |
| 26.04 | PID08 | Compressed Air Receiver Tank | In operation | | | |
| 26.05 | PID08 | Air Dryer | Running | | | |

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

| Sub-System | P&ID | Description | Status ¹ | Checked | Criticality ² | Notes |
|------------------------------|-------|--|---------------------|---------|--------------------------|-------|
| 26.06 | PID08 | Oil Removal Filter | In operation | | | |
| 26.07 | PID08 | Particulate Filter | In operation | | | |
| 27 | PID16 | Oxygen System | In operation | | | |
| 28 | | GWETS Plant Controls/ Siemens Controls | In operation | | | |
| 29 | | Well Control System/ Allen Bradley Controls | In operation | | | |
| 30 | | MCC FBR Pad | In operation | | | |
| 31 | | MCC in D-1 | In operation | | | |
| 32 | | MCC in EQ area | In operation | | | |
| Miscellaneous Systems | | | | | | |
| 33 | | Operations Office/Network | In operation | | | |
| 34 | | Laboratory Analyzers | In operation | | | |
| 35 | | Security Systems | In operation | | | |
| Shelf Spares | | | | | | |
| | | Media Return Pump Rebuild Kit | In stock | | | |
| | | pH Feed Pump | In stock | | | |
| | | Nutrient Feed Pump | In stock | | | |
| | | Electron Donor Feed Pump | In stock | | | |
| | | Phosphoric Acid Feed Pump | In stock | | | |
| | | Interceptor Well Pumps (4 each) | In stock | | | |
| | | Seep Well Pump (1 each, same as Athens so total of 2) | In stock | | | |
| | | Athens Road Well Pump (1 each, same as Seep so total of 2) | In stock | | | |

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant