
To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: Frank Johns/Tt

Date: November 26, 2014

Subject: NERT – GWETS Operation Monthly Report – October 2014

Tetra Tech is providing this monthly report to provide a summary of GWETS operation during October 2014 and oversight tasks performed by Tetra Tech.

Summary of GWETS Operation

The groundwater extraction and treatment system (GWETS) operated normally in October, with the exception of GW-11. GW-11 is still being bypassed due to high suspended solids content, primarily insects and some algae, causing frequent plugging of the bag filters and increased the backwash frequency for the GAC. Envirogen Technologies, Inc. (ETI) has ordered automatic cleaning filters to replace the bag filters. The new filters are expected to be online with the pond taken out of bypass by early December.

The flow rate to the plant averaged approximately 930 gpm during the month. At the end of the month, the GW-11 volume was 42.8 MG, equal to 13.6 days of available storage in event of an emergency. The volume decreased approximately 0.5 MG from the end of September, likely due to evaporation. The influent perchlorate concentration from the equalization tank to the FBR plant averaged 113 mg/L for the month, with a maximum concentration of 120 mg/L.

There were no exceedances at the GWETS Outfall for perchlorate or any other constituent in excess of the NPDES permitted numerical discharge limits (Attachment A, prepared by ENVIRON).

Operational Metrics

The approved program to add instruments, controls, data acquisition systems, along with various other technical upgrades to improve the efficiency of data collection and reporting remains on-schedule for phased activation beginning in March 2015.

See attached Tables 1 and 2 for a summary of the current GWETS operational metrics that provide data for flow rates and perchlorate and chromium concentrations and mass removal. The attached tables and figure have been revised and consolidated at the request of NDEP and are presented as follows:

- Table 1 – Flow Rate and Perchlorate and Chromium Concentrations
- Table 2 – Perchlorate and Chromium Mass Flux
- Figure 1 – Historical Perchlorate Mass Flux

Operational Issues

In addition to plant repairs conducted by ETI in accordance with their NERT Perchlorate Treatment System Operations Manual, the following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11 continues to be bypassed due to the issue with insects and algae causing plugging of the bag filters ahead of the GAC units. ETI has ordered automatic cleaning filters to replace the bag filters and are scheduled for installation in late November with operation in early December.
2. Major maintenance being performed or completed in the month included:
 - New motor and pump installed at ART-3B.
 - ART-7B now online.
 - Repairing the ram head of the filter press at the GWTP.
 - Replacing sump pump at the GWTP.
 - Repaired raw water feed pump (P102B).
 - Installing new nozzles and laterals on FBR 5.
 - Unclogged line on discharge side of media return pump for FBR 7 and 8.
 - Bypassing steel airlines with hose feeding the pressure tank at the DAF system.
 - New mechanical seal ordered for effluent pump (P601) on old effluent pumping system.
 - New positioner ordered for filter reject tank on the sand filter system.
 - Replacement kits ordered for filter press pump (P902).
 - New pump heads ordered for DAF polymer system.
 - Recorders installed on compressed air system.
 - Allen-Bradley computer is still operating inconsistently. A new computer is on order.
3. Outstanding maintenance and repairs from the previous month have been addressed as outlined below:
 - Raw water feed pump (P102B) removed for maintenance in shop.
 - i. P102B sent to shop in September, repaired and installed in October.
 - Media return pump for FBRs 7 and 8 taken out of service for belt replacement.
 - i. Media return pump repaired and reinstalled.
 - Level controllers at the equalization tanks were dropping out.
 - i. Level controllers are operating correctly.
 - Allen-Bradley computer for extraction wells and GWTP was down for a time with no visual indication of operation in control room. All wells and GWTP continued to operate with notification by auto-dialer.
 - i. A new computer is on order.

GWETS Upgrades and Facility Projects

The following is a summary of initiatives in-progress during the reporting period at the direction of the Trust:

1. 2013 Optimization

Construction for ART-7B was completed in early October. PC-150 is scheduled to be operational in early November. Another round of flow optimization for the IWF will be initiated once these AWF

wells are operational. Capture zone analyses for the IWF and AWF will be performed in November with a final report expected in January 2015.

2. AP-5 Closure

Tetra Tech has continued development of a work plan for closure of the pond. The draft work plan is scheduled to be submitted to the NDEP by the end of November. Tetra Tech continues to coordinate with NDEP, ETI, and the Trust on this project. This will be a long-term project that will directly impact GWETS operations across multiple levels once implemented.

3. Enhanced Operational Metrics

Tetra Tech started design for the enhanced operational metrics project in September. A preliminary design meeting was held with ETI on October 29.

Equipment Availability Tracking

ETI operators continue to update the equipment tracking form on a weekly basis at a minimum, or whenever there is a change in the status of key equipment. During regular site visits, Tetra Tech field personnel continue to verify the entries in the form, including both the operating status and the presence of the required shelf spares. The equipment tracking form submitted to Tetra Tech on October 30, 2014, is attached (Attachment B).

GWETS Security

ETI continues to staff the GWETS using a single shift and follows the security procedure in the SOP dated April 30, 2014. During weekly calls, ETI notifies Tetra Tech of any issues with GWETS security. There were no issues reported in October.

Tetra Tech Activities

Tetra Tech conducted weekly calls with ETI to review operation of the GWETS on October 2, 9, 16, and 23. A call was not held the week of October 17 since Tetra Tech and ETI met in person at the site. Becki Dano, CEM, of Tetra Tech, performed visits to the GWETS on October 7, 10, 17, and 31. She checked permit and sampling forms to ensure each was correct and up-to-date, checked equipment status, and viewed shelf spare inventory.

Summary

Upon review of available and relevant information, Tetra Tech concurs with the management of the GWETS at this time. No additional involvement from either the Trust or Tetra Tech is recommended at this time.

Tables

Operational Metrics

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) ²	Chromium TR (mg/L) ²	Chromium(VI) (mg/L) ^{2,8}
SWF Total Extraction ⁵	517 ¹	11	0.02	Future Metric
AWF Total Extraction ⁵	289 ¹	163	0.44	Future Metric
IWF Total Extraction ⁶	68 ¹	1,002	7.20	Future Metric
GWTP Effluent ⁷	58	978	0.30	ND
GW-11 Influent	NA ³	NA ⁴	NA ⁴	Future Metric
GW-11 Effluent/ FBR Influent ⁷	931	113	0.11	0.08

Notes:

TR = Total Recoverable; NA = Not Available; ND = not detectable above laboratory detection limit (Chromium (VI) = 0.25 ug/L)

1: Sum of daily average flow for individual wells

2: All concentrations reported are monthly flow weighted averages

3: GW-11 is currently offline. Flow is a calculated metric, but will be transitioned to flow meter measurement beginning in 2015

4: Perchlorate and chromium can be calculated, but will be transitioned to in-line samples beginning in 2015

5: Perchlorate sampled monthly, chromium TR sampled quarterly, values reported from TestAmerica

6: Perchlorate and chromium TR sampled quarterly, values reported from TestAmerica

7: Perchlorate, chromium TR and chromium (VI) sampled weekly, values reported from TestAmerica

8: Hexavalent chromium will be analyzed and reported monthly beginning January 2015

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics		
Location ID	Perchlorate (lbs/month) ¹	Chromium TR (lbs/month) ¹
SWF Total Extraction	2,161	3
AWF Total Extraction	17,621	48
IWF Total Extraction	25,520	183
GWTP Effluent	21,239	7
GW-11 Influent	NA ²	NA ²
GW-11 Effluent/FBR Influent	39,075	37

Notes:

TR = Total Recoverable; NA = Not Available


1: Total lbs extracted is calculated from flow weighted average concentration and average flow (see Table 1)

2: GW-11 is currently offline

Figures

Operational Metrics

Figure 1 - Historical Perchlorate Mass Flux



Note: Total perchlorate shown on this graph was calculated from the sum of perchlorate extracted from wells. It should be noted that due to the accuracy of existing flow meters, this total may not align with total perchlorate reported in FBR influent flow.

Attachment A

NPDES Tracking Sheet (Prepared by ENVIRON)

Continuous		Daily samples, composited weekly		Weekly samples								Weekly samples, collected separately			Quarterly sample					
Flow Rate		Perchlorate		pH	Hexavalent Chromium	Total Chromium	Total Suspended Solids (TSS)		Total Iron		Total Ammonia as N		Total Phosphorus as P		BOD ₅ (inhibited)		Manganese			
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (ug/L)	30-Day Avg. (lbs/day)	30-Day Avg. (S.U.)	Daily Max. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)		30-Day Avg. (lbs/day)		30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	
1.45	1.75	18	0.22	6.5 to 9.0	0.01	0.1	135	1,634	10	121.03	40		20		25	40	254	5	60.52	
December 2013	1.30	1.34	1.3	0.014	6.98	0.00013	0.014	20	220	3.6	39	1.8		1.7		2.5	3.8	27		
January 2014	1.34	1.37	1.3	0.014	6.91	0.0013	0.036	28	320	4.2	47	5.3		3.3		4.2	5.2	47	0.57	6.5
February 2014	1.37	1.44	1.3	0.014	7.08	0.00013	0.020	19	220	2.9	33	10		3.2		5.2	9.9	58		
March 2014	1.38	1.48	1.3	0.014	6.98	0.00048	0.012	25	260	5.2	55	6		2.3		2.6	3.7	30		
April 2014	1.07	1.46	1.3	0.012	6.63	0.00029	0.028	17	170	3.8	37	2.2		1.9		4.3	6.3	44	0.15	1.6
May 2014	1.37	1.48	1.3	0.014	6.81	0.0013	0.012	19	220	3.3	38	8		3.1		3.1	3.4	35		
June 2014	1.31	1.37	1.3	0.014	6.69	0.00013	0.017	17	170	3.3	35	5		2.0		2.4	5.4	26		
July 2014	1.11	1.40	1.3	0.012	6.88	0.00013	0.020	32	290	6.7	61	2.2		3.2		4.3	5.4	40	0.24	2.0
August 2014	1.27	1.60	1.3	0.013	6.80	0.00013	0.034	20	210	3.9	41	2.8		2.1		3.2	5.7	33		
September 2014	1.16	1.32	1.3	0.012	6.73	0.00013	0.029	26	260	4.4	44	3		11		2.3	3.8	22		
October 2014 (month-to-date)	1.19	1.23	1.3	0.012	6.86	0.00013	0.026	15	150	2.9	29	11		6.2		3.4	4.5	34		

Daily Grab Sample Dates	Composite Sample Date	ug/L	lbs/day	Sample Date	S.U.	mg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	mg/L	lbs/day
12/1 - 12/7	12/7/2013	ND (<2.5)	1.3	0.014	12/2/2013	7.11	ND (<0.00025)	0.0031	39	430	4.2	46	ND (<0.10)	0.05	0.5	0.053	0.58	12/5/2013	1.4	15
12/8 - 12/14	12/14/2013	ND (<2.5)	1.3	0.013	12/9/2013	6.65	ND (<0.00025)	0.014	15	160	3.7	40	ND (<0.10)	0.05	0.5	0.089	0.95	12/11/2013	2.1	22
12/15 - 12/21	12/21/2013	ND (<2.5)	1.3	0.014	12/16/2013	7.08	ND (<0.00025)	0.014	12	130	3.2	35	ND (<0.10)	0.05	0.5	0.15	1.6	12/18/2013	3.1	34
12/22 - 12/28	12/28/2013	ND (<2.5)	1.3	0.014	12/23/2013	7.22	ND (<0.00025)	0.010	19	210	3.7	40	--	0.46	5.0	0.28	3.1	12/23/2013	3.8	41
12/29 - 1/4	1/4/2014	ND (<2.5)	1.3	0.014	12/30/2013	6.85	ND (<0.00025)	0.0075	14	150	3.3	36	--	0.23	2.5	0.21	2.3	12/30/2013	1.9	21
1/5 - 1/11	1/11/2014	ND (<2.5)	1.3	0.014	1/6/2014	6.91	ND (<0.00025)	0.015	21	230	3.7	41	--	0.17	1.9	0.26	2.9	1/8/2014	2.3	26
1/12 - 1/18	1/18/2014	ND (<2.5)	1.3	0.014	1/13/2014	7.31	ND (<0.00025)	0.0082	16	180	3.5	40	--	0.25	2.8	0.21	2.4	1/15/2014	4.5	51
1/19 - 1/25	1/25/2014	ND (<2.5)	1.3	0.014	1/20/2014	6.72	0.0013	0.036	60	680	5.8	65	--	0.97	11	0.42	4.7	1/22/2014	4.6	52
1/26 - 2/1	2/1/2014	ND (<2.5)	1.3	0.014	1/27/2014	6.69	ND (<0.00025)	0.0098	15	170	3.8	43	--	0.48	5.4	0.28	3.1	1/29/2014	5.2	58
2/2 - 2/8	2/8/2014	ND (<2.5)	1.3	0.014	2/3/2014	6.91	ND (<0.00025)	0.020	23	260	4.0	45	--	0.33	3.7	0.13	1.5	2/5/2014	4.6	52
2/9 - 2/15	2/15/2014	ND (<2.5)	1.3	0.014	2/10/2014	6.98	ND (<0.00025)	0.0047	22	250	3.0	34	--	0.94	11	0.33	3.7	2/12/2014	2.6	29
2/16 - 2/22	2/22/2014	ND (<2.5)	1.3	0.015	2/17/2014	7.25	ND (<0.00025)	0.0052	22	260	4.2	49	--	1.5	17	0.27	3.1	2/19/2014	9.9	110
2/23 - 3/1	3/1/2014	ND (<2.5)	1.3	0.015	2/24/2014	7.18	ND (<0.00025)	0.0043	10	120	0.30	3.5	--	0.58	6.8	0.39	4.6	2/26/2014	3.7	43
3/2 - 3/8	3/8/2014	ND (<2.5)	1.3	0.013	3/3/2014	6.91	ND (<0.00025)	0.0064	16	170	3.8	41	--	0.43	4.6	0.20	2.1	3/5/2014	2.4	26
3/9 - 3/15	3/15/2014	ND (<2.5)	1.3	0.015	3/10/2014	7.36	ND (<0.00025)	0.0051	54	630	9.8	114	--	1.6	19	0.28	3.3	3/12/2014	3.4	40
3/16 - 3/22	3/22/2014	ND (<2.5)	1.3	0.015	3/17/2014	6.87	ND (<0.00025)	0.0023	13	150	3.0	36	--	0.19	2.3	0.18	2.1	3/19/2014	1.0	12
3/23 - 3/29	3/29/2014	ND (<2.5)	1.3	0.015	3/24/2014	6.72	0.00048	0.0059	12	140	3.6	42	--	0.33	3.9	0.18	2.1	3/26/2014	3.7	44
3/30 - 4/5	4/5/2014	ND (<2.5)	1.3	0.0090	3/31/2014	7.04	ND (<0.00025)	0.012	30	220	5.9	42	ND (<0.10)	0.05	0.36	0.26	1.9	4/4/2014 ¹	NS	NS
4/6 - 4/12	4/12/2014	ND (<2.5)	1.3	0.0056	4/11/2014	6.61	0.00029	0.0096	15	70	3.4	15	ND (<0.10)	0.05	0.23	0.16	0.7	4/11/2014	3.4	15
4/13 - 4/19	4/19/2014	ND (<2.5)	1.3	0.015	4/14/2014	6.66	ND (<0.00025)	0.028	20	230	4.4	52	ND (<0.10)	0.05	0.59	0.22	2.6	4/16/2014	6.3	74
4/20 - 4/26	4/26/2014	ND (<2.5)	1.3	0.014	4/21/2014	6.62	ND (<0.00025)	0.012	15	170	3.5	40	--	0.51	5.9	0.20	2.3	4/23/2014	2.5	29
4/27 - 5/3	5/3/2014	ND (<2.5)	1.3	0.014	4/28/2014	6.62	ND (<0.00025)	0.012	17	200	3.7	43	--	0.18	2.1	0.16	1.9	4/30/2014	4.9	57
5/4 - 5/10	5/10/2014	ND (<2.5)	1.3	0.014	5/5/2014	6.77	ND (<0.00025)	0.0074	13	150	2.7	31	--	0.49	5.6	0.14	1.6	5/7/2014	2.8	32
5/11 - 5/17	5/17/2014	ND (<2.5)	1.3	0.014	5/12/2014	6.62	0.0013	0.0083	26	290	3.9	44	--	1.1	12	0.39	4.4	5/14/2014	3.0	34
5/18 - 5/24	5/24/2014	ND (<2.5)	1.3	0.014	5/19/2014	7.06	ND (<0.00025)	0.012	15	170	3.3	37	--	0.99	11	0.31	3.5	5/21/2014	3.4	38
5/25 - 5/31	5/31/2014	ND (<2.5)	1.3	0.014	5/27/2014	6.77	ND (<0.00025)	0.012	23	270	3.4	39	--	0.12	1.4	0.25	2.9	5/28/2014 ²	NS	NS
6/1 - 6/7	6/7/2014	ND (<2.5)	1.3	0.014	6/2/2014	6.85	ND (<0.00025)	0.010	18	200	3.1	34	--	1.3	14	0.52	5.6	6/4/2014	2.3	25
6/8 - 6/14	6/14/2014	ND (<2.5)	1.3	0.014	6/9/2014	6.69	ND (<0.00025)	0.0091	13	140	3.0	33	--	0.11	1.2	0.040	0.43	6/11/2014	1.2	13
6/15 - 6/21	6/21/2014	ND (<2.5)	1.3	0.014	6/16/2014	6.69	ND (<0.00025)	0.016	13	140	3.7	41	--	0.57	6.3	0.16	1.8	6/18/2014	0.86	10
6/22 - 6/28	6/28/2014	ND (<2.5)	1.3	0.013	6/23/2014	6.71	ND (<0.00025)	0.0062	10	110	2.0	21	--	0.11	1.2	0.070	0.75	6/25/2014	5.4	58
6/29 - 7/5 ³	7/5/2014	ND (<2.5)	1.3	0.012	6/30/2014 ³	6.50	ND (<0.00025)	0.017	29	280	4.8	47	ND (<0.10)	0.05	0.49	0.16	1.6	7/2/2014 ³	4.5	44
7/6 - 7/12 ³	7/12/2014	ND (<2.5)	1.3	0.012	7/8/2014 ³	6.77	ND (<0.00025)	0.0089	20	200	3.2	31	--	0.41	4.0	0.23	2.3	7/9/2014 ³	3.4	33
7/13 - 7/19	7/19/2014	ND (<2.5)	1.3	0.010	7/15/2014	6.85	ND (<0.00025)	0.020	34	280	8.3	69	ND (<0.10)	0.05	0.41	0.35	2.9	7/16/2014	4.5	37
7/20 - 7/26	7/26/2014	ND (<2.5)	1.3	0.012	7/21/2014	7.25	ND (<0.00025)	0.020	50	470	9.2	87	--	0.22	2.1	0.56	5.3	7/23/2014	3.7	35
7/27 - 8/2	8/2/2014	ND (<2.5)	1.3	0.012	7/28/2014	6.65	ND (<0.00025)	0.014	23	220	6.1	57	--	0.25	2.3	0.25	2.3	7/30/2014	5.4	51
8/3 - 8/9	8/9/2014	ND (<2.5)	1.3	0.013	8/4/2014	6.84	ND (<0.00025)	0.034	21	210	4.5	46	--	0.23	2.3	0.16	1.6	8/6/2014	5.7	58
8/10 - 8/16	8/16/2014	ND (<2.5)	1.3	0.014	8/11/2014	6.65	ND (<0.00025)	0.012	25	270	4.4	48	ND (<0.10)	0.05	0.54	0.18	2.0	8/13/2014	1.8	20
8/17 - 8/23	8/23/2014	ND (<2.5)	1.3	0.013	8/18/2014	6.87	ND (<0.00025)	0.0064	14	150	2.9	31	--	0.26	2.8	0.22	2.4	8/20/2014	2.8	30
8/24 - 8/30	8/30/2014	ND (<2.5)	1.3	0.014	8/25/2014	6.83	ND (<0.00025)	0.0059	20	220	3.7	40	--	0.49	5.4	0.21	2.3	8/27/2014	2.3	25
8/31 - 9/6	9/6/2014	ND (<2.5)	1.																	

Attachment B

Equipment Tracking Form

Sub-System	P&ID	Description	Status ¹	Checked	Notes
		Main Plant Equipment			
1		Seep Wells and Lift Station 1			
1.01		Seep Well Field, 9 wells	Running	X	All 9 wells in operation
1.02		Lift Station 1 Lift Pump A	Running	X	
1.03		Lift Station 1 Lift Pump B	Standby	X	
1.04		Area in and around Lift Station 1	Running	X	
2		Athens Road Wells and Lift Station 3			
2.01		Athens Road Well Field, 9 wells	Running	X	All 9 wells in operation/ New motor and pump installed ART-3b
2.02		Lift Station 3 Lift Pump A	Standby	X	
2.03		Lift Station 3 Lift Pump B	Running	X	
2.04		Area in and around Lift Station 3	Running	X	Well Art-7B now online/ testing flow with ART-7online with 7B to
3		Lift Station 2 and Transmission Piplines			
3.01		Influent Pipeline	In operation	X	
3.02		Effluent Pipeline	Running	X	
3.03		Lift Station 2 Lift Pump A	Running	X	
3.04		Lift Station 2 Lift Pump B	Standby	X	
3.05		Area in and around Lift Station 2	Running	X	
4		Interceptor Wells and Cr Treatment Plant			
4.01		IWF Well Field, 30 wells	Running	X	27 wells online
4.02		Ferrous Sulfate Feed System	Running	X	
4.03		Polymer Feed System	Running	X	
4.04		Clarifier	In operation	X	
4.05		Filter Press	Running	X	Maintenance needed for the ram head. In process of
4.06		GWTP Effluent Tank	In operation	X	
4.07		Interceptor Booster Pump A	Standby	X	
4.08		Interceptor Booster Pump B	Running	X	
4.09		Area In And Around GWTP	Running	X	In the process of replacing sump with new pump.
5		Equalization Area and GW-11 Pond			
5.01	PID10A	Pond GW-11	In operation	X	
5.02	PID10A	Pond Water Pump - P101A	Off	X	
5.03	PID10A	Pond Water Pump - P101B	Off	X	
5.04	PID10A	Equalization Tanks	In operation	X	
5.05	PID10A	Raw Water Feed Pump - P102A	Running	X	
5.06	PID10A	Raw Water Feed Pump - P102B	Standby	X	Repaired pump installed and online.
5.07	PID10B	Carbon Absorber - LGAC 201A	Running	X	

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

5.08	PID10B	Carbon Absorber - LGAC 201B	Running	X	
5.09	PID10B	Carbon Absorber - LGAC 201C	Standby	X	

¹Status Codes

- Running - Unit is in operation
- Standby - Spare or duplicate, not currently in operation
- Maintenance - Out of service for maintenance
- Off - Not currently needed for use, but can be placed in service

6		First Stage FBRs A, 1 & 2		
6.01	PID14	FBR A	Running	X
6.02	PID14	Separator Tank - 1401	Running	X
6.03	PID14	Media Return Pump - P 1401	Running	X
6.04	PID14	P1401A	Standby	X
6.05	PID01A	P1401B	Running	X
6.06	PID01A	FBR 1	Running	X
6.07	PID02A	FBR 2	Running	X
6.08	PID01A	First Stage Separator Tank - T2011	Running	X
6.09	PID01A	Media Return Pump - P2011	Running	X
6.10	PID01A	First Stage FBR Pump - P1011	Standby	X
6.11	PID01A	First Stage FBR Pump - P1012	Running	X
6.12	PID01A	First Stage FRB Pump - P101A	Running	X
6.13	PID07A	FBR A pH Feed Pump - P71A	Standby	X
6.14	PID07A	FBR 1 pH Feed Pump - P711	Standby	X
6.15	PID07A	FBR 2 pH Feed Pump - P712	Standby	X
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off	X
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off	X
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off	X
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running	X
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running	X
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running	X
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running	X
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running	X
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running	X
7		First Stage FBRs 3 & 4		
7.01	PID01B	FBR 3	Off	X
7.02	PID01B	FBR 4	Off	X
7.03	PID02B	First Stage Separator Tank - T2012	Off	X
7.04	PID01B	Media Return Pump - P2012	Off	X
7.05	PID01B	First Stage FBR Pump - P1013	Off	X
7.06	PID01B	First Stage FRB Pump - P1014	Off	X
7.07	PID01B	First Stage FBR Pump - P102A	Off	X
7.08	PID07A	FBR 3 pH Feed Pump - P713	Off	X
7.09	PID07A	FBR 4 pH Feed Pump - P714	Off	X
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723	Off	X
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off	X
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Off	X

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

7.13	PID15	<i>FBR 4 Nutrient (Phos Acid) Feed Pump - P1524</i>	Off	X	
7.14	PID07B	<i>FBR 3 Electron Donor Assembly Pump - P733</i>	Off	X	
7.15	PID07B	<i>FBR 4 Electron Donor Assembly Pump - P734</i>	Off	X	

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

7					
Second Stage FBRs 5 & 6					
8.01	PID03A	FBR 5	Off	X	Installing new nozzles and laterals. No damage found on internal
8.02	PID03A	FBR 6	Off	X	
8.03	PID03C	Second Stage Separator Tank - T3011	Off	X	
8.04	PID03A	Media Return Pump - P3011	Off	X	
8.05	PID03A	Second Stage FBR Pump - P3015	Off	X	
8.06	PID03A	Second Stage FBR Pump - P3016	Off	X	
8.07	PID03A	Second Stage FBR Pump - P301A	Off	X	
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off	X	
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off	X	
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off	X	
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off	X	
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Off	X	
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Off	X	
9					
Second Stage FBRs 7 & 8					
9.01	PID03B	FBR 7	Running	X	
9.02	PID03B	FBR 8	Running	X	
9.03	PID03D	Second Stage Separator Tank - T3012	Running	X	
9.04	PID03B	Media Return Pump - P3012	Running	X	Line unclogged on discharge side of pump.
9.05	PID03B	Second Stage FBR Pump - P3017	Standby	X	
9.06	PID03B	Second Stage FBR Pump - P3018	Running	X	
9.07	PID03B	Second Stage FBR Pump - P302A	Running	X	
9.08	PID07A	FBR 7 pH Feed Pump - P717	Standby	X	
9.09	PID07A	FBR 8 pH Feed Pump - P718	Standby	X	
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off	X	
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off	X	
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running	X	
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running	X	

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

10		Aeration and DAF System			
10.01	PID04	Aeration Tank	In operation	X	
10.02	PID04	Aeration Blower - B401	Running	X	
10.03	PID04	Biofilter	In operation	X	
10.04	PID04	Nutrient Solution	Running	X	
10.05	PID04	Biofilter Sump	Running	X	
10.06	PID04	Nutrient Pump - P401	Running	X	
10.07	PID04	Biofilter Sump Pump - P402A	Standby	X	
10.08	PID04	Biofilter Sump Pump - P402B	Off	X	Only one pump in place
10.09	PID04	Biofilter Blower	Running	X	
10.10	PID05	DAF Pressure Tanks	In operation	X	
10.11	PID05	DAF Vessel - D501	Running	X	
10.12	PID05	DAF Pressure Pump - P501	Running	X	
10.13	PID05	DAF Float Pump - P502	Running	X	
10.14	PID05	DAF Vessel - D551	Running	X	
10.15	PID05	DAF Pressure Pump - P551	Running	X	Bypassing steel arilines with hose feeding the pressure tank.
10.16	PID05	DAF Float Pump - P552	Running	X	
10.17	PID05	Screw Conveyer Drive	Standby	X	
10.18	PID05	Skimmer Drive	Running	X	
11		Pumping System (Old Effluent)			
11.01	PID06	Effluent Tank 601	In operation	X	
11.02	PID06	Effluent Pump - P601	Maintenance	X	New mechanical seal to arrive week of 10/31/14
11.03	PID06	Effluent Pump - P602	Running	X	
12		Sand Filter System			
12.01	PID17	Sand Filter	Running	X	
12.02	PID17	Filter Reject Tank	In operation	X	New positioner being ordered
12.03	PID17	Filter Reject Pump - P1701A	Running	X	
12.04	PID17	Filter Reject Pump - P1701B	Standby	X	
13		Effluent Tank and Pumping			
13.01	PID10C	UV Effluent Tank	Running	X	
13.02	PID10C	Effluent Booster Pump - P1302A	Running	X	
13.03	PID10C	Effluent Booster Pump - P1302B	Standby	X	

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

14		Solids Collection and Pressing System			
14.01	PID16	Sludge Storage Tank	In operation	X	
14.02	PID16	Solids Storage Effluent Pump - P1601	Running	X	
14.03	PID16	Solids Cond. Tank	In operation	X	Large debris found in tank inhibiting proper flow through pump.
14.04	PID09	Sludge Mixer	Running	X	
14.05	PID09	Filter Press Pump - P901	Running	X	
14.06	PID09	Filter Press Pump - P902	Standby	X	Replacement kits on order
14.07	PID09	West Press	Off	X	
14.08	PID09	East Press	Running	X	
14.09	PID09	Filtrate Tank	In operation	X	
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running	X	
		Chemical Systems			
15		Electron Donor System			
15.01	PID07B	Electron Donor Tank	In operation	X	
15.02	PID07B	Booster Pump P739A	Running	X	
15.03	PID07B	Booster Pump P739B	Standby	X	
17	PID07C	Micro Nutrient System	In operation	X	
18	PID07C	Hydrogen Peroxide System	In operation	X	
19	PID07C	De-Foam System	In operation	X	
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation	X	
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation	X	
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation	X	
23	PID07C	Ferric Chloride System	In operation	X	
24	PID07B	Polymer Systems - DAF	In operation	X	New pump heads on order
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation	X	

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Utility Systems					
26		Compressed Air System			
26.01	PID08	West Compressor	Running	X	
26.02	PID08	East Compressor	Running	X	
26.03	PID08	O2 Compressor	Running	X	
26.04	PID08	Compressed Air Receiver Tank	In operation	X	
26.05	PID08	Air Dryer	Running	X	
26.06	PID08	Oil Removal Filter	In operation	X	
26.07	PID08	Particulate Filter	In operation	X	
27	PID16	Oxygen System	In operation	X	
28		GWETS Plant Controls/ Siemens Controls	In operation	X	
29		Well Control System/ Allen Bradley Controls	In operation	X	
30		MCC FBR Pad	In operation	X	Matrix will be onsite on Nov. 10th to repair panel view
31		MCC in D-1	In operation	X	Hampton Tedder installed recorders in attempt to identify
32		MCC in EQ area	In operation	X	
Miscellaneous Systems					
33		Operations Office/Network	In operation	X	
34		Laboratory Analyzers	In operation	X	
35		Security Systems	In operation	X	
Shelf Spares					
		Media Return Pump Rebuild Kit	In stock	X	
		pH Feed Pump	In stock	X	
		Nutrient Feed Pump	In stock	X	
		Electron Donor Feed Pump	In stock	X	
		Phosphoric Acid Feed Pump	In stock	X	
		Interceptor Well Pumps (4 each)	In stock	X	
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock	X	
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock	X	More boreline fittings and 3hp motor on order.

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service