



---

**To:** Nevada Division of Environmental Protection  
Nevada Environmental Response Trust

---

**Cc:** Nevada Environmental Response Trust Stakeholders

---

**From:** Jeff Lance

---

**Date:** April 28, 2016

---

**Subject:** NERT – GWETS Operation Monthly Report – March 2016

---

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies Inc. (ETI) provides this summary of the groundwater extraction and treatment system (GWETS) operation and performance during March 2016.

### Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS normally in March 2016. The flow rate to the plant averaged approximately 908 gallons per minute (gpm) during March 2016. At the end of the month, the GW-11 Pond volume was at 43.66 million gallons (MG), which would allow 13.04 days of available additional storage in event of an emergency plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond increased approximately 0.2 MG from the end of February. Figure 1 in this report depicts the actual and projected GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the FBR plant averaged 84 mg/L for the month, with a maximum concentration of 97 mg/L.

Analytical data indicate that the permitted effluent discharges at GWETS Outfall 001 were within the NPDES permitted numerical discharge limits (Please see Attachment A, prepared by Ramboll Environ).

### Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics that provide data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 presents historical perchlorate and chromium mass flux.



## Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Henderson, Nevada Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

### 1. GW-11 Pond

- GW-11 Pond Leak Detection System: ETI was able to dislodge and lower the NE corner sump pump an additional 20 feet, to a total depth of approximately 115 feet. An obstruction in the casing prevented it from going any further.
- ETI installed three of the four dedicated generators at each pond corner to reduce the effort required to complete the leak detection pumping procedures. The remaining generator will be installed after a protective cover is fabricated, which is scheduled to occur in April, 2016.

### 2. Biological Plant

- There were no significant Plant interruptions or unplanned diversions for the month of March that met the immediate NEDP Notification Requirements.
- Plant Recycle/Power Outage, Mar. 08, 2016: Flow to the plant was switched from GW11 to Tanks 101 that receive flow from LS2. A planned power outage was scheduled for this day to repair the overhead power lines that feed the onsite laboratory and stopped our ability to monitor the influent to the plant. Due to ETI's inability to monitor the influent there was a potential of high perchlorate loading from LS2 that could have upset the FBR's so the plant was put in recycle mode for the duration of the outage – 5hr 37 min.
- Diversion to GW11, Mar 10, 2016: The Plant's operating communication system was disrupted due to a faulty PLC in the main server which caused the plant to shut down. The effluent flow was diverted to GW11 until the plant could be brought back online. The event lasted 1hr 37min and 92,926 gals were diverted to GW11.
- Plant Recycle for Maintenance, Mar. 17, 2016: Plant put in recycle mode for maintenance work on the sand filter. The event lasted 1hr 55 min.
- Diversion to GW11 for Maintenance, Mar 28, 2016: Effluent flow was diverted to allow for the GAC valves to be repaired. The event lasted 2hrs 17min and 77,077 gals were diverted to GW11.
- Diversion to GW11 for Maintenance, Mar 28, 2016: Effluent flow was diverted to allow for repair of the check valve in the discharge pipeline. The event lasted 1hr 45min and 70,875 gals were diverted to GW11

### 3. Spills

- No reportable spills occurred in March 2016.

### 4. Maintenance

- Major maintenance performed by ETI in the month included:
  - i. Repaired overhead power lines from D1 building and secured power pole with new guy wire
  - ii. South DAF was sand blasted to remove coating and performed an inspection that revealed numerous repairs needed on the sides and bottom of the tank.
  - iii. South DAF repairs made to the tank, interior recoated, auger removed and serviced. The DAF will be put back in service following installation of the new pressure tank.
  - iv. Pressure tanks for both North and South DAF's are leaking and corroded and require replacement. New tanks were ordered and are scheduled to be installed the first week of June, 2016.
  - v. The sand filter was taken offline to perform repairs to the header, air lifts and return pump.
  - vi. FBR 8 repairs were completed, vessel sealed and wet tested, ready to be returned to service.
  - vii. FBR 7 is being drained in preparation for an inspection and repair as needed.
  - viii. A design is being prepared to install an inductor style pump to replace the existing diaphragm Media Return pumps that have ongoing maintenance issues.
- Preventative Maintenance completed or being performed by ETI in the month included:
  - i. Replace all of the influent and effluent control valves on the GAC Tanks.
  - ii. Trouble shooting of the flow meters and totalizers on the IWF wells along with LS2 flow meter
  - iii. Serviced the combination valves on the effluent pipeline.
  - iv. Replaced PLC in the primary server in the control room.
- Outstanding or ongoing maintenance and repairs from the previous month are outlined below:
  - i. FBR 7 is off-line and currently in the rehabilitation process. All forward flow is being sent to FBRs 5 and 6, on-going from last month.

### **GWETS Upgrades and Facility Projects**

The following is a summary of the initiatives in-progress during the reporting period at the direction of the Trust:

#### 1. AP-5 Solids Removal

Tetra Tech is moving forward with the design to relocate the AP-5 pond solids to three large tanks for washing to remove perchlorate salts, with eventual treatment of the perchlorate containing wash water in the GWETS. The tanks have been ordered, and site subgrade preparation will begin in April, 2016. Pumping tests are planned for April, 2016.



2. Enhanced Operational Metrics  
No change in status from the last reporting period.
3. GWETS Data Accessibility (GWETS/NET)  
No change in status from the last reporting period.
4. GW-11 Pond Level monitoring  
Tetra Tech has finalized design drawings and is preparing to install a pressure transducer and associated equipment to provide continuous monitoring of the water elevation in the GW-11 pond. The equipment will include a display at the EQ area and transmit water level data to the control room in the D1 Bldg. Contractor bids have been received and system installation is planned for May 2016.
5. GWETS Discharge Flow Evaluation  
Tetra Tech is preparing to conduct a capacity evaluation of the GWETS discharge pipeline. The evaluation will include modeling followed by pumping and flow rate measurement over a range of discharge rates to validate model results. Field testing is scheduled of late May 2016.

### **Equipment Availability Tracking**

ETI operators continue to update the equipment tracking form on a weekly basis at a minimum, or whenever there is a change in the status of key equipment. During regular site visits, Tetra Tech field personnel verify the entries on the form, including both the operating status and confirmation of the inventory of required shelf spares. The equipment tracking form is included as Attachment B.

### **GWETS Staffing**

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).



# Tables

## Operational Metrics

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) <sup>2</sup>	Chromium (TR) (mg/L) <sup>2</sup>	Chromium(VI) (mg/L) <sup>2</sup>
SWF Total Extraction <sup>3</sup>	538 <sup>1</sup>	8	0.001	0.007
AWF Total Extraction <sup>3</sup>	258 <sup>1</sup>	129	0.36	0.452
IWF Total Extraction <sup>3</sup>	53 <sup>1</sup>	696	8.98	7.074
GWTP Effluent <sup>4</sup>	55	685	0.18	ND
GW-11 Influent	23	81	0.04	0.026
GW-11 Effluent/ FBR Influent <sup>4</sup>	908	85	0.07	0.055

## Notes:

TR = Total Recoverable; ND = not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Sum of daily average flow for individual wells.

2: All concentrations reported are monthly flow weighted averages.

3: Perchlorate and chromium TR sampled monthly, values reported from TestAmerica.

4: Perchlorate, chromium TR and chromium (VI) sampled weekly, values reported from TestAmerica.

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) <sup>1</sup>	Chromium (TR) (lbs/month) <sup>1</sup>	Chromium (VI) (lbs/month) <sup>1</sup>
SWF Total Extraction	1,546	0.2	1.3
AWF Total Extraction	12,484	35	44
IWF Total Extraction	13,797	178	140
GWTP Effluent	14,077	3.7	0.0
GW-11 Influent <sup>2</sup>	695	0.3	0.2
GW-11 Effluent/FBR Influent <sup>2</sup>	28,636	23	19

## Notes:

TR = Total Recoverable.

1: Total lbs extracted is calculated from flow weighted average concentration and average flow (see Table 1).

2: GW-11 was being bypassed from 3/2/16 through 3/31/16




## Figures Operational Metrics



Figure 1 – GW11 Volume Graph


Nevada Environmental Response Trust  
 GW-11 Pond Volume  
 Projected v. Actual  
 Update 3/30/2016



Notes:

- 1: Monthly GW-11 withdrawals exceed influent flows by approximately 50 gpm.
- 2: Monthly GW-11 withdrawals exceed influent flows by approximately 20 gpm with seasonally changing influent additions each month (ie.- higher GAC backwash volume in summer).
- 3: Monthly GW-11 withdrawals exceed influent flows by approximately 50 gpm with an assumed 2.8 million gallons of influent additions each month.
- 4: Monthly evaporation was calculated using Shevenell, 1996. Statewide Potential Evapotranspiration Maps for Nevada. Nevada Bureau of Mines and Geology Report 48. University of Nevada Reno.
- 5: Average monthly rainfall was estimated from rain gage 4774 data on TIMET property.

Figure 2 - Historical Perchlorate Mass Flux



Note: Total perchlorate shown on this graph was calculated from the sum of perchlorate extracted from wells. It should be noted that due to the accuracy of existing flow meters, this total may not align with total perchlorate reported in FBR influent flow.



Attachment A  
NPDES Tracking Sheet (Prepared by ENVIRON)

Continuous		Daily samples, composited weekly	
Flow Rate		Perchlorate	
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (ug/L)	30-Day Avg. (lbs/day)
1.45	1.75	18	0.22

Weekly samples								
pH	Hexavalent Chromium	Total Chromium	Total Suspended Solids (TSS)		Total Iron		Total Ammonia as N	Total Phosphorus as P
30-Day Avg. (S.U.)	Daily Max. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)
6.5 to 9.0	0.01	0.1	135	1,634	10	121.03	40	20

Weekly samples, collected separately			Quarterly sample	
BOD <sub>5</sub> (inhibited)			Manganese	
30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)
25	40	254	5	60.52

December 2015	1.32	1.43	1.3	0.014	6.94	0.00013	0.011	16	170	2.2	24	3.7	0.6	8	20	92		
January 2016	1.28	1.39	1.3	0.014	6.89	0.00013	0.022	24	250	4.5	47	9	0.25	5.8	6.5	61	0.26	2.9
February 2016	1.34	1.41	1.3	0.015	6.96	0.00013	0.015	20	230	3.6	41	6	0.62	3.9	6.0	43		
March 2016 (month to date)	1.39	1.45	1.3	0.015	6.88	0.00013	0.026	21	250	3.2	37	13	2.1	4.3	5.8	50		

Daily Grab Sample Dates	Composite Sample Date	ug/L	lbs/day	Sample Date	S.U.	mg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	mg/L	lbs/day			
11/29 - 12/5	12/5/2015	ND (<2.5)	1.3	0.014	11/30/2015	7.00	ND (<0.00025)	0.014	21	239	4.4	50	ND (<0.10)	0.05	0.57	ND (<0.025)	0.013	0.14	12/2/2015	7.7	88		
12/6 - 12/12	12/12/2015	ND (<2.5)	1.3	0.012	12/7/2015	6.85	ND (<0.00025)	0.0082	19	190	3.5	35	--	0.23	2.3	ND (<0.025)	0.013	0.12	12/9/2015	4.2	42		
12/13 - 12/19	12/19/2015	ND (<2.5)	1.3	0.015	12/14/2015	6.86	ND (<0.00025)	0.0075	18	211	1.8	21	--	0.81	9.5	--	0.11	1.3	12/16/2015	1.8	21		
12/20 - 12/26	12/26/2015	ND (<2.5)	1.3	0.014	12/21/2014	7.10	ND (<0.00025)	0.0090	19	208	3.1	34	--	0.14	1.5	--	0.036	0.39	12/23/2015	7.4	81		
12/27 - 1/2	1/2/2016	ND (<2.5)	1.3	0.014	12/29/2015	6.94	ND (<0.00025)	0.011	6.6	75	0.51	5.8	--	0.14	1.6	--	0.060	0.68	12/30/2015	20	227		
1/3 - 1/9	1/9/2016	ND (<2.5)	1.3	0.013	1/4/2016	6.92	ND (<0.00025)	0.0070	18	193	3.9	42	--	0.32	3.4	--	0.028	0.30	1/6/2016	5.7	61		
1/10 - 1/16	1/16/2016	ND (<2.5)	1.3	0.014	1/11/2016	7.02	ND (<0.00025)	0.022	25	260	5.0	52	--	1.8	19	ND (<0.025)	0.013	0.13	1/13/2016	6.5	68		
1/17 - 1/23	1/23/2016	ND (<2.5)	1.3	0.013	1/19/2016	6.62	ND (<0.00025)	0.016	30	311	5.1	53	--	0.96	10	ND (<0.025)	0.013	0.13	1/20/2016	6.0	62		
1/24 - 1/30	1/30/2016	ND (<2.5)	1.3	0.014	1/25/2016	7.01	ND (<0.00025)	0.014	23	255	3.8	42	--	0.19	2.1	--	0.040	0.44	1/27/2016	4.8	53	0.26	2.9
1/31 - 2/6	2/6/2016	ND (<2.5)	1.3	0.014	2/1/2016	6.94	ND (<0.00025)	0.015	35	394	4.5	51	--	0.18	2.0	--	0.059	0.66	2/3/2016	6.0	68		
2/7 - 2/13	2/13/2016	ND (<2.5)	1.3	0.015	2/9/2016	7.18	ND (<0.00025)	0.013	16	181	3.8	43	--	0.98	11	--	0.059	0.67	2/10/2016	2.5	28		
2/13 - 2/20	2/20/2016	ND (<2.5)	1.3	0.015	2/15/2016	6.82	ND (<0.00025)	0.0092	14	158	2.8	32	--	0.33	3.7	--	0.048	0.54	2/17/2016	3.4	38		
2/21 - 2/27	2/27/2016	ND (<2.5)	1.3	0.015	2/22/2016	6.91	ND (<0.00025)	0.013	16	181	3.4	38	--	0.50	5.6	--	0.054	0.61	2/24/2016	3.5	40		
2/28 - 3/5	3/5/2016	ND (<2.5)	1.3	0.014	3/1/2016	7.11	ND (<0.00025)	0.0092	12	132	2.0	22	--	1.9	21	--	0.062	0.68	3/2/2016	3.3	36		
3/6 - 3/12	3/12/2016	ND (<2.5)	1.3	0.015	3/7/2016	6.91	ND (<0.00025)	0.012	18	202	2.6	29	--	1.4	16	--	0.096	1.1	3/9/2016	2.7	30		
3/13 - 3/19	3/19/2016	ND (<2.5)	1.3	0.015	3/14/2016	6.68	ND (<0.00025)	0.026	33	388	4.1	48	--	0.71	8.3	--	0.23	2.7	3/16/2016	5.8	68		
3/20 - 3/26	3/26/2016	NA	NA	NA	3/21/2016	6.81	ND (<0.00025)	0.023	22	260	4.1	48	--	0.45	5.3	--	0.32	3.8	3/23/2016	5.5	65		
3/27 - 4/2	4/2/2016	NA	NA	NA	3/28/2016	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	3/30/2016	NA	NA		
					4/4/2016	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	4/6/2016	NA	NA		

Note: All analytical responsibilities are performed by TestAmerica Laboratories, Inc. (TestAmerica) in Irvine, California, unless otherwise indicated.

NA = Not Available To Date

ND = Not Detected above laboratory reporting limit; concentration in adjacent cell to right is one-half the reporting limit (per Permit condition)

-- = Analyte detected; see column adjacent to right

Last Updated: April 8, 2016



Attachment B  
Equipment Tracking Form

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>Main Plant Equipment</b>						
<b>1 Seep Wells and Lift Station 1</b>						
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running			
1.03		Lift Station 1 Lift Pump B	Standby			
1.04		Area in and around Lift Station 1	Running		3	Replaced worn valve at sample port on PC-120
<b>2 Athens Road Wells and Lift Station 3</b>						
2.01		Athens Road Well Field, 9 wells	Running		2	Short in wiring supplying power to ART-9. Ran a jumper from 7b to bring the well back online. Contractors are completing the work to include pulling new wire. Pump and motor are in working order.
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running			
<b>3 Lift Station 2 and Transmission Pipelines</b>						
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running		3	Replaced two combo valves on the pipeline, removed debris from enclosures.
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running			
<b>4 Interceptor Wells and Cr Treatment Plant</b>						
4.01		IWF Well Field, 30 wells	Running			
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation			
4.05		Filter Press	Running			
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Running		3	Replaced flex coupling connecting motor to pump
4.08		Interceptor Booster Pump B	Standby			
4.09		Area In And Around GWTP	Running		3	Removed flowmeter and inspected for proper operation. No faults found. Flowmeter in-service.

<sup>1</sup>Status Codes

- Running - Unit is in operation
- Standby - Spare or duplicate, not currently in operation
- Maintenance - Out of service for maintenance
- Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>5</b>		<b>Equalization Area and GW-11 Pond</b>				
5.01	PID10A	Pond GW-11	In operation			
5.02	PID10A	Pond Water Pump - P101A	Standby			
5.03	PID10A	Pond Water Pump - P101B	Standby		3	New seal received. Tentative plan in place. Pump still operational.
5.04	PID10A	Equalization Tanks	In operation			
5.05	PID10A	Area in and Around EQ	In operation		2	Replaced damaged 4" butterfly valve supplying SLW to Tronox.
5.06	PID10A	Raw Water Feed Pump - P102A	Running			
5.07	PID10A	Raw Water Feed Pump - P102B	Standby			
5.08	PID10A	F-101 Filters	Standby			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running			
<b>6</b>		<b>First Stage FBRs A, 1 &amp; 2</b>				
6.01	PID14	FBR A	Running			
6.02	PID14	Separator Tank - 1401	Running			
6.03	PID14	Media Return Pump - P 1401	Running			
6.04	PID14	P1401A	Standby			
6.05	PID01A	P1401B	Running			
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012	Running			
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			

<sup>1</sup>Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
<b>7</b>		<b>First Stage FBRs 3 &amp; 4</b>				
7.01	PID01B	FBR 3	Off			
7.02	PID01B	FBR 4	Off			
7.03	PID02B	First Stage Separator Tank - T2012	Off			
7.04	PID01B	Media Return Pump - P2012	Off			
7.05	PID01B	First Stage FBR Pump - P1013	Off			
7.06	PID01B	First Stage FRB Pump - P1014	Off			
7.07	PID01B	First Stage FBR Pump - P102A	Off			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Off			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Off			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723	Off			
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Off			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Off			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Off			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Off			
<b>8</b>		<b>Second Stage FBRs 5 &amp; 6</b>				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running		3	Replaced worn airline tubing for the in bed cleaners
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running		3	Replaced belt
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			

<sup>1</sup>Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service



Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>9</b>		<b>Second Stage FBRs 7 &amp; 8</b>				
9.01	PID03B	FBR 7	Off		4	FBR drained and opened. Finishing the removal of carbon to inspect the nozzles and headers.
9.02	PID03B	FBR 8	Off		4	Wet test complete.
9.03	PID03D	Second Stage Separator Tank - T3012	Off			
9.04	PID03B	Media Return Pump - P3012	Off			
9.05	PID03B	Second Stage FBR Pump - P3017	Off			
9.06	PID03B	Second Stage FBR Pump - P3018	Off			
9.07	PID03B	Second Stage FBR Pump - P302A	Off			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Off			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Off			
<b>10</b>		<b>Aeration and DAF System</b>				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Biofilter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Biofilter Sump	Running			
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Biofilter Sump Pump - P402A	Standby			
10.09	PID04	Biofilter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation		3	Replaced worn regulator for the N.DAF air supply to pressure tank.
10.11	PID05	DAF Vessel - D501	Maintenance		2	Vessel ready to be put back into service.
10.12	PID05	DAF Pressure Pump - P501	Maintenance			
10.13	PID05	DAF Float Pump - P502	Standby			
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running			
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			

<sup>1</sup>Status Codes

- Running - Unit is in operation
- Standby - Spare or duplicate, not currently in operation
- Maintenance - Out of service for maintenance
- Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>11</b>		<b>Pumping System (Old Effluent)</b>				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602	Standby			
<b>12</b>		<b>Sand Filter System</b>				
12.01	PID17	Sand Filter	Maintenance		2	Sand filter back online. Tightened header, re secured boots connecting airlifts, flushed tank with SLW.
12.02	PID17	Filter Reject Tank	Out of service			
12.03	PID17	Filter Reject Pump - P1701A	Maintenance		3	Pulled volute to repair inside of the casing.
12.04	PID17	Filter Reject Pump - P1701B	Running			
<b>13</b>		<b>Effluent Tank and Pumping</b>				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			
13.04	PID10C	Area Around Effluent and North D-1	Running			
<b>14</b>		<b>Solids Collection and Pressing System</b>				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation			
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902	Running			
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			

<sup>1</sup>Status Codes

- Running - Unit is in operation
- Standby - Spare or duplicate, not currently in operation
- Maintenance - Out of service for maintenance
- Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>Chemical Systems</b>						
<b>15</b>		<b>Electron Donor System</b>				
15.01	PID07B	Electron Donor Tank	In operation			
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17.00	PID07C	Micro Nutrient System	In operation			
18.00	PID07C	Hydrogen Peroxide System	In operation			
19.00	PID07C	De-Foam System	In operation			
20.00	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21.00	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22.00	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23.00	PID07C	Ferric Chloride System	In operation			
24.00	PID07B	Polymer Systems - DAF	In operation			
25.00	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
<b>Utility Systems</b>						
<b>26</b>		<b>Compressed Air System</b>				
26.01	PID08	West Compressor	Running		2	Oil added for cooling. Ingersoll Rand to investigate where leak is.
26.02	PID08	East Compressor	Running		2	New contactor and overload switch replaced. Compressor ready for service.
26.03	PID08	O2 Compressor	Running			
26.04	PID08	Compressed Air Receiver Tank	In operation			
26.05	PID08	Air Dryer	Running			
26.06	PID08	Oil Removal Filter	In operation			
26.07	PID08	Particulate Filter	In operation			
27.00	PID16	Oxygen System	In operation			
28.00	PID16	GWETS Plant Controls/ Siemens Controls	In operation			
29.00	PID16	Well Control System/ Allen Bradley Controls	In operation			
30.00	PID16	MCC FBR Pad	In operation			
31.00	PID16	MCC in D-1	In operation			
32.00	PID16	MCC in EQ area	In operation			

<sup>1</sup>Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>Miscellaneous</b>						
33.00		Operations Office/Network	In operation			
34.00		Laboratory Analyzers	In operation			
35.00		Security Systems	In operation			
<b>Shelf Spares</b>						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			

<sup>1</sup> Status Codes

**Equipment**

Running                    Unit is in operation  
 Standby                   Duplicate or installed spare, not currently operating  
 Maintenance            Out for repairs or maintenance

Off                            Not currently needed, but available

<sup>1</sup> Criticality Codes

1 = Critical            Cannot continue with operation until repairs made  
 2 = Important        Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate        Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low                - Tasks performed to either improve the existing equipment (i.e., testing new options)

- Minor repairs that in no way alter the performance of the plant

**Tanks, Pipelines, Ponds**

In operation  
 Out of service

**Spares**

In stock

<sup>1</sup> Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service