

---

**To:** Nevada Division of Environmental Protection  
Nevada Environmental Response Trust

---

**Cc:** Nevada Environmental Response Trust Stakeholders

---

**From:** Ryan Sullivan, Vice President Service and O&M

---

**Date:** June 20, 2020

---

**Subject:** NERT – GWETS Operation Monthly Report – May 2020

---

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during May 2020.

### Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in May 2020. Flow from PC-119, PC-120, PC-121, and PC-133 was routed to the IX system, bypassing all flow meters associated with the FBR plant. The flow rate to the IX system averaged approximately 181 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 1,065 gpm during May 2020. At the end of the month, the GW-11 Pond volume was at 36.0 million gallons (MG), which would allow 18.4 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond decreased by 3.7 MG from the end of April 2020. Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 0.37 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 86 mg/L for the month, with a maximum concentration of 89 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of April 2020 averaged 77 mg/L, with a maximum concentration of 81 mg/L. Fluctuations in the influent perchlorate concentrations are due to the changes in the AP-5 treatment feed rate and not a result of groundwater changes.

### Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. These tables also include data associated with the AP-5 decant liquids. Figure 2 graphically presents historical perchlorate and chromium mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

## Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

### 1. GW-11

There were no operational issues with GW-11 in the month of May.

### 2. Biological Plant

Treatment of AP-5 water through the FBR Biological plant resumed in the month of May. Treatment began the month with a flow rate of 5.0 gpm and increasing to 6.0 gpm by the end of the month.

There were influent / effluent diversions during the reporting period generally associated with maintenance activities as well as extraction well short-term shutdown events. Below is a description of the events that occurred:

#### Diversion Events / Well Shutdowns

- Effluent diversion to GW-11 occurred on May 7, 2020 from 1:59pm to 3:43pm as a precautionary measure due to concerns of effluent quality. Adjustments were made to the process and flow returned to the outfall. Approximately 120,000 gallons of effluent were diverted to GW-11.
- Influent diversion to GW-11 occurred on May 28, 2020 from 6:45am to 1:50pm due to maintenance efforts. Approximately 87,000 gallons of water was diverted to GW-11.
- Effluent diversion to GW-11 occurred on May 28, 2020 from 2:25pm to May 29, 2020 at 6:38am due to maintenance efforts associated with repairs to the effluent pipeline. Approximately 1,033,000 gallons of effluent were diverted to GW-11.

### 3. Spills

There were no reportable spills in the month of May.

### 4. Maintenance

- Major maintenance performed by ETI in the month included:
  - I. Replaced the air end on the GWTP press pump.
  - II. Replaced the pulley on Media Return #3.
  - III. Replaced cloths on GWTP press.
  - IV. Replaced pH probes on FBR's 2, 4, and 6.
  - V. Changed the I/P (current to pressure) control module on FBR 3 feed valve.
  - VI. Installed a new spool piece on the discharge pipe to the outfall at the EQ area.
  - VII. Replaced the gasket on the discharge of the North turbine pump at Lift Station 1.
  - VIII. Replaced the handle on the discharge valve for the North turbine pump at Lift Station 1.

- IX. Replaced the pressure line on the recycle piping of FBR 2.
  - X. Changed out the Ferric Chloride chemical feed pump.
- Preventative Maintenance completed or being performed by ETI in the month included:
    - I. Cleaned the sight glasses for media return piping.
    - II. Pressure washed the GWTP press cloths and plates.
    - III. Flushed the sump pit at the D-1 area.
    - IV. Flushed the turbidity meters and calibrated them.
    - V. Cleaned the air filters on the Lift Station 3 Air Conditioning cabinets.
    - VI. Tested and calibrated the level sensors on the chemical feed totes.

### **GWETS Upgrades and Facility Projects**

Unit 4 Chromium Water Treatment Plant – Envirogen received comments regarding the deliverable documents that were submitted to the Trust in July 2019 for this project. The revised documents dealing with the Controls Specification, Process Drawings, and Mechanical Details were re-submitted to the Trust in September. Envirogen is awaiting further direction from the Trust regarding this matter.

GWETS Extension –The signed Work Authorization for engineering and fabrication of the GWETS Extension was returned to the Trust on January 28, 2020. The O&M Work Authorization proposal for the GWETS Extension was submitted to the Trust on March 10, 2020. Envirogen is awaiting further direction from the Trust regarding the O&M Work Authorization.

### **GWETS Staffing**

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

# Tables

---

*Operational Metrics*

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) <sup>6 7</sup>	Chromium (TR) (mg/L) <sup>6 7</sup>	Chromium(VI) (mg/L) <sup>6 7</sup>
SWF Total Extraction <sup>1</sup>	750 <sup>5</sup>	7.2	0.0020	0.0022
AWF Total Extraction <sup>1</sup>	466 <sup>5</sup>	62	0.16	0.15
IWF Total Extraction <sup>1</sup>	61 <sup>5</sup>	397	6.4	6.3
AP Area Total Extraction <sup>1</sup>	11.3 <sup>5</sup>	544	0.111	0.098
GWTP Effluent <sup>2</sup>	62	456	0.48	ND
GW-11 Influent <sup>1</sup>	5.91	62	0.07	0.030
FBR Influent <sup>2 3</sup>	1,065	86	0.033	0.029
T-205 Effluent (AP-5 Wash Water) <sup>3 4 8</sup>	5.5	NA	NA	NA

## Notes:

TR = Total Recoverable; NA = Not Analyzed; ND = Not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

- 1: Perchlorate and chromium TR sampled monthly, values reported from TestAmerica.
- 2: Perchlorate, chromium TR, and chromium (VI) sampled weekly, values reported from TestAmerica.
- 3: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.
- 4: Flow weighted average concentration based on mass flow meter readings.
- 5: Sum of daily average flow for individual wells.
- 6: All concentrations reported are monthly flow weighted averages.
- 7: ND analytical values are treated as zero values in the flow weighted average calculations.
- 8: AP-5 sediment mixing and solids washing activities were completed on January 4, 2020. Wash water is still being transferred to T-205 to be processed

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) <sup>3</sup>	Chromium (TR) (lbs/month) <sup>3</sup>	Chromium (VI) (lbs/month) <sup>3</sup>
SWF Total Extraction	2,013	0.57	0.61
AWF Total Extraction	10,796	27	25
IWF Total Extraction	9,027	145	144
AP Area Total Extraction	2,299	0.47	0.42
GWTP Effluent	10,578	11	ND
GW-11 Influent	136.6	0.163	0.0661
FBR Influent <sup>1</sup>	33,989	13	11.3
T-205 Effluent (AP-5 Wash Water) <sup>1 2 4</sup>	0.0	NA	NA

## Notes:

TR = Total Recoverable; NA = Not Analyzed.

1: AP-5 Wash Water perchlorate data is also included in the GW-11 Effluent/ FBR Influent totals.

2: AP-5 Wash Water concentrations and mass flux are estimates based on mass flow meter readings.

3: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).

4: AP-5 sediment mixing and solids washing activities were completed on January 4, 2020. Wash water is still being transferred to T-205 to be processed.

# Figures

---

*Operational Metrics*

Figure 1 - GW-11 Pond Volume Through 5/31/2020







Figure 2 - Historical Perchlorate Mass Removed From Environment



# Attachment A

---

*NPDES Tracking Sheet (Prepared by Ramboll)*

Treated Effluent at Outfall 001																					
Continuous		Daily Samples, composited weekly		Weekly Grab Samples										Weekly, collected separately			Quarterly				
Flow Rate		Perchlorate		pH	Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)	Total Suspended Solids (TSS)		Total Ammonia as N		Total Phosphorus as P		BOD <sub>5</sub> (inhibited)			Total Dissolved Solids (TDS)		
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (µg/L)	30-Day Avg. (lbs/day)	Daily Min. (S.U.)	Daily Max. (S.U.)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (mg/L)	Daily Max. (mg/L)	Daily Average (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)		30-Day Avg. (lbs/day)		30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	Daily Max. (mg/L)	
2.52	2.88	18	0.38	6.5	9.0	10	100	5,000	10,000	20	135	2,839	20*		10*		25	40	525	8,000	
January 2020	1.82	1.89	3	0.04	6.61	6.87	1.1	19	290	540	0.85	5.0	80	6		3.3		1.3	2.1	20	
February 2020	1.85	1.91	1.3	0.019	6.68	6.91	ND (<0.25)	7.6	170	980	1.1	4.9	70	2.3		1.6		ND (<2.0)	ND (<2.0)	16	4,100
March 2020	1.86	1.91	1.3	0.019	6.55	7.11	0.36	5.4	220	1,100	ND (<0.50)	7	110	1.3		1.7		ND (<2.0)	ND (<2.0)	15	
April 2020	1.85	1.88	1.3	0.019	6.59	7.12	ND (<0.25)	6.4	160	1,300	ND (<0.50)	12	180	1.0		1.3		1.2	2.2	19	
May 2020	1.81	1.91	1.3	0.019	6.51	6.98	ND (<0.25)	6.8	150	830	11	9	130	8		2.4		ND (<2.0)	3.3	24	4,500
June 2020 (month to date)	1.80	1.90	NA	NA	6.80	6.80	ND (<0.25)	7.5	110	740	0.58	11	160	8.5		1.8		2.1	2.1	NA	

Daily Grab Sample Dates	Composite Sample Date	µg/L	lbs/day	Sample Date	S.U.	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	Sample Date	mg/L			
12/29 - 1/4	1/4/2020	4.4	4.4	0.063	12/30/2019	6.63	ND (<0.25)	4.6	300	63	4.5	14	196	--	4.5	63	--	0.27	3.8	12/30/2019	ND (<2.0)	1.0	14	
1/5 - 1/11	1/11/2020	12	<0.079	6	0.09	1/6/2020	6.61	ND (<0.25)	2.7	290	58	0.85	4.9	70	--	0.85	12	--	0.22	3.1	1/8/2020	ND (<2.0)	1.0	15
1/12 - 1/18	1/18/2020	ND (<2.5)	1.3	0.019	1/13/2020	6.63	ND (<0.25)	19	210	66	ND (<0.50)	3.2	49	--	0.25	3.8	ND (<0.025)	0.013	0.19	1/15/2020	ND (<2.0)	1.0	16	
1/19 - 1/25	1/25/2020	ND (<2.5)	1.3	0.019	1/20/2020	6.87	ND (<0.25)	5.8	210	140	ND (<0.50)	9.2	142	--	0.16	2.5	--	0.12	1.9	1/22/2020	2.1	32		
1/26 - 2/1	2/1/2020	ND (<2.5)	1.3	0.019	1/27/2020	6.76	1.1	ND (<2.5)	200	540	ND (<0.50)	2.7	41	--	0.35	5.4	--	0.51	7.8	1/29/2020	ND (<2.0)	1.0	15	
2/2 - 2/8	2/8/2020	ND (<2.5)	1.3	0.019	2/3/2020	6.91	ND (<0.25)	3.0	150	980	1.1	6.7	103	--	0.11	1.7	--	0.093	1.4	2/6/2020	ND (<2.0)	1.0	16	
2/9 - 2/15	2/15/2020	ND (<2.5)	1.3	0.019	2/10/2020	6.68	ND (<0.25)	7.6	170	820	ND (<0.50)	6.4	97	--	0.18	2.7	--	0.095	1.4	2/12/2020	ND (<2.0)	1.0	15	
2/16 - 2/22	2/22/2020	ND (<2.5)	1.3	0.019	2/17/2020	6.87	ND (<0.25)	4.5	160	510	ND (<0.50)	3.0	46	--	0.15	2.3	--	0.12	1.8	2/19/2020	ND (<2.0)	1.0	15	
2/23 - 2/29	2/29/2020	ND (<2.5)	1.3	0.020	2/24/2020	6.81	ND (<0.25)	3.6	140	770	ND (<0.50)	3.5	54	--	0.17	2.6	--	0.11	1.7	2/26/2020	ND (<2.0)	1.0	16	
3/1 - 3/7	3/7/2020	ND (<2.5)	1.3	0.020	3/2/2020	7.01	ND (<0.25)	4.8	190	920	ND (<0.50)	5.8	91	--	0.17**	2.7	--	0.13	2.0	3/4/2020	ND (<2.0)	1.0	15	
3/8 - 3/14	3/14/2020	ND (<2.5)	1.3	0.019	3/9/2020	6.55	ND (<0.25)	4.7	220	890	ND (<0.50)	6.1	96	--	0.12**	1.9	--	0.11	1.7	3/12/2020	ND (<2.0)	1.0	15	
3/15 - 3/21	3/21/2020	ND (<2.5)	1.3	0.019	3/16/2020	7.11	ND (<0.25)	5.4	190	1,100	ND (<0.50)	11	173	ND (<0.10)	0.05**	0.79	--	0.077	1.2	3/18/2020	ND (<2.0)	1.0	16	
3/22 - 3/28	3/28/2020	ND (<2.5)	1.3	0.019	3/23/2020	6.74	ND (<0.25)	3.6	220	1,000	ND (<0.50)	6.2	97	--	0.14**	1.5	--	0.13	2.0	3/25/2020	ND (<2.0)	1.0	15	
3/29 - 4/4	4/4/2020	ND (<2.5)	1.3	0.019	3/30/2020	6.61	0.36	3.5	140	740	ND (<0.50)	5.5	86	ND (<0.10)	0.05**	0.76	--	0.082	1.3	4/1/2020	ND (<2.0)	1.0	15	
4/5 - 4/11	4/11/2020	ND (<2.5)	1.3	0.019	4/6/2020	7.12	ND (<0.25)	6.2	160	1,200	ND (<0.50)	12	187	--	0.19**	1.9	--	0.12	1.9	4/8/2020	ND (<2.0)	1.0	16	
4/12 - 4/18	4/18/2020	ND (<2.5)	1.3	0.019	4/13/2020	7.08	ND (<0.25)	6.4	110	1,300	ND (<0.50)	14	217	ND (<0.10)	0.05**	0.77	--	0.063	1.0	4/15/2020	ND (<2.0)	2.2	34	
4/19 - 4/25	4/25/2020	ND (<2.5)	1.3	0.020	4/20/2020	6.93	ND (<0.25)	5.6	150	1,200	ND (<0.50)	13	203	ND (<0.10)	0.05**	0.78	--	0.084	1.3	4/22/2020	ND (<2.0)	1.0	16	
4/26 - 5/2	5/2/2020	ND (<2.5)	1.3	0.019	4/27/2020	6.59	ND (<0.25)	3.3	130	860	ND (<0.50)	8.4	129	ND (<0.10)	0.05**	0.77	--	0.074	1.1	4/29/2020	ND (<2.0)	1.0	15	
5/3 - 5/9	5/9/2020	ND (<2.5)	1.3	0.019	5/4/2020	6.98	ND (<0.25)	4.0	130	440	ND (<0.50)	5.1	81	--	0.15**	8.5	--	0.083	1.3	5/6/2020	ND (<2.0)	1.0	16	
5/10 - 5/16	5/16/2020	ND (<2.5)	1.3	0.020	5/11/2020	6.51	ND (<0.25)	6.8	150	690	ND (<0.50)	9.4	146	--	0.14	2.2	--	0.12	1.9	5/13/2020	ND (<2.0)	1.0	16	
5/17 - 5/23	5/23/2020	ND (<2.5)	1.3	0.019	5/18/2020	6.98	ND (<0.25)	4.6	140	600	1.9	6.1	94	--	1.9	29	--	0.20	3.1	5/20/2020	ND (<2.0)	1.0	15	
5/24 - 5/30	5/30/2020	ND (<2.5)	1.3	0.017	5/26/2020	6.98	ND (<0.25)	6.6	120	830	11	14	208	--	0.51	7.8	--	0.22	3.3	5/27/2020	3.3	50		
5/31 - 6/6	6/6/2020	NA	NA	NA	6/1/2020	6.80	ND (<0.25)	7.5	110	740	0.58	11	162	--	0.58	8.5	--	0.12	1.8	6/3/2020	2.1	NA	4,500	
					6/8/2020	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	6/10/2020	NA	NA		

Note: All analytical responsibilities are performed by TestAmerica Laboratories, Inc. (TestAmerica) in Irvine, California, unless otherwise indicated.

\*\* Additional samples were collected and analyzed for ammonia during this week and results were included in the 30-day average loading calculation.

NA = Not Available To Date

ND = Not Detected above laboratory reporting limit; concentration in adjacent cell to right is one-half the reporting limit (per Permit condition)

J = Result is less than the reporting limit but greater than or equal to the method detection limit and the concentration is an approximate value.

-- = Analyte detected; see column adjacent to right

\* Total phosphorus discharge limitation of 10 lbs/day applies between March 1 and October 31; Ammonia discharge limitation of 20 lbs/day applies between April 1 and September 30; no limits apply the rest of the year.

Last Updated: June 12, 2020

# Attachment B

---

*Equipment Tracking Form*

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>Main Plant Equipment</b>						
<b>1 Seep Wells and Lift Station 1</b>						
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running			
1.03		Lift Station 1 Lift Pump B	Standby		3	Ongoing assembly of parts for the new turbine installation.
1.04		Area in and around Lift Station 1	Running			
<b>2 Athens Road Wells and Lift Station 3</b>						
2.01		Athens Road Well Field, 9 wells	Running			
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running		3	Installed a temporary A/C unit for the turbine cabinet.
<b>3 Lift Station 2 and Transmission Pipelines</b>						
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running		1	Installed a new spool piece on the discharge to the outfall at the EQ.
3.03		Lift Station 2 Lift Pump A	Running		3	Oil change on the turbine.
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running			
<b>4 Interceptor Wells and Cr Treatment Plant</b>						
4.01		IWF Well Field, 30 wells	Running			
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation			
4.05		Filter Press	Running		2	Pressure washed and replaced all the clothes on the press.
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Running			
4.08		Interceptor Booster Pump B	Standby			
4.09		Area In And Around GWTP	Running		3	Changed out the air filter to the press feed pump.
<b>5 Equalization Area and GW-11 Pond</b>						
5.01	PID10A	Pond GW-11	In operation			
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			
5.05	PID10A	Area in and Around EQ	In operation			
5.06	PID10A	Raw Water Feed Pump - P102A				
5.07	PID10A	Raw Water Feed Pump - P102B				

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made  
 2= Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running			
<b>6</b>		<b>First Stage FBRs A, 1 &amp; 2</b>				
6.01	PID14	FBR A				
6.02	PID14	Separator Tank - 1401				
6.03	PID14	Media Return Pump - P 1401				
6.04	PID14	P1401A				
6.05	PID01A	P1401B				
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running		3	Replaced the pump for blown trunnions.
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012				
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
<b>7</b>		<b>First Stage FBRs 3 &amp; 4</b>				
7.01	PID01B	FBR 3	Running		2	The slam valve was replaced with a rebuilt actuator.
7.02	PID01B	FBR 4	Running			
7.03	PID02B	First Stage Separator Tank - T2012	Running			
7.04	PID01B	Media Return Pump - P2012	Running			
7.05	PID01B	First Stage FBR Pump - P1013	Running			
7.06	PID01B	First Stage FRB Pump - P1014	Running			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723				
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
<b>8</b>		<b>Second Stage FBRs 5 &amp; 6</b>				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running		2	Took the FBR offline to replace the slam valve actuator and install new air line fittings.
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running			
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
<b>9</b>		<b>Second Stage FBRs 7 &amp; 8</b>				
9.01	PID03B	FBR 7	Running			
9.02	PID03B	FBR 8	Running			
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running		3	Replaced the media return pump.
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Running			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			
<b>10</b>		<b>Aeration and DAF System</b>				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Bio filter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump				
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running			
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			
<b>11</b>		<b>Pumping System (Old Effluent)</b>				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602	Standby			
<b>12</b>		<b>Sand Filter System</b>				
12.01	PID17	Sand Filter				
12.02	PID17	Filter Reject Tank	In operation			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
<b>13</b>		<b>Effluent Tank and Pumping</b>				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			
13.04	PID10C	Area Around Effluent and North D-1	Running			
<b>14</b>		<b>Solids Collection and Pressing System</b>				
14.01	PID16	Sludge Storage Tank	In operation			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant



Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation		2	The tank was drained and the level transmitter was inspected, calibrated and re-installed.
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902				
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			
<b>Chemical Systems</b>						
<b>15</b>	<b>Electron Donor System</b>					
15.01	PID07B	Electron Donor Tank	In operation			
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23	PID07C	Ferric Chloride	In operation			
24	PID07B	Polymer Systems - DAF	In operation			
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
<b>Utility Systems</b>						
<b>26</b>	<b>Compressed Air System</b>					
26.01	PID08	West Compressor	Running			
26.02	PID08	East Compressor	Running			
26.03	PID08	O2 Compressor	Running			
26.04	PID08	Compressed Air Receiver Tank	In operation			
26.05	PID08	Air Dryer	Running			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
26.06	PID08	Oil Removal Filter	In operation			
26.07	PID08	Particulate Filter	In operation			
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			
29		Well Control System/ Allen Bradley Controls	In operation			
30		MCC FBR Pad	In operation			
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			
<b>Miscellaneous Systems</b>						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
<b>Shelf Spares</b>						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made  
 2= Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant