

---

**To:** Nevada Division of Environmental Protection  
Nevada Environmental Response Trust

---

**Cc:** Nevada Environmental Response Trust Stakeholders

---

**From:** Ryan Sullivan, Vice President Service and O&M

---

**Date:** October 20, 2020

---

**Subject:** NERT – GWETS Operation Monthly Report – September 2020

---

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during September 2020.

### Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in September 2020. Flow from PC-119, PC-120, PC-121, and PC-133 was routed to the IX system, bypassing all flow meters associated with the FBR plant. The flow rate to the IX system averaged approximately 179 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 1,038 gpm during September 2020. At the end of the month, the GW-11 Pond volume was at 34.4 million gallons (MG), which would allow 19.5 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond decreased by 0.4 MG from the end of August 2020. Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 0.28 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 59 mg/L for the month, with a maximum concentration of 63 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of August 2020 averaged 59 mg/L, with a maximum concentration of 64 mg/L.

### Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 graphically presents historical perchlorate and chromium mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

### Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate

Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

## 1. GW-11

There were no operational issues with GW-11 in the month of September.

## 2. Biological Plant

There were influent / effluent diversions during the reporting period generally associated with GW-11 pond level maintenance as well as extraction well short-term shutdown events. Below is a description of the events that occurred:

### **Diversion Events / Well Shutdowns**

- Well Shutdown of Interceptor Well Field (IWF) occurred on September 2, 2020 from 10:36am to 11:01am due to maintenance activities on the discharge piping for pump P-1A for the purposes of bypassing the Degassifier tank in order to conduct maintenance on the tank walls. Maintenance completed the bypass and the well field was brought back online.
- Well Shutdown of IWF occurred intermittently on September 4, 2020 from 9:03am to 9:11am, 1:11pm to 1:24pm, and 5:10pm to 5:15pm due to ongoing maintenance activities on the discharge piping for pump P-1A. Bypassing the Degassifier tank changed the flow characteristics for the GWTP. Adjustments were made and the well field was brought back online.
- Well Shutdown of IWF occurred on September 6, 2020 from 11:46am to 11:54am due to ongoing maintenance activities on the discharge piping for pump P-1A. Bypassing the Degassifier tank changed the flow characteristics for the GWTP. Adjustments were made and the well field was brought back online.
- Effluent diversion to GW-11 occurred on September 5, 2020 from 11:30pm to September 6, 2020 at 5:32am due to low GW-11 pond level. Approximately 382,000 gallons of water were diverted to GW-11.
- Well Shutdown of IWF occurred intermittently on September 7, 2020 from 5:50am to 5:56am, 11:53am to 11:59am, 3:52pm to 3:58pm, and 9:19pm to 9:24pm due to ongoing maintenance activities on the discharge piping for pump P-1A. Bypassing the Degassifier tank changed the flow characteristics for the GWTP. Adjustments were made and the well field was brought back online.
- Effluent diversion to GW-11 occurred on September 7, 2020 from 11:38pm to September 8, 2020 at 5:10am due to low GW-11 pond level. Approximately 365,000 gallons of water were diverted to GW-11.
- Well Shutdown of IWF occurred intermittently on September 8, 2020 from 3:57am to 4:03am, 8:00am to 8:05am, 10:21am to 10:28am, 12:26pm to 12:34pm, 2:08pm to 2:14pm, 3:43pm to 3:50pm, 5:20pm to 5:25pm, 6:47pm to 6:56pm, 8:18pm to 8:26pm, 9:46pm to 9:51pm, and 10:43pm to 10:50pm due to ongoing maintenance activities on the discharge piping for pump P-1A. Bypassing the Degassifier tank changed the flow characteristics for the GWTP. Adjustments were made and the well field was brought back online.
- Well Shutdown of Seep Well Field (SWF) occurred on September 8, 2020 from 8:13am to 7:27pm, due to NV Energy power outages. When power was restored the wells were reset and the well field brought back online.
- Effluent diversion to GW-11 occurred on September 8, 2020 from 11:36pm to September 9, 2020

5:38am due to low GW-11 pond level. Approximately 378,000 gallons of water were diverted to GW-11.

- Well Shutdown of IWF occurred intermittently on September 9, 2020 from 1:10am to 1:18am, 1:27am to 1:33am, 2:38am to 2:43am, 3:52am to 3:59am, 5:04am to 5:10am, and 6:14am to 6:24am due to ongoing maintenance activities on the discharge piping for pump P-1A. Bypassing the Degassifier tank changed the flow characteristics for the GWTP. Adjustments were made and the well field was brought back online.
- Effluent diversion to GW-11 occurred on September 9, 2020 from 11:40pm to September 10, 2020 at 4:50am due to low GW-11 pond level. Approximately 340,000 gallons of water were diverted to GW-11.
- Well Shutdown of IWF occurred on September 13, 2020 from 2:59pm to 3:09pm due to ongoing maintenance activities on the discharge piping for pump P-1A. Bypassing the Degassifier tank changed the flow characteristics for the GWTP. Adjustments were made and the well field was brought back online.
- Effluent diversion to GW-11 occurred on September 21, 2020 from 11:19pm to September 22, 2020 4:22 am due to low GW-11 pond level. Approximately 338,000 gallons of water were diverted to GW-11.
- Influent diversion to GW-11 occurred on September 22, 2020 from 5:18am to 5:31am due to maintenance activities on the effluent pipeline. Approximately 14,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on September 22, 2020 from 2:03pm to 2:22pm due to maintenance efforts on the Sand Filter. Approximately 20,000 gallons of effluent were diverted to GW-11.
- Effluent diversion to GW-11 occurred on September 25, 2020 from 11:35pm to September 26, 2020 5:00am due to low GW-11 pond level. Approximately 351,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on September 29, 2020 from 11:26pm to September 30, 2020 5:07am due to low GW-11 pond level. Approximately 371,000 gallons of water were diverted to GW-11.

### 3. Spills

There were no reportable spills in the month of September.

### 4. Maintenance

- Major maintenance performed by ETI in the month included:
  - I. The combo valves were taken apart and cleaned and put back into service.
  - II. Replaced the flow meters on IWF extraction wells I-M and I-U. Installed a new .5 hp motor and fuses on IWF extraction well I-F.
  - III. Continued to replace the o - rings on the GWTP filter press plates.
  - IV. Replaced the piping on the discharge of the booster pump.
  - V. Replaced the wiring on the pond corner pumps.
  - VI. Drained the sand filter to clear out the sand cleaners from the airlifts.

- VII. Replaced the West D-1 building sump pump with a larger pump and new larger piping.
- VIII. Rebuilt the bed height pumps on FBRs A, 1, and 2.
- IX. Changed the impeller on the LS1 flowmeter.
- X. Installed a new wheel on the GW-11 emergency exit gate.

- Preventative Maintenance completed or being performed by ETI in the month included:

- I. Changed the oil on the LS2 turbine.
- II. Cleaned the filters on the LS3 A/C's.
- III. Replaced the belts on the D-1 exhaust vents.
- IV. Flushed the North D-1 building sump pit.
- V. Flushed the ORP lines.
- VI. Conducted the infrared checks on the MCC buckets.
- VII. Cleaned the strainers on the FBR recycle pumps.
- VIII. Greased the recycle pump motors.
- IX. Inspected the front gate rollers and drive system.

## **GWETS Upgrades and Facility Projects**

Unit 4 Chromium Water Treatment Plant – Envirogen received comments regarding the deliverable documents that were submitted to the Trust in July 2019 for this project. The revised documents dealing with the Controls Specification, Process Drawings, and Mechanical Details were re-submitted to the Trust in September. Envirogen is awaiting further direction from the Trust regarding this matter. The Trust has advised Envirogen that this project is on hold pending finalization and approval of the forthcoming Unit 4 Source Area In-Situ Bioremediation Work Plan.

GWETS Extension –The signed Work Authorization for engineering and fabrication of the GWETS Extension was returned to the Trust on January 28, 2020. Orders have been placed for the major equipment for the GWETS Extension with deliveries expected during the third and fourth quarters of 2020. Envirogen is currently awaiting Trust comment on the O&M Work Authorization proposal for the GWETS Extension.

## **GWETS Staffing**

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

# Tables

---

*Operational Metrics*

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) <sup>4 5</sup>	Chromium (TR) (mg/L) <sup>4 5</sup>	Chromium(VI) (mg/L) <sup>4 5</sup>
SWF Total Extraction <sup>1</sup>	734 <sup>3</sup>	8.0	0.0030	0.0027
AWF Total Extraction <sup>1</sup>	470 <sup>3</sup>	66	0.15	0.15
IWF Total Extraction <sup>1</sup>	59 <sup>3</sup>	460	6.6	6.7
AP Area Total Extraction <sup>1</sup>	10.1 <sup>3</sup>	648	0.142	0.147
GWTP Effluent <sup>2</sup>	62	466	0.42	ND
GW-11 Influent <sup>1</sup>	0.14	61	0.11	0.004
FBR Influent <sup>2</sup>	1,038	59	0.024	0.016

## Notes:

TR = Total Recoverable; NA = Not Analyzed; ND = Not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Perchlorate and chromium TR sampled monthly, values reported from Eurofins TestAmerica.

2: Perchlorate, chromium TR, and chromium (VI) sampled weekly, values reported from Eurofins TestAmerica.

3: Sum of daily average flow for individual wells.

4: All concentrations reported are monthly flow weighted averages.

5: ND analytical values are treated as zero values in the flow weighted average calculations.

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) <sup>1</sup>	Chromium (TR) (lbs/month) <sup>1</sup>	Chromium (VI) (lbs/month) <sup>1</sup>
SWF Total Extraction	2,115	0.81	0.73
AWF Total Extraction	11,119	25	25
IWF Total Extraction	9,825	140	143
AP Area Total Extraction	2,352	0.51	0.53
GWTP Effluent	10,349	9.4	ND
GW-11 Influent	3.1	0.006	0.0002
FBR Influent <sup>1</sup>	22,286	8.9	6.0

Notes:

TR = Total Recoverable; NA = Not Analyzed.

1: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).

# Figures

---

*Operational Metrics*



Figure 1 - GW-11 Pond Volume Through 9/30/2020





Figure 2 - Historical Perchlorate Mass Removed From Environment



# Attachment A

---

*NPDES Tracking Sheet (Prepared by Ramboll)*

Treated Effluent at Outfall 001																			
Continuous		Daily Samples, composited weekly		Weekly Grab Samples										Weekly, collected separately			Quarterly		
Flow Rate		Perchlorate		pH	Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)	Total Suspended Solids (TSS)	Total Ammonia as N		Total Phosphorus as P		BOD <sub>5</sub> (inhibited)			Total Dissolved Solids (TDS)	
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (µg/L)	30-Day Avg. (lbs/day)	Daily Min. (S.U.)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (mg/L)	Daily Average (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	Daily Max. (mg/L)	
2.52	2.88	18	0.38	6.5	9.0	10	100	5,000	10,000	20	135	2,839	20*	10*	25	40	525	8,000	
January 2020	1.82	1.89	3	0.04	6.61	6.87	1.1	19	290	540	0.85	5.0	80	6	3.3	1.3	2.1	2.0	
February 2020	1.85	1.91	ND (<2.5)	0.019	6.68	6.91	ND (<0.25)	7.6	170	980	1.1	4.9	70	2.3	1.6	ND (<2.0)	ND (<2.0)	16	4,100
March 2020	1.86	1.91	ND (<2.5)	0.019	6.55	7.11	0.36	5.4	220	1,100	ND (<0.50)	7	110	1.3	1.7	ND (<2.0)	ND (<2.0)	15	
April 2020	1.85	1.88	ND (<2.5)	0.019	6.59	7.12	ND (<0.25)	6.4	160	1,300	ND (<0.50)	12	180	1.0	1.3	1.6	2.6	24	
May 2020	1.81	1.91	ND (<2.5)	0.019	6.51	6.98	ND (<0.25)	7.4	160	830	11	9	130	10	2.4	1.6	3.3	24	4,500
June 2020	1.73	1.88	ND (<2.5)	0.018	6.66	7.01	ND (<0.25)	7.5	160	820	1.1	8	120	4.5	1.3	2.0	4.0	27	
July 2020	1.62	1.87	ND (<2.5)	0.017	6.49	7.12	ND (<0.25)	5.8	150	930	1.6	7	80	8	2.0	3.4	8.7	52	
August 2020	1.65	1.85	ND (<2.5)	0.017	6.72	7.26	ND (<0.25)	17	100	1,000	6.4	8	90	7	1.3	ND (<2.0)	ND (<2.0)	13	4,100
September 2020 (month to date)	1.75	1.90	2.0	0.029	6.71	7.17	ND (<0.25)	7.0	120	1,100	2.1	8	120	1.4	1.5	2.5	4.3	32	

Daily Grab Sample Dates	Composited Sample Date	µg/L	lbs/day	Sample Date	S.U.	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	Sample Date	mg/L		
12/29 - 1/4	1/4/2020	4.4	0.063	12/30/2019	6.63	ND (<0.25)	4.6	300	63	4.5	14	196	--	4.5	63	--	0.27	3.8	12/30/2019	ND (<2.0)	1.0	14	
1/5 - 1/11	1/11/2020	12.0	<0.079	1/6/2020	6.61	ND (<0.25)	2.7	290	58	0.85	4.9	70	--	0.85	12	--	0.22	3.1	1/8/2020	ND (<2.0)	1.0	15	
1/12 - 1/18	1/18/2020	ND (<2.5)	1.3	0.019	6.63	ND (<0.25)	19	210	66	ND (<0.50)	3.2	49	--	2.5	3.8	ND (<0.025)	0.013	0.19	1/15/2020	ND (<2.0)	1.0	16	
1/19 - 1/25	1/25/2020	ND (<2.5)	1.3	0.019	6.87	ND (<0.25)	5.8	210	140	ND (<0.50)	9.2	142	--	0.16	2.5	--	0.12	1.9	1/22/2020	2.1	32		
1/26 - 2/1	2/1/2020	ND (<2.5)	1.3	0.019	6.76	1.1	ND (<2.5)	200	540	ND (<0.50)	2.7	41	--	0.35	5.4	--	0.51	7.8	1/29/2020	ND (<2.0)	1.0	15	
2/2 - 2/8	2/8/2020	ND (<2.5)	1.3	0.019	6.91	ND (<0.25)	3.3*	3.0	150	980	1.1	6.7	103	--	0.11	1.7	--	0.093	1.4	2/6/2020	ND (<2.0)	1.0	16
2/9 - 2/15	2/15/2020	ND (<2.5)	1.3	0.019	6.68	ND (<0.25)	7.6	170	820	ND (<0.50)	6.4	97	--	0.18	2.7	--	0.095	1.4	2/12/2020	ND (<2.0)	1.0	15	
2/16 - 2/22	2/22/2020	ND (<2.5)	1.3	0.019	6.87	ND (<0.25)	4.5	160	510	ND (<0.50)	3.0	46	--	0.15	2.3	--	0.12	1.8	2/19/2020	ND (<2.0)	1.0	15	
2/23 - 2/29	2/29/2020	ND (<2.5)	1.3	0.020	6.81	ND (<0.25)	3.6	140	770	ND (<0.50)	3.5	54	--	0.17	2.6	--	0.11	1.7	2/26/2020	ND (<2.0)	1.0	16	
3/1 - 3/7	3/7/2020	ND (<2.5)	1.3	0.020	7.01	ND (<0.25)	4.8	190	920	ND (<0.50)	5.8	91	--	0.17**	2.7	--	0.13	2.0	3/4/2020	ND (<2.0)	1.0	15	
3/8 - 3/14	3/14/2020	ND (<2.5)	1.3	0.019	6.55	ND (<0.25)	4.7	220	890	ND (<0.50)	6.1	96	--	0.12**	1.9	--	0.11	1.7	3/12/2020	ND (<2.0)	1.0	15	
3/15 - 3/21	3/21/2020	ND (<2.5)	1.3	0.019	7.11	ND (<0.25)	5.4	190	1,100	ND (<0.50)	11	173	ND (<0.10)	0.05**	0.79	--	0.077	1.2	3/18/2020	ND (<2.0)	1.0	16	
3/22 - 3/28	3/28/2020	ND (<2.5)	1.3	0.019	6.74	ND (<0.25)	3.6	220	1,000	ND (<0.50)	6.2	97	--	0.14**	1.5	--	0.13	2.0	3/25/2020	ND (<2.0)	1.0	15	
3/29 - 4/4	4/4/2020	ND (<2.5)	1.3	0.019	6.61	0.36	3.5	140	740	ND (<0.50)	5.5	86	ND (<0.10)	0.05**	0.76	--	0.082	1.3	4/1/2020	ND (<2.0)	1.0	15	
4/5 - 4/11	4/11/2020	ND (<2.5)	1.3	0.019	7.12	ND (<0.25)	6.2	160	1,200	ND (<0.50)	12	187	--	0.19**	1.9	--	0.12	1.9	4/8/2020	2.6	41		
4/12 - 4/18	4/18/2020	ND (<2.5)	1.3	0.019	7.08	ND (<0.25)	6.4	110	1,300	ND (<0.50)	14	217	ND (<0.10)	0.05**	0.77	--	0.063	1.0	4/15/2020	2.2	34		
4/19 - 4/25	4/25/2020	ND (<2.5)	1.3	0.020	6.93	ND (<0.25)	5.6	150	1,200	ND (<0.50)	13	203	ND (<0.10)	0.05**	0.78	--	0.084	1.3	4/22/2020	ND (<2.0)	1.0	16	
4/26 - 5/2	5/2/2020	ND (<2.5)	1.3	0.019	6.59	ND (<0.25)	3.3	130	860	ND (<0.50)	8.4	129	ND (<0.10)	0.05**	0.77	--	0.074	1.1	4/29/2020	ND (<2.0)	1.0	15	
5/3 - 5/9	5/9/2020	ND (<2.5)	1.3	0.019	6.98	ND (<0.25)	7.4*	4.0	160	440	ND (<0.50)	5.1	81	--	0.15**	10.1	--	0.083	1.3	5/6/2020	ND (<2.0)	1.0	16
5/10 - 5/16	5/16/2020	ND (<2.5)	1.3	0.020	6.51	ND (<0.25)	6.8	150	690	ND (<0.50)	9.4	146	--	0.14	2.2	--	0.12	1.9	5/13/2020	ND (<2.0)	1.0	16	
5/17 - 5/23	5/23/2020	ND (<2.5)	1.3	0.019	6.98	ND (<0.25)	4.6	140	600	1.9	6.1	94	--	1.9	29	--	0.20	3.1	5/20/2020	ND (<2.0)	1.0	15	
5/24 - 5/30	5/30/2020	ND (<2.5)	1.3	0.017	6.98	ND (<0.25)	6.6	120	830	11	14	208	--	0.51	7.6	--	0.22	3.3	5/27/2020	3.3	50		
5/31 - 6/6	6/6/2020	ND (<2.5)	1.3	0.018	6.80	ND (<0.25)	7.5	110	740	0.58	11	162	--	0.58	8.5	--	0.12	1.8	6/3/2020	2.1	32		
6/7 - 6/13	6/13/2020	ND (<2.5)	1.3	0.018	6.66	ND (<0.25)	3.8	110	410	ND (<0.50)	4.6	69	--	0.18	2.7	--	0.073	1.1	6/10/2020	ND (<2.0)	1.0	15	
6/14 - 6/20	6/20/2020	ND (<2.5)	1.3	0.019	6.87	ND (<0.25)	5.3	150	820	1.1	7.8	117	--	0.16	2.4	--	0.013	0.19	6/17/2020	ND (<2.0)	1.0	15	
6/21 - 6/27	6/27/2020	ND (<2.5)	1.3	0.017	6.92	ND (<0.25)	7.3	160	780	ND (<0.50)	8.4	125	--	0.26	3.9	--	0.12	1.8	6/24/2020	4.0	44		
6/28 - 7/4	7/4/2020	ND (<2.5)	1.3	0.017	7.01	ND (<0.25)	5.9	99	710	ND (<0.50)	9.9	145	--	0.33	4.8	--	0.12	1.8	7/1/2020	ND (<2.0)	1.0	15	
7/5 - 7/11	7/11/2020	ND (<2.5)	1.3	0.017	6.98	ND (<0.25)	5.8	87	930	1.6	12	146	--	1.6	20	--	0.25	3.1	7/8/2020	ND (<2.0)	1.0	15	
7/12 - 7/18	7/18/2020	ND (<2.5)	1.3	0.017	6.49	ND (<0.25)	4.1	120	680	ND (<0.50)	7.2	84	--	0.30	3.5	--	0.089	1.04	7/15/2020	2.5	38		
7/19 - 7/25	7/25/2020	ND (<2.5)	1.3	0.016	7.10	ND (<0.25)	4.7	110	470	0.51	3.9	60	--	0.51	7.8	--	0.096	1.5	7/22/2020	3.8	59		
7/26 - 8/1	8/1/2020	ND (<2.5)	1.3	0.017	7.12	ND (<0.25)	ND (<2.5)	150	510	ND (<0.50)	3.2	48	--	0.16	2.4	--	0.150	2.2	7/29/2020	8.7	133		
8/2 - 8/8	8/8/2020	ND (<2.5)	1.3	0.015	6.72	ND (<0.25)	3.6	94	730	ND (<0.50)	8.1	98	--	0.20	2.4	--	0.077	0.93	8/5/2020	ND (<2.0)	1.0	12	
8/9 - 8/15	8/15/2020	ND (<2.5)	1.3	0.016	6.86	ND (<0.25)	6.0*	9.6	1,000	6.4	19	170	--	6.4**	57	--	0.35	3.1	8/13/2020	ND (<2.0)	1.0	10	
8/16 - 8/22	8/22/2020	ND (<2.5)	1.3	0.019	7.26	ND (<0.25)	17	85	88	ND (<0.50)	2.8	43	--	0.38**	5.8	--	0.11	1.7	8/19/2020	ND (<2.0)	1.0	15	
8/23 - 8/29	8/29/2020	ND (<2.5)	1.3	0.018	6.76	ND (<0.25)	6.0	57	350	1.1	3.9	60	ND (<0.10)	0.05**	0.77	--	0.039	0.60	8/26/2020	ND (<2.0)	1.0	15	
8/30 - 9/5	9/5/2020	ND (<2.5)	1.3	0.019	6.91	ND (<0.25)	4.4	81	610	1.2	6.3	96	--	0.13**	2.0	ND (<0.025)	0.013	0.19	9/2/2020	4.3	66		
9/6 - 9/12	9/12/2020	1.2	1.2	0.016	6.71	ND (<0.25)	4.0	110	530	2.1	6.6	72	--	0.15	1.6	ND (<0.025)	0.013	0.14	9/9/2020	ND (<2.0)	1.0	11	
9/13 - 9/19	9/19/2020	3.9	3.9	0.059	6.78	ND (<0.25)	5.4	100	810	ND (<0.50)	7.1	108	--	0.11	1.7	--	0.13	2.0	9/16/2020	2.4	36		
9/20 - 9/26	9/26/2020	1.5	1.5	0.022	6.86	ND (<0.25)	7.0	120	1,100	ND (<0.50)	12	186	--	0.10	1.6	--							

# Attachment B

---

*Equipment Tracking Form*

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>Main Plant Equipment</b>						
<b>1 Seep Wells and Lift Station 1</b>						
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running			
1.03		Lift Station 1 Lift Pump B	Standby			
1.04		Area in and around Lift Station 1	Running		1	Power loss from NV Energy caused the LS to go down. Once the power was re-established by NV Energy the LS was back online.
<b>2 Athens Road Wells and Lift Station 3</b>						
2.01		Athens Road Well Field, 9 wells	Running			
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running			
<b>3 Lift Station 2 and Transmission Pipelines</b>						
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running		3	The combo valves were taken apart and cleaned and put back into service.
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running			
<b>4 Interceptor Wells and Cr Treatment Plant</b>						
4.01		IWF Well Field, 30 wells	Running		3	Replaced the flow meter on I-M and on I-U. installed a new .5 hp motor and fuses on I-F
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation			
4.05		Filter Press	Running		2	The O-rings are continuing to be replaced on the plates.
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Running			
4.08		Interceptor Booster Pump B	Standby			
4.09		Area In And Around GWTP	Running		2	The piping was replaced on the discharge of the booster pump.
<b>5 Equalization Area and GW-11 Pond</b>						
5.01	PID10A	Pond GW-11	In operation		3	The wiring was replaced on the pond corner pumps.
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
5.05	PID10A	Area in and Around EQ	In operation			
5.06	PID10A	Raw Water Feed Pump - P102A				
5.07	PID10A	Raw Water Feed Pump - P102B				
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running			
<b>6</b>		<b>First Stage FBRs A, 1 &amp; 2</b>				
6.01	PID14	FBR A				
6.02	PID14	Separator Tank - 1401				
6.03	PID14	Media Return Pump - P 1401				
6.04	PID14	P1401A				
6.05	PID01A	P1401B				
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012			1	The overload was replaced as well as the fuses. The seal water solenoid was also replaced.
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
<b>7</b>		<b>First Stage FBRs 3 &amp; 4</b>				
7.01	PID01B	FBR 3	Running			
7.02	PID01B	FBR 4	Running			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
7.03	PID02B	First Stage Separator Tank - T2012	Running			
7.04	PID01B	Media Return Pump - P2012	Running			
7.05	PID01B	First Stage FBR Pump - P1013	Running			
7.06	PID01B	First Stage FRB Pump - P1014	Running			
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723				
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
<b>8</b>		<b>Second Stage FBRs 5 &amp; 6</b>				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running			
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
<b>9</b>		<b>Second Stage FBRs 7 &amp; 8</b>				
9.01	PID03B	FBR 7	Running			
9.02	PID03B	FBR 8	Running			
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Running			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made  
 2= Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant



Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			
<b>10</b>		<b>Aeration and DAF System</b>				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running		3	The belt was replaced on the motor
10.03	PID04	Bio filter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump				
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation		3	The solenoids were replaced on the tank level blowdown. The level controller was also reset
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running		2	Replaced the breaker and cover on the pressure pump motor.
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running			
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			
<b>11</b>		<b>Pumping System (Old Effluent)</b>				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602	Standby			
<b>12</b>		<b>Sand Filter System</b>				
12.01	PID17	Sand Filter			2	The vessel was drained to clear out the sand cleaners from the airlifts
12.02	PID17	Filter Reject Tank	In operation			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
<b>13</b>		<b>Effluent Tank and Pumping</b>				
13.01	PID10C	UV Effluent Tank	Running			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			
13.04	PID10C	Area Around Effluent and North D-1	Running		3	The ISEP was replaced with a larger pump and new larger piping.
<b>14</b>		<b>Solids Collection and Pressing System</b>				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation			
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902				
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			
		<b>Chemical Systems</b>				
<b>15</b>		<b>Electron Donor System</b>				
15.01	PID07B	Electron Donor Tank	In operation			
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23	PID07C	Ferric Chloride	In operation			
24	PID07B	Polymer Systems - DAF	In operation			
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
		<b>Utility Systems</b>				
<b>26</b>		<b>Compressed Air System</b>				
26.01	PID08	West Compressor	Running			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made  
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
26.02	PID08	East Compressor	Running			
26.03	PID08	O2 Compressor	Running			
26.04	PID08	Compressed Air Receiver Tank	In operation			
26.05	PID08	Air Dryer	Running			
26.06	PID08	Oil Removal Filter	In operation			
26.07	PID08	Particulate Filter	In operation			
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			
29		Well Control System/ Allen Bradley Controls	In operation			
30		MCC FBR Pad	In operation			
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			
<b>Miscellaneous Systems</b>						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
<b>Shelf Spares</b>						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			

Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made  
 2= Important - Can still operate safely and in compliance with permits, but risks are increased  
 3= Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place  
 4= Low - Minor repairs that in no way alter the performance of the plant