
To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: Ryan Sullivan, Vice President Service and O&M

Date: April 20, 2021

Subject: NERT – GWETS Operation Monthly Report – April 2021

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during April 2021.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in April 2021. Flow from PC-119, PC-120, PC-121, and PC-133 was routed to the IX system, bypassing all flow meters associated with the FBR plant. The flow rate to the IX system averaged approximately 193 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 1,027 gpm during April 2021. At the end of the month, the GW-11 Pond volume was at 34.4 million gallons (MG), which would allow 19.5 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond did not change from the end of March 2020. Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 0.21 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 55 mg/L for the month, with a maximum concentration of 59 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of March 2021 averaged 56 mg/L, with a maximum concentration of 58 mg/L.

Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 graphically presents historical perchlorate and chromium mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate

Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11

There were no operational issues with GW-11 in the month of April.

2. Biological Plant

There were influent / effluent diversions during the reporting period generally associated with GW-11 pond level maintenance as well as extraction well short-term shutdown events. Below is a description of the events that occurred:

Diversion Events / Well Shutdowns

- Well Field Shutdown of the Interceptor Well Field (IWF) occurred on April 2, 2021 from 1:43am to 1:50am due to high inlet tank level alarms at the GWTP. Troubleshooting was conducted and the well field was brought back online.
- Extraction Well Shutdown of PC-119 (SWF) occurred on April 2, 2021 from 9:44am to 11:20am, due to a malfunction in the electrical system at the motor. Maintenance was conducted, the breaker switch was replaced, and the well was brought back online.
- Extraction Well Shutdown of I-I (IWF) occurred on April 4, 2021 from 7:01am to 11:30am, due to a malfunction at the pump and motor. Maintenance was conducted, the pump and motor were replaced, and the well was brought back online.
- Influent diversion to GW-11 occurred on April 5, 2021 from 1:45pm to 2:45pm due to maintenance efforts at the Ethanol pump skid. Approximately 63,000 gallons of water were diverted to GW-11.
- Influent diversion to GW-11 occurred on April 7, 2021 from 9:28am to 10:06am due to maintenance efforts at the GAC pressure gauge. A new saddle tap was installed and the plant brought back online. Approximately 40,000 gallons of water were diverted to GW-11.
- Well Field Shutdown of the IWF occurred on April 7, 2021 from 8:06am to 8:14am due to electrical abnormalities. Troubleshooting was conducted and the well field was brought back online.
- Effluent diversion to GW-11 occurred on April 7, 2021 from 11:50pm to April 8, 2021 at 4:51am due to low GW-11 pond level. Approximately 323,000 gallons of water were diverted to GW-11.
- Well Field Shutdown of the IWF occurred on April 8, 2021 from 12:18pm to 12:31pm due to electrical abnormalities. Troubleshooting was conducted and the well field was brought back online.
- Well Field Shutdown of the IWF occurred on April 16, 2021 from 8:34am to 8:39am due to electrical abnormalities. Troubleshooting was conducted and the well field was brought back online.
- Well Field Shutdown of the IWF occurred on April 17, 2021 from 8:06am to 8:14am due to electrical abnormalities. Troubleshooting was conducted and the well field was brought back online. Final resolution to the electrical abnormalities included replacement of the electrical transformer, VFD, new wiring and connections, and installation of electrical grounding components.
- Extraction Well Shutdown of I-J (IWF) occurred on April 19, 2021 from 4:34am to 9:46am, due to a malfunction at the motor. Maintenance was conducted, the motor was replaced, and the well was brought back online.
- Effluent diversion to GW-11 occurred on April 22, 2021 from 11:34pm to April 23, 2021 at 2:05am due to low GW-11 pond level. Approximately 160,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on April 25, 2021 from 12:12am to at 4:24am due to low GW-

11 pond level. Approximately 263,000 gallons of water were diverted to GW-11.

- Effluent diversion to GW-11 occurred on April 25, 2021 from 11:45pm to April 26, 2021 at 4:24am due to low GW-11 pond level. Approximately 280,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on April 26, 2021 from 9:00am to 12:40pm as a precautionary measure due to high perchlorate onsite lab results. Adjustments were made, new samples were conducted in the lab, and the effluent was returned to the outfall. Approximately 216,000 gallons of water were diverted to GW-11.

3. Spills

There were no reportable spills in the month of April.

4. Maintenance

- Major maintenance performed by ETI in the reporting month included:
 - I. Repaired the breaker switch on the bucket for PC-119.
 - II. Drilled out a new hole for the transducer on PC-116.
 - III. Repaired the connections for the lift station 1 MCC air conditioner.
 - IV. Replaced the check valve on the discharge of the west turbine at lift station 3.
 - V. Replaced the pump and 0.5 hp motor on extraction well I-I.
 - VI. Replaced the 0.5 hp motor on extraction well I-J.
 - VII. Replaced the pump head of the new P-1001 mag drive pump.
 - VIII. Powered down the GWTP plant to connect new wiring and grounding on the main power line. A new transformer was installed.
 - IX. Rebuilt the bed height pump for FBR A.
 - X. Installed a new metering pump to replace the temporary pump for the FBR A phosphoric acid feed.
 - XI. Opened the electrical conduit to remove water from the sprinkler system that entered the conduit for the FBR 8 ethanol feed pump. New connections were made and the conduit was sealed.
 - XII. Replaced the pump due to blown discs and check flaps for the South DAF sludge pump.
 - XIII. Repaired a damaged airlift on the sand filter.
 - XIV. The CP compressor has been repaired and is ready for service.
 - XV. Replaced the saddle clamp for the GAC pressure gauge.
- Preventative Maintenance completed by ETI in the reporting month included:
 - I. Flushed solids from the separator and transferring back into the FBR.
 - II. Removed the North and South DAF vessels from service and removed accumulated solids.
 - III. Cleaned the filters for the Air Conditioners at the lift stations.
 - IV. Flushed solids from separator 2 back into FBR 3.

GWETS Upgrades and Facility Projects

Unit 4 Chromium Water Treatment Plant – Envirogen participated in a meeting with the Trust in April 2021

to discuss moving this project forward. Envirogen is currently waiting for a response from the Trust on the scope split for the work, and where Envirogen's scope of work begins.

GWETS Extension – The signed Work Authorization for engineering and fabrication of the GWETS Extension was returned to the Trust on January 28, 2020. As a result of comments received from Clark County that prohibit the use of shipping containers as structures, Envirogen submitted a Work Authorization to the Trust for: re-designing the pump system containers to independent skids; modifying the electrical control panels; and providing 3-sided canopies to house sun sensitive equipment. The Work Authorization was signed by Envirogen and the Trust in March 2021. Envirogen received comments from the Trust regarding the GWETS O&M Work Authorization (Contract Amendment 8) and provided a response in March 2021.

GWETS Staffing

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

Tables

Operational Metrics

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) ^{4 5}	Chromium (TR) (mg/L) ^{4 5}	Chromium(VI) (mg/L) ^{4 5}
SWF Total Extraction ¹	750 ³	5.3	0.0010	0.0015
AWF Total Extraction ¹	462 ³	59	0.13	0.13
IWF Total Extraction ¹	61 ³	410	6.6	6.7
AP Area Total Extraction ¹	9.1 ³	638	0.16	0.15
GWTP Effluent ²	70	442	0.10	ND
GW-11 Influent ¹	1.5	40	0.06	0.037
FBR Influent ²	1,027	55	0.019	0.020

Notes:

TR = Total Recoverable; NA = Not Analyzed; ND = Not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Perchlorate and chromium TR sampled monthly, values reported from Eurofins TestAmerica.

2: Perchlorate, chromium TR, and chromium (VI) sampled weekly, values reported from Eurofins TestAmerica.

3: Sum of daily average flow for individual wells.

4: All concentrations reported are monthly flow weighted averages.

5: ND analytical values are treated as zero values in the flow weighted average calculations.

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) ¹	Chromium (TR) (lbs/month) ¹	Chromium (VI) (lbs/month) ¹
SWF Total Extraction	1,437	0.27	0.39
AWF Total Extraction	9,885	21	22
IWF Total Extraction	9,048	145	148
AP Area Total Extraction	2,085	0.52	0.49
GWTP Effluent	11,223	2.5	ND
GW-11 Influent	21	0.03	0.020
FBR Influent ¹	20,292	6.2	6.7

Notes:

TR = Total Recoverable; NA = Not Analyzed.

1: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).

Figures

Operational Metrics

Figure 1 - GW-11 Pond Volume Through 04/30/2021





Figure 2 - Historical Perchlorate Mass Removed From Environment



Attachment A

NPDES Tracking Sheet (Prepared by Ramboll)

Treated Effluent at Outfall 001																							
Continuous				Daily Samples, composited weekly				Weekly Grab Samples												Weekly, collected separately			Quarterly
Flow Rate		Perchlorate		pH		Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)	Total Suspended Solids (TSS)		Total Ammonia as N		Total Phosphorus as P		BOD ₅ (inhibited)			Total Dissolved Solids (TDS)			
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (µg/L)	30-Day Avg. (lbs/day)	Daily Min. (S.U.)	Daily Max. (S.U.)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (mg/L)	Daily Average (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	Daily Max. (mg/L)				
2.52	2.88	18	0.38	6.5	9.0	10	100	5,000	10,000	20	135	2,839	20*	10*	25	40	525	8,000					
January 2021		1.80	1.90	0.6	0.009	6.6	6.8	ND (<0.25)	12	100	1,300	1.0	19	290	4	7	ND (<5.0)	ND (<5.0)	38				
February 2021		1.76	1.85	0.55	0.008	6.5	6.7	ND (<0.25)	5.6	100	1,200	10	21	320	6	6.1	11	38	170	3,900			
March 2021		1.76	1.84	ND (<0.31)	0.0023	6.5	6.9	ND (<0.25)	2.2	110	1,100	1.4	15	220	2.6	6.6	5	15	80				
April 2021 (month to date)		1.72	1.82	3	0.05	6.6	7.2	ND (<0.25)	1.2	72	940	0.29	7	100	2.2	5.2	ND (<5.0)	ND (<5.0)	37	NA			
May 2021 (month to date)		1.64	1.84	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

Daily Grab Sample Dates	Composite Sample Date	µg/L	lbs/day	Sample Date	S.U.	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	Sample Date	mg/L			
1/3 - 1/9	1/9/2021	ND (<0.31)	0.16	0.0023	1/4/2021	6.6	ND (<0.25)	2.2	100	650	0.16	24	367	--	0.064	1.0	--	0.38	5.8	1/6/2021	ND (<5.0)	2.5	38	
1/10 - 1/16	1/16/2021	ND (<0.31)	0.16	0.0023	1/12/2021	6.7	ND (<0.25)	2.9	82	720	0.32	21	319	--	0.14	2.1	--	0.36	5.5	1/13/2021	ND (<5.0)	2.5	38	
1/17 - 1/23	1/23/2021	1.8	1.8	0.027	1/18/2021	6.8	ND (<0.25)	3.6	83	1,300	1.0	18	278	--	0.87	13	--	0.68	10	1/20/2021	ND (<5.0)	2.5	38	
1/24 - 1/30	1/30/2021	ND (<0.31)	0.16	0.0023	1/25/2021	6.6	ND (<0.25)	12	64	940	0.21	14	215	--	0.095	1.5	--	0.39	6.0	1/27/2021	ND (<5.0)	2.5	39	
1/31 - 2/6	2/6/2021	ND (<0.31)	0.16	0.0023	2/1/2021	6.7	ND (<0.25)	5.3	5.6*	49	880	1.1	13	198	--	0.99	15	--	0.43	6.6	2/3/2021	ND (<5.0)	2.5	38
2/7 - 2/13	2/13/2021	0.921	0.92	0.014	2/8/2021	6.6	ND (<0.25)	4.4	57	1,100	10	28	429	--	0.25	3.8	--	0.45	6.9	2/10/2021	ND (<5.0)	2.5	36	
2/14 - 2/20	2/20/2021	ND (<0.31)	0.16	0.0023	2/15/2021	6.5	ND (<0.25)	2.9	76	930	0.16	22	330	--	0.16	2.4	--	0.38	5.7	2/17/2021	38	569		
2/21 - 2/27	2/27/2021	0.961	0.96	0.0140	2/22/2021	6.7	ND (<0.25)	ND (<0.85)	100	1,200	0.19	21	316	--	0.16	2.4	--	0.34	5.1	2/24/2021	ND (<5.0)	2.5	37	
2/28 - 3/6	3/6/2021	ND (<0.31)	0.16	0.0022	3/2/2021	6.6	ND (<0.25)	1.1	96	570	1.4	11	155	--	0.30	4.2	--	0.34	4.8	3/4/2021	ND (<5.0)	2.5	38	
2/7 - 3/13	3/13/2021	ND (<0.31)	0.16	0.0023	3/8/2021	6.6	ND (<0.25)	2.2	110	760	0.21	20	286	--	0.21	3.0	--	0.37	5.3	3/10/2021	ND (<5.0)	2.5	37	
3/14 - 3/20	3/20/2021	ND (<0.31)	0.16	0.0023	3/15/2021	6.5	ND (<0.25)	ND (<0.85)	78	700	0.46	21	316	--	0.22	3.3	--	0.63	9.5	3/17/2021	ND (<5.0)	2.5	37	
3/21 - 3/27	3/27/2021	ND (<0.31)	0.16	0.0023	3/22/2021	6.9	ND (<0.25)	ND (<0.85)	53	1,100	ND (<0.050)	18	271	ND (<0.039)	0.020	0.29	--	0.55	8.3	3/24/2021	15	228		
3/28 - 4/3	4/3/2021	ND (<0.31)	0.16	0.0023	3/29/2021	6.6	ND (<0.25)	ND (<0.85)	61	840	0.25	ND (<10)	5	74	--	0.13	1.9	--	0.34	5.0	3/31/2021	ND (<5.0)	2.5	37
4/4 - 4/10	4/10/2021	10	10	0.14	4/5/2021	6.6	ND (<0.25)	1.1	38	880	0.22	ND (<10)	5	74	--	0.16	2.4	--	0.37	5.5	4/7/2021	ND (<5.0)	2.5	37
4/11 - 4/17	4/17/2021	ND (<0.31)	0.16	0.0023	4/12/2021	7.0	ND (<0.25)	ND (<0.85)	30	920	0.24	13	194	--	0.14	2.1	--	0.33	4.9	4/14/2021	ND (<5.0)	2.5	37	
4/18 - 4/24	4/24/2021	ND (<0.31)	0.16	0.0022	4/19/2021	7.0	ND (<0.25)	1.2	49	940	0.29	ND (<10)	5	75	--	0.15	2.2	--	0.33	4.9	4/21/2021	ND (<5.0)	2.5	37
4/25 - 5/1	5/1/2021	NA	NA	NA	4/23/2021	7.2	ND (<0.25)	ND (<0.85)	72	790	0.23	ND (<10)	5	75	--	0.15	2.3	--	0.35	5.3	4/28/2021	NA	NA	
					5/3/2021	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	5/5/2021	NA	NA	

Note: All analytical responsibilities are performed by TestAmerica Laboratories, Inc. (TestAmerica) in Irvine, California, unless otherwise indicated.

* An additional chromium sample was collected this week as part of the Quarterly sampling event.

NA = Not Available To Date

ND = Not Detected above laboratory reporting limit; concentration in adjacent cell to right is one-half the reporting limit (per Permit condition)

J = Result is less than the reporting limit but greater than or equal to the method detection limit and the concentration is an approximate value.

-- = Analyte detected; see column adjacent to right

* Total phosphorus discharge limitation of 10 lbs/day applies between March 1 and October 31; Ammonia discharge limitation of 20 lbs/day applies between April 1 and September 30; no limits apply the rest of the year.

Last Updated: May 7, 2021

Attachment B

Equipment Tracking Form

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
Main Plant Equipment						
1 Seep Wells and Lift Station 1						
1.01		Seep Well Field, 9 wells	Running		2	Repaired the breaker switch on the bucket for PC-119. Drilled out a new hole for the transducer on PC-116.
1.02		Lift Station 1 Lift Pump A	Running			
1.03		Lift Station 1 Lift Pump B	Standby			
1.04		Area in and around Lift Station 1	Running		3	Repaired the connections for the MCC air conditioner
2 Athens Road Wells and Lift Station 3						
2.01		Athens Road Well Field, 9 wells	Running			
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running		2	Replaced the check valve on the discharge of the turbine.
2.04		Area in and around Lift Station 3	Running			
3 Lift Station 2 and Transmission Pipelines						
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running			
4 Interceptor Wells and Cr Treatment Plant						
4.01		IWF Well Field, 30 wells	Running		2	Replaced the pump and .5 hp motor on I-I. Replaced the .5 hp motor on I-J.
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation			
4.05		Filter Press	Running			
4.06		GWTP Effluent Tank	In operation		1	Replaced the pump head of the new P-1001 mag drive pump.
4.07		Interceptor Booster Pump A	Running			
4.08		Interceptor Booster Pump B	Standby			
4.09		Area In And Around GWTP	Running			Powered down the plant to connect new wiring and grounding on the main power line. A new transformer was installed.
5 Equalization Area and GW-11 Pond						
5.01	PID10A	Pond GW-11	In operation			
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			
5.05	PID10A	Area in and Around EQ	In operation			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
5.06	PID10A	Raw Water Feed Pump - P102A				
5.07	PID10A	Raw Water Feed Pump - P102B				
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running			
6		First Stage FBRs A, 1 & 2				
6.01	PID14	FBR A				
6.02	PID14	Separator Tank - 1401			3	Rebuilt the bed height pump.
6.03	PID14	Media Return Pump - P 1401				
6.04	PID14	P1401A				
6.05	PID01A	P1401B				
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running		4	Flushing solids from the separator and transferring back into the FBR.
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012				
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running		2	A new metering pump was installed to replace the temporary pump.
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
7		First Stage FBRs 3 & 4				
7.01	PID01B	FBR 3	Running			
7.02	PID01B	FBR 4	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
7.03	PID02B	First Stage Separator Tank - T2012	Running			
7.04	PID01B	Media Return Pump - P2012	Running			
7.05	PID01B	First Stage FBR Pump - P1013	Running			
7.06	PID01B	First Stage FRB Pump - P1014	Running			
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723				
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
8		Second Stage FBRs 5 & 6				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running			
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
9		Second Stage FBRs 7 & 8				
9.01	PID03B	FBR 7	Running			
9.02	PID03B	FBR 8	Running			
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Running			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2= Important - Can still operate safely and in compliance with permits, but risks are increased
 3= Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4= Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running		2	Opened the electrical supply to remove water from the sprinkler system that entered the conduit. New connections were made and the conduit was sealed.
10		Aeration and DAF System				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Bio filter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump				
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running		2	Took the vessel offline to remove solids.
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running		2	Replaced the pump due to blown discs and check flaps.
10.14	PID05	DAF Vessel - D551	Running		2	Took the vessel offline to remove the solids.
10.15	PID05	DAF Pressure Pump - P551	Running			
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			
11		Pumping System (Old Effluent)				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602	Standby			
12		Sand Filter System				
12.01	PID17	Sand Filter			4	Repaired a damaged airlift.
12.02	PID17	Filter Reject Tank	In operation			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
13		Effluent Tank and Pumping				
13.01	PID10C	UV Effluent Tank	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2= Important - Can still operate safely and in compliance with permits, but risks are increased
 3= Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4= Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			
13.04	PID10C	Area Around Effluent and North D-1	Running			
14		Solids Collection and Pressing System				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation			
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902				
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			
		Chemical Systems				
15		Electron Donor System				
15.01	PID07B	Electron Donor Tank	In operation			
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23	PID07C	Ferric Chloride	In operation			
24	PID07B	Polymer Systems - DAF	In operation			
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
		Utility Systems				
26		Compressed Air System				
26.01	PID08	West Compressor	Running			
26.02	PID08	East Compressor	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
26.03	PID08	O2 Compressor	Running		2	The compressor has been repaired and is ready for service.
26.04	PID08	Compressed Air Receiver Tank	In operation			
26.05	PID08	Air Dryer	Running			
26.06	PID08	Oil Removal Filter	In operation			
26.07	PID08	Particulate Filter	In operation			
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			
29		Well Control System/ Allen Bradley Controls	In operation			
30		MCC FBR Pad	In operation			
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			
Miscellaneous Systems						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
Shelf Spares						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2= Important - Can still operate safely and in compliance with permits, but risks are increased
 3= Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4= Low - Minor repairs that in no way alter the performance of the plant