
To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: Michael Del Vecchio, Director Engineering and Project Management

Date: Oct 20, 2021

Subject: NERT – GWETS Operation Monthly Report – September 2021

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during September 2021.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in September 2021. Flow from PC-118, PC-119, PC-120, PC-121, and PC-133 was routed to the IX system, bypassing all flow meters associated with the FBR plant. The flow rate to the IX system averaged approximately 263 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 954 gpm during September 2021. At the end of the month, the available GW-11 Pond volume was at 34.4 million gallons (MG), which would allow 19.5 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The available water volume stored in the GW-11 Pond increased since the end of August 2021; Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 0.54 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 62 mg/L for the month, with a maximum concentration of 87 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of August 2021 averaged 62 mg/L, with a maximum concentration of 67 mg/L.

Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 graphically presents historical perchlorate and chromium mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11

There were no operational issues with GW-11 in the month of September.

2. Biological Plant

There were influent / effluent diversions during the reporting period generally associated with GW-11 pond level maintenance as well as extraction well short-term shutdown events. Below is a description of the events that occurred:

Diversion Events / Well Shutdowns

- Effluent diversion to GW-11 occurred on September 5, 2021 from 11:50pm to September 6, 2021 at 5:21am due to low GW-11 pond level. Approximately 302,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on September 12, 2021 from 11:22pm to September 13, 2021 at 8:50am due to low GW-11 pond level. Approximately 550,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on September 18, 2021 from 11:31pm to September 19, 2021 at 4:05am due to low GW-11 pond level. Approximately 266,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on September 19, 2021 from 10:58pm to September 20, 2021 at 3:45am due to low GW-11 pond level. Approximately 258,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on September 22, 2021 from 11:15pm to September 23, 2021 at 4:05am due to low GW-11 pond level. Approximately 255,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on September 27, 2021 from 11:11pm to September 28, 2021 at 3:45am due to low GW-11 pond level. Approximately 219,000 gallons of water were diverted to GW-11.
- Effluent diversion to GW-11 occurred on September 28, 2021 from 11:19pm to September 29, 2021 at 3:45am due to low GW-11 pond level. Approximately 279,000 gallons of water were diverted to GW-11.

3. Spills

There were no reportable spills in the month of September.

4. Maintenance

- Major maintenance performed by ETI in the reporting month included:
 - I. Installed a temporary recycle pump for the South DAF pressure tank.
 - II. Replaced a damaged combo valve on the Effluent pipeline.
 - III. Rebuilt the air diaphragm pump for Separator 2.
 - IV. Installed new positioners and actuators on the FBR 7 and 8 feed valves.
 - V. Installed a new outlet and mixer for the GWTP polymer tote.
 - VI. Installed a new handle for the feed line on the west press.
 - VII. Installed a new pressure gauge for the Influent side of the GAC vessels.
 - VIII. Installed a new flowmeter on AP Area extraction well E2-4.
 - IX. Installed a new lid on AP Area extraction well E2-3.
 - X. Rebuilt the pump for the bed height control on FBR A.
 - XI. Flushed the Effluent discharge line of GWTP.

- Preventative maintenance performed by ETI in the reporting month included:
 - I. Flushed the sand in the sand filter.
 - II. Cleaned the air filters on the Air Conditioners at lift station 3.
 - III. Changed the belts on the biofilter blower.
 - IV. Greased the FBR recycle pumps that are online.
 - V. Changed the oil on the turbine pump at Lift Station 2.
 - VI. Flushed the ORP lines and inspected the probes.
 - VII. Flushed the turbidity meters.
 - VIII. Cleaned out the DAF polymer pumps.
 - IX. Pressure washed the outfall.
 - X. Cleaned out the PC well vaults.

Attachment B contains a summary of all maintenance activities completed during the reporting period.

GWETS Upgrades and Facility Projects

Unit 4 Chromium Water Treatment Plant – Envirogen participated in a meeting with the Trust in April 2021 to discuss moving this project forward. Envirogen received notification at the end of May that the Trust will be repurposing one of the AP tanks to support the Unit 4 Source Area In-situ Bioremediation Treatability Study. Groundwater extracted as part of this treatability study will be conveyed to this tank via tanker truck where it will be stored and subsequently routed to the treatment plants for processing. Envirogen will take over responsibility for operating this tank for the duration of treatability study. Envirogen has established a scope of work for this activity and is currently working on preliminary design.

GWETS Extension – The signed Work Authorization for engineering and fabrication of the GWETS Extension was returned to the Trust on January 28, 2020. As a result of comments received from Clark County that prohibit the use of shipping containers as structures, Envirogen submitted a Work Authorization to the Trust for: re-designing the pump system containers to independent skids; modifying the electrical control panels; and providing 3-sided canopies to house sun sensitive equipment. The Work Authorization was signed by Envirogen and the Trust in March 2021. Components of the system have arrived onsite and are being stored until construction begins. Envirogen received comments from the Trust regarding the GWETS O&M Work Authorization (Contract Amendment 8) and provided a response in March 2021. The

Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Authorization has not been completed, Envirogen is waiting to receive the final version of the Contract Amendment.

GWETS Staffing

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

Tables

Operational Metrics

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) ^{4 5}	Chromium (TR) (mg/L) ^{4 5}	Chromium(VI) (mg/L) ^{4 5}
SWF Total Extraction ¹	741 ³	8.4	0.0011	0.0026
AWF Total Extraction ¹	454 ³	65	0.12	0.14
IWF Total Extraction ¹	57 ³	457	6.0	7.6
AP Area Total Extraction ¹	9.9 ³	707	0.16	0.17
GWTP Effluent ²	66	137	0.00	ND
GW-11 Influent ¹	0.1	78	0.07	0.003
FBR Influent ²	954	62	0.015	0.019

Notes:

TR = Total Recoverable; NA = Not Analyzed; ND = Not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

- 1: Perchlorate and chromium TR sampled monthly, values reported from Eurofins TestAmerica.
- 2: Perchlorate, chromium TR, and chromium (VI) sampled weekly, values reported from Eurofins TestAmerica.
- 3: Sum of daily average flow for individual wells.
- 4: All concentrations reported are monthly flow weighted averages.
- 5: ND analytical values are treated as zero values in the flow weighted average calculations.

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) ¹	Chromium (TR) (lbs/month) ¹	Chromium (VI) (lbs/month) ¹
SWF Total Extraction	2,236	0.29	0.68
AWF Total Extraction	10,613	20	22
IWF Total Extraction	9,457	123	158
AP Area Total Extraction	2,539	0.58	0.60
GWTP Effluent	3,254	0.00	ND
GW-11 Influent	3.7	0.00	0.000
FBR Influent ¹	21,452	5.3	6.4

Notes:

TR = Total Recoverable; NA = Not Analyzed.

1: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).

Figures

Operational Metrics

Figure 1 - GW-11 Pond Volume Through 9/30/2021





Figure 2 - Historical Perchlorate Mass Removed From Environment



Attachment A

NPDES Tracking Sheet (Prepared by Ramboll)

Treated Effluent at Outfall 001																		
Continuous		Daily Samples, composited weekly		Weekly Grab Samples										Weekly, collected separately			Quarterly	
Flow Rate		Perchlorate		pH	Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)	Total Suspended Solids (TSS)	Total Ammonia as N		Total Phosphorus as P		BOD ₅ (inhibited)			Total Dissolved Solids (TDS)
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	Daily Min. (S.U.)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (mg/L)	Daily Max. (mg/L)	Daily Average (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	Daily Max. (mg/L)	Daily Max. (mg/L)
2.52	2.88	18	0.38	6.5	9.0	10	100	5,000	10,000	20	135	2,839	20*	10*	25	40	525	8,000
January 2021	1.80	1.90	0.6	0.009	6.6	6.8	ND (<0.25)	12	100	1,300	1.0	19	290	4	7	ND (<5.0)	ND (<5.0)	38
February 2021	1.76	1.85	0.55	0.008	6.5	6.7	ND (<0.25)	5.6	100	1,200	1.0	21	320	6	6.1	11	38	170
March 2021	1.76	1.84	ND (<0.31)	0.0023	6.5	6.9	ND (<0.25)	2.2	110	1,100	1.4	15	220	2.6	6.6	5	15	80
April 2021	1.72	1.82	9	0.12	6.6	7.2	ND (<0.25)	1.2	72	940	0.29	7	100	2.2	5.2	ND (<5.0)	ND (<5.0)	37
May 2021	1.65	1.84	0.16	0.0021	6.5	6.9	ND (<4.0)	4.7	100	1,700	0.56	16	220	2.8	3.2	ND (<5.0)	ND (<5.0)	34
June 2021	1.72	1.82	0.16	0.0022	6.5	6.6	ND (<0.25)	2.1	78	990	0.69	15	230	1.7	5.7	ND (<5.0)	ND (<5.0)	35
July 2021	1.62	1.86	0.16	0.0021	6.6	7.0	ND (<0.25)	14	100	1,500	0.50	20	210	1.0	4.4	ND (<5.0)	ND (<5.0)	27
August 2021	1.69	1.84	0.16	0.0022	6.5	6.7	ND (<0.20)	3.7	110	1,900	0.67	17	250	3.1	6	ND (<4.3)	ND (<5.0)	30
September 2021 (month to date)	1.69	1.85	0.90	0.013	6.5	7.2	ND (<0.50)	ND (<0.85)	110	1,200	0.43	13	160	1.5	2.2	ND (<5.0)	ND (<5.0)	37

Daily Grab Sample Dates	Composite Sample Date	µg/L	lbs/day	Sample Date	S.U.	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	Sample Date	mg/L		
1/3 - 1/9	1/9/2021	ND (<0.31)	0.16	0.0023	1/4/2021	6.6	ND (<0.25)	2.2	100	650	0.16	24	367	--	0.064	1.0	--	0.38	5.8	1/6/2021	ND (<5.0)	2.5	38		
1/10 - 1/16	1/16/2021	ND (<0.31)	0.16	0.0023	1/12/2021	6.8	ND (<0.25)	2.9	82	720	0.32	21	319	--	0.14	2.1	--	0.36	5.5	1/13/2021	ND (<5.0)	2.5	38		
1/17 - 1/23	1/23/2021	1.8	0.027	1/18/2021	6.7	ND (<0.25)	3.6	83	1,300	1.0	18	278	--	0.87	13	--	0.68	10	1/20/2021	ND (<5.0)	2.5	38			
1/24 - 1/30	1/30/2021	ND (<0.31)	0.16	0.0023	1/25/2021	6.6	ND (<0.25)	1.2	64	940	0.21	14	215	--	0.095	1.5	--	0.39	6.0	1/27/2021	ND (<5.0)	2.5	39		
1/31 - 2/6	2/6/2021	ND (<0.31)	0.16	0.0023	2/1/2021	6.7	ND (<0.25)	5.3	56"	49	880	1.1	13	198	--	0.99	15	--	0.43	6.6	2/3/2021	ND (<5.0)	2.5	38	2/2/2021
2/7 - 2/13	2/13/2021	0.92	0.014	2/8/2021	6.6	ND (<0.25)	4.4	57	1,100	10	28	429	--	0.25	3.8	--	0.45	6.9	2/10/2021	ND (<5.0)	2.5	36			
2/14 - 2/20	2/20/2021	ND (<0.31)	0.16	0.0023	2/15/2021	6.5	ND (<0.25)	2.9	76	930	0.16	22	330	--	0.16	2.4	--	0.38	5.7	2/17/2021	38	569			
2/21 - 2/27	2/27/2021	0.96	0.0140	2/22/2021	6.7	ND (<0.25)	ND (<0.85)	100	1,200	0.19	21	316	--	0.16	2.4	--	0.34	5.1	2/24/2021	ND (<5.0)	2.5	37			
2/28 - 3/6	3/6/2021	ND (<0.31)	0.16	0.0022	3/2/2021	6.6	ND (<0.25)	1.1	96	570	1.4	11	155	--	0.30	4.2	--	0.34	4.8	3/4/2021	ND (<5.0)	2.5	38		
2/7 - 3/13	3/13/2021	ND (<0.31)	0.16	0.0023	3/8/2021	6.6	ND (<0.25)	2.2	110	760	0.21	20	286	--	0.21	3.0	--	0.37	5.3	3/10/2021	ND (<5.0)	2.5	37		
3/14 - 3/20	3/20/2021	ND (<0.31)	0.16	0.0023	3/15/2021	6.5	ND (<0.25)	ND (<0.85)	78	700	0.46	21	316	--	0.22	3.3	--	0.63	9.5	3/17/2021	ND (<5.0)	2.5	37		
3/21 - 3/27	3/27/2021	ND (<0.31)	0.16	0.0023	3/22/2021	6.9	ND (<0.25)	ND (<0.85)	53	1,100	ND (<0.050)	18	271	ND (<0.039)	0.020	0.29	--	0.55	8.3	3/24/2021	15	228			
3/28 - 4/3	4/3/2021	ND (<0.31)	0.16	0.0023	3/29/2021	6.6	ND (<0.25)	ND (<0.85)	61	840	0.25	ND (<10)	5	74	--	0.13	1.9	--	0.34	5.0	3/31/2021	ND (<5.0)	2.5	37	
4/4 - 4/10	4/10/2021	10	0.14	4/5/2021	6.6	ND (<0.25)	1.1	38	880	0.22	ND (<10)	5	74	--	0.16	2.4	--	0.37	5.5	4/7/2021	ND (<5.0)	2.5	37		
4/11 - 4/17	4/17/2021	ND (<0.31)	0.16	0.0023	4/12/2021	7.0	7.0'	ND (<0.25)	ND (<0.85)	30	920	0.24	13	194	--	0.14	2.1	--	0.33	4.9	4/14/2021	ND (<5.0)	2.5	37	
4/18 - 4/24	4/24/2021	ND (<0.31)	0.16	0.0022	4/19/2021	7.0	ND (<0.25)	1.2	49	940	0.29	ND (<10)	5	75	--	0.15	2.2	--	0.33	4.9	4/21/2021	ND (<5.0)	2.5	37	
4/25 - 5/1	5/1/2021	24	0.35	4/27/2021	7.2	ND (<0.25)	ND (<0.85)	72	790	0.23	ND (<10)	5	75	--	0.15	2.3	--	0.35	5.3	4/28/2021	ND (<5.0)	2.5	38		
5/2 - 5/8	5/8/2021	ND (<0.31)	0.16	0.0020	5/3/2021	6.8	ND (<4.0)	ND (<0.85)	54	950	0.33	ND (<10)	5	59	--	0.19	2.3	--	0.31	3.7	5/5/2021	ND (<5.0)	2.5	25	
5/9 - 5/15	5/15/2021	ND (<0.31)	0.16	0.0021	5/11/2021	6.7	ND (<0.25)	<0.85	<0.85	72	970	0.56	15	217	--	0.44	6.4	--	0.38	5.5	5/12/2021	ND (<5.0)	2.5	37	5/12/2021
5/16 - 5/22	5/22/2021	ND (<0.31)	0.16	0.0021	5/17/2021	6.9	ND (<0.25)	3.7	100	1,700	0.14	23	301	--	0.11	1.4	--	0.079	1.0	5/19/2021	ND (<5.0)	2.5	37		
5/23 - 5/29	5/29/2021	ND (<0.31)	0.16	0.0023	5/24/2021	6.5	ND (<0.25)	4.7	98	790	0.21	20	295	--	0.090	1.3	--	0.17	2.5	5/26/2021	ND (<5.0)	2.5	37		
5/30 - 6/5	6/5/2021	ND (<0.31)	0.16	0.0023	6/1/2021	6.6	ND (<0.25)	2.1	77	690	0.33	12	180	--	0.15	2.2	--	0.41	6.1	6/2/2021	ND (<5.0)	2.5	37		
6/6 - 6/12	6/12/2021	ND (<0.31)	0.16	0.0023	6/7/2021	6.6	ND (<0.20)	1.6	78	990	0.22	16	237	--	0.065	1.0	--	0.10	1.5	6/9/2021	ND (<5.0)	2.5	37		
6/13 - 6/19	6/19/2021	ND (<0.31)	0.16	0.0022	6/14/2021	6.6	ND (<0.20)	1.7	61	960	0.69	23	343	--	0.11	1.6	--	0.53	7.9	6/16/2021	ND (<5.0)	2.5	35		
6/20 - 6/26	6/26/2021	ND (<0.31)	0.16	0.0021	6/21/2021	6.5	ND (<0.20)	ND (<0.85)	50	530	0.35	15	222	--	0.12	1.8	--	0.36	5.3	6/23/2021	ND (<5.0)	2.5	30		
6/27 - 7/3	7/3/2021	ND (<0.31)	0.16	0.0022	6/28/2021	6.5	ND (<0.20)	1.4	54	860	0.52	11	164	--	0.12	1.8	--	0.52	7.8	6/30/2021	ND (<5.0)	2.5	30		
7/4 - 7/10	7/10/2021	ND (<0.31)	0.16	0.0022	7/6/2021	6.7	ND (<0.20)	1.9	55	630	0.27	20	205	--	0.084	0.86	--	0.31	3.2	7/7/2021	ND (<5.0)	2.5	37		
7/11 - 7/17	7/17/2021	ND (<0.31)	0.16	0.0021	7/12/2021	6.6	ND (<0.20)	0.94	45	750	0.22	ND (<10)	5	66	--	0.058	0.76	--	0.28	3.7	7/14/2021	ND (<5.0)	2.5	37	
7/18 - 7/24	7/24/2021	ND (<0.31)	0.16	0.0017	7/20/2021	6.6	ND (<0.20)	1.4	100	1,500	0.50	45	404	--	0.22	2.0	--	0.45	4.0	7/21/2021	ND (<5.0)	2.5	34		
7/25 - 7/31	7/31/2021	ND (<0.31)	0.16	0.0024	7/27/2021	7.0	ND (<0.25)	2.7	100	1,100	ND (<0.050)	11	171	ND (<0.039)	0.020	0.30	--	0.43	6.7	7/28/2021	ND (<5.0)	2.5	38		
8/1 - 8/7	8/7/2021	ND (<0.31)	0.16	0.0023	8/2/2021	6.5	ND (<0.20)	1.2	36	1,900	0.67	29	445	--	0.40	6.1	--	0.88	14	8/4/2021	ND (<5.0)	2.5	37		
8/8 - 8/14	8/14/2021	ND (<0.31)	0.16	0.0022	8/9/2021	6.5	ND (<0.20)	2.5	91	730	0.50	16	238	--	0.14	2.1	--	0.42	6.3	8/11/2021	ND (<5.0)	2.5	31		
8/15 - 8/21	8/21/2021	ND (<0.31)	0.16	0.0022	8/17/2021	6.5	ND (<0.20)	1.8	110	860	0.39	ND (<10)	5	60	--	0.17	2.0	--	0.33	4.0	8/18/2021	ND (<2.0)	1.0	13	
8/22 - 8/28	8/28/2021	ND (<0.31)	0.16	0.0020	8/23/2021	6.5	ND (<0.20)	3.7	99	530	0.27	12	175	--	0.21	3.1	--	0.32	4.7	8/25/2021	ND (<5.0)	2.5	37		
8/29 - 9/4	9/4/2021	0.97	0.014	8/30/2021	6.7	ND (<0.20)	ND (<0.85)	100	640	0.32	21	313	--	0.13	1.9	--	0.23	3.4	9/1/2021	ND (<5.0)	2.5	37			
9/5 - 9/11	9/11/2021	0.93	0.013	9/7/2021	7.0	ND (<0.20)	ND (<0.85)	110	450	0.21	10	150	--	0.044	0.66	--									

Attachment B

Equipment Tracking Form

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
Main Plant Equipment						
1		Seep Wells and Lift Station 1				
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running			
1.03		Lift Station 1 Lift Pump B	Standby			
1.04		Area in and around Lift Station 1	Running			
2		Athens Road Wells and Lift Station 3				
2.01		Athens Road Well Field, 9 wells	Running			
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running			
3		Lift Station 2 and Transmission Pipelines				
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running		3	Replaced a damaged combo valve.
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running			
4		Interceptor Wells and Cr Treatment Plant				
4.01		IWF Well Field, 30 wells	Running		3	Replaced a flowmeter on the AP-5 well E2-4. Installed a new lid on E2-3.
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running		3	Installed new tubing on the discharge of the pump. Set up a new mixer on the polymer tote.
4.04		Clarifier	In operation			
4.05		Filter Press	Running		3	Installed a rebuilt press feed pump.
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Running			
4.08		Interceptor Booster Pump B	Standby			
4.09		Area In And Around GWTP	Running		2	Bypassed the EFF line of the plant to jet the pipeline.
5		Equalization Area and GW-11 Pond				
5.01	PID10A	Pond GW-11	In operation		3	Replaced the flowmeter on the SW pond corner. Replaced the electrical leads for the pump on the NW corner. Install all new fittings, pump and motor on the SW corner.
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			
5.05	PID10A	Area in and Around EQ	In operation		3	Replaced the pressure gauge on the INF side of the GAC's.

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
5.06	PID10A	Raw Water Feed Pump - P102A				
5.07	PID10A	Raw Water Feed Pump - P102B				
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running			
6		First Stage FBRs A, 1 & 2				
6.01	PID14	FBR A				
6.02	PID14	Separator Tank - 1401				
6.03	PID14	Media Return Pump - P 1401				
6.04	PID14	P1401A				
6.05	PID01A	P1401B				
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012				
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
7		First Stage FBRs 3 & 4				
7.01	PID01B	FBR 3	Running			
7.02	PID01B	FBR 4	Running			
7.03	PID02B	First Stage Separator Tank - T2012	Running			
7.04	PID01B	Media Return Pump - P2012	Running			
7.05	PID01B	First Stage FBR Pump - P1013	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
7.06	PID01B	First Stage FRB Pump - P1014	Running			
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723				
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
8		Second Stage FBRs 5 & 6				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running		3	Replaced the belt on the pump.
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
9		Second Stage FBRs 7 & 8				
9.01	PID03B	FBR 7	Running		3	Installed a new positioner and actuator on the feed valve.
9.02	PID03B	FBR 8	Running		3	Installed a new positioner and actuator on the feed valve.
9.03	PID03D	Second Stage Separator Tank - T3012	Running		4	Set up the 3" AOD to transfer any solids that were accumulated in the separator.
9.04	PID03B	Media Return Pump - P3012	Running			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Running			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			
10		Aeration and DAF System				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Bio filter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump				
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running			
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running		3	Replaced 2 damaged links on the N.DAF skimmer system.
11		Pumping System (Old Effluent)				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602				
12		Sand Filter System				
12.01	PID17	Sand Filter			1	Took the sand filter offline to flush and clean the sand.
12.02	PID17	Filter Reject Tank	In operation			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
13		Effluent Tank and Pumping				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby		2	Replaced the discharge check valve.
13.04	PID10C	Area Around Effluent and North D-1	Running			
14		Solids Collection and Pressing System				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
14.03	PID16	Solids Cond. Tank	In operation			
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902				
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			
Chemical Systems						
15		Electron Donor System				
15.01	PID07B	Electron Donor Tank	In operation			
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23	PID07C	Ferric Chloride	In operation			
24	PID07B	Polymer Systems - DAF	In operation			
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
Utility Systems						
26		Compressed Air System				
26.01	PID08	West Compressor	Running			
26.02	PID08	East Compressor	Running		2	The compressor is offline to make repairs to the oil cooler system.
26.03	PID08	O2 Compressor	Running			
26.04	PID08	Compressed Air Receiver Tank	In operation			
26.05	PID08	Air Dryer	Running			
26.06	PID08	Oil Removal Filter	In operation			
26.07	PID08	Particulate Filter	In operation			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			
29		Well Control System/ Allen Bradley Controls	In operation			
30		MCC FBR Pad	In operation			
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			
Miscellaneous Systems						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
Shelf Spares						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant