
To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: Michael Del Vecchio, Director Engineering and Project Management

Date: Feb 20, 2022

Subject: NERT – GWETS Operation Monthly Report – January 2022

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during January 2022.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in January 2022. Flow from PC-118, PC-119, PC-120, PC-121, and PC-133 was routed to the IX system, bypassing all flow meters associated with the FBR plant. The flow rate to the IX system averaged approximately 265 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 992 gpm during January 2022. At the end of the month, the available GW-11 Pond volume was at 36.8 million gallons (MG), which would allow 17.8 days of available additional storage in the event of an emergency FBR plant shutdown with continued well field pumping. The available water volume stored in the GW-11 Pond decreased since the end of December 2021; Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the IX system averaged 1.3 mg/L for the month. The influent perchlorate concentration to the FBR plant averaged 58 mg/L for the month, with a maximum concentration of 69 mg/L. In comparison, the influent perchlorate concentration to the FBRs for the month of December 2021 averaged 42 mg/L, with a maximum concentration of 71 mg/L.

Enhanced Operational Metrics

Tables 1 and 2 provide a summary of the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 graphically presents historical perchlorate and chromium mass flux information. Attachment A provides a summary of the NPDES permit analytes with numerical discharge limits.

Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11

There were no operational issues with GW-11 in the month of January.

2. Biological Plant

There were influent / effluent diversions during the reporting period generally associated with GW-11 pond level maintenance as well as extraction well short-term shutdown events. Below is a description of the events that occurred:

Diversion Events / Well Shutdowns

- Athens Well Field (AWF) Extraction well ART 8A shutdown occurred on January 6, 2022 from 9:45am to 10:14am due to maintenance efforts to replace the motor. Maintenance was completed and the well was brought back online.
- Effluent diversion to GW-11 occurred on January 8, 2022 from 5:20am to 7:40am due to high effluent turbidity as a result of a malfunctioning Hydrogen Peroxide feed pump. The chemical feed pump was replaced, adjustments were made to the process and the effluent was returned to the outfall. Approximately 158,000 gallons of water were diverted to GW-11.
- Athens Well Field (AWF) Extraction wells ART 9, ART 7, PC-150 shutdown occurred on January 18, 2022 from 7:15am to 3:15pm due to maintenance efforts to relieve overheating of the Lift Station 2 control panel as part of the ongoing repair/replace project associated with Amendment 8. Maintenance was completed, the electrical panels were brought online, and the wells were brought back online.
- Athens Well Field (AWF) shutdown occurred on January 19, 2022 from 7:23am to 2:08pm due to maintenance efforts to relieve overheating of the Lift Station 2 control panel as part of the ongoing repair/replace project associated with Amendment 8. Maintenance was completed, the electrical panels were brought online, and the well field was brought back online.
- Interceptor Well Field (IWF) extraction well I-R shutdown occurred on January 30, 2022 from 1:13pm to January 31, 2022 at 7:30am due to a malfunctioning pump motor. The well was pulled, the motor was replaced, and the well was brought back online.

3. Spills

There were no reportable spills in the month of January.

4. Maintenance

- Major maintenance performed by ETI in the reporting month included:
 - I. Replaced the gasket on the discharge line of the Lift Station 2 vertical turbines.
 - II. Rebuilt the airlifts for the sand filter.
 - III. Installed new splash guards around the airlifts for the sand filter.
 - IV. Replaced the blind flange on the discharge of the 1302 effluent pumps.
 - V. Installed a new pump on ART-8A.
 - VI. Built a new strainer basket for the Lift Station 3 (LS3) vertical turbines.
 - VII. Repaired the suction piping on the bed height pump for FBR 4.
 - VIII. Rebuilt the polymer injection line at the GWTP.
 - IX. Changed a fuse on IWF extraction well I-Y. Installed a new ½ hp motor on IWF extraction well I-AA.
 - X. Installed a new SLMW backflush valve on the South GAC.

- Preventative maintenance performed by ETI in the reporting month included:
 - I. Replaced the tire on the truck.
 - II. Checked the fluid and replaced batteries on the maintenance cart as needed.
 - III. Cleaned and flushed the level control sensor on tank T-601.
 - IV. Installed a SLMW line for the filter press.
 - V. Installed new light bulbs at the GWTP and by FBR A.
 - VI. Cleaned and inspected the GWTP effluent meter.
 - VII. Inspected and changed the oil on the Lift Station 1 vertical turbines.
 - VIII. Inspected and tested the breakers at LS3.
 - IX. Greased the bio-filter blower.
 - X. Changed out the belts on the bio-filter blower and the aeration blower.

Attachment B contains a summary of all maintenance activities completed during the reporting period.

Facility Projects

1. Chromium Treatment Subsystem – Envirogen submitted a Work Authorization for this scope in January 2022. Envirogen is targeting May of 2022 to complete the modifications required to treat groundwater extracted as part of the Unit 4 Source Area In-Situ Bioremediation Treatability Study as well as the flow currently routed to the existing Chromium Treatment Plant (i.e. GWTP) from the IWF and AP Area wells. With the current supply chain issues, once approved, Envirogen will move to quickly verify the targeted completion date.

2. Treatment System Extension (TSE) – Envirogen has delivered all of the contracted equipment for the GWETS extension. TSE construction and system start-up is being facilitated by Arcadis through terms with the Trust and began in December. ETI will incorporate a summary of the treatment operations once the system becomes operational (anticipated to occur in 4Q 2022).

3. Facility Repair/Replacement Items – Envirogen and the Trust have finalized a list of facility items to be addressed in connection with Amendment 8 to the O&M Agreement. Attachment C contains a status summary of all agreed upon items prepared by the Trust. Specific details on in-progress items are provided below:
 - I. (WA 21-02) East Air Compressor - Complete
 - II. (WA 21-03) Wiring at Lift Station 3
 1. Concrete pads were poured in preparation for wiring cabinets.
 - III. (WA 21-04) Motor Control Center at Lift Station 1 (Authorization received from the Trust. Procurement/planning in progress)
 - IV. (WA 21-05) Replacement of Safety Shower System (Authorization received from the Trust. Procurement/planning in progress)
 - V. (WA 21-06) Influent Pipeline Combination Valves (Authorization received from the Trust. Procurement/planning in progress)
 - VI. (WA 21-07) Replacement of all pH and ORP probes (Authorization received from the Trust. Procurement/planning in progress)
 - VII. (WA 21-08) Wiring IWF wells (Authorization received from the Trust. Procurement/planning in progress)
 - VIII. (WA 21-09) Siemens controls upgrade (Authorization received from the Trust. Procurement/planning in progress)
 - IX. (WA 22-01) DAF Pilot (Authorization received from the Trust. Procurement/planning in progress)
 - X. (WA 22-02) Sludge Pump and Bins (Authorization received from the Trust. Procurement/planning in progress)
 - XI. (WA 22-03) Influent and Effluent Pump Motors (Authorization received from the Trust. Procurement/planning in progress)
 - XII. (WA 22-04) FBR Skid Upgrades (Authorization received from the Trust. Procurement/planning in progress)
 - XIII. (WA 22-05) Large Valve Upgrades (Authorization received from the Trust. Procurement/planning in progress)

4. Improved Biological Treatment Plant Efficiency – Consistent with Attachment D to the December 2021 GWETS Operation Monthly Report, Envirogen plans to take five FBRs out of service and maintain them in working condition should they be needed in the future. This action will reduce the use of electricity and water and still maintain sufficient treatment capacity to address current groundwater extracted from the IWF, AWF, and the SWF as well as groundwater to be extracted as part of the Unit 4 Source Area In-Situ Bioremediation Treatability Study.

Tables

Operational Metrics

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) ^{4 5}	Chromium (TR) (mg/L) ^{4 5}	Chromium(VI) (mg/L) ^{4 5}
SWF Total Extraction ¹	752 ³	8.2	0.0012	0.0020
AWF Total Extraction ¹	469 ³	51	0.14	0.15
IWF Total Extraction ¹	57 ³	431	5.8	5.9
AP Area Total Extraction ¹	8.7 ³	606	0.17	0.16
GWTP Effluent ²	58	448	0.26	ND
GW-11 Influent ¹	0.22	51	0.071	0.0079
FBR Influent ²	992	58	0.061	0.056

Notes:

TR = Total Recoverable; ND = Not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Perchlorate and chromium TR sampled monthly, values reported from Eurofins TestAmerica.

2: Perchlorate, chromium TR, and chromium (VI) sampled weekly, values reported from Eurofins TestAmerica.

3: Sum of daily average flow for individual wells.

4: All concentrations reported are monthly flow weighted averages.

5: ND analytical values are treated as zero values in the flow weighted average calculations.

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics			
Location ID	Perchlorate (lbs/month) ¹	Chromium (TR) (lbs/month) ¹	Chromium (VI) (lbs/month) ¹
SWF Total Extraction	2,310	0.34	0.56
AWF Total Extraction	8,972	24	25
IWF Total Extraction	9,180	123	126
AP Area Total Extraction	1,963	0.54	0.51
GWTP Effluent	9,635	5.7	ND
GW-11 Influent	4.1	0.01	0.00
FBR Influent ¹	21,321	18	16.3

Notes:


TR = Total Recoverable.

1: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).

Figures

Operational Metrics


Figure 1 - GW-11 Pond Volume Through 01/31/2022



Notes:

1. A transducer installed along the eastern berm provides water pressure measurements that are correlated to elevations for calculation of water depths.

Figure 2 - Historical Perchlorate Mass Removed From Environment



Attachment A

NPDES Tracking Sheet (Prepared by Ramboll)

Treated Effluent at Outfall 001																					
Continuous		Daily Samples, composited weekly				Weekly Grab Samples										Weekly, collected separately			Quarterly		
Flow Rate		Perchlorate				pH	Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)	Total Suspended Solids (TSS)		Total Ammonia as N		Total Phosphorus as P		BOD ₅ (inhibited)			Total Dissolved Solids (TDS)
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (µg/L)	30-Day Avg. (lbs/day)			Daily Min. (S.U.)	Daily Max. (S.U.)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (µg/L)	Daily Max. (mg/L)	Daily Average (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	Daily Max. (mg/L)	Daily Max. (mg/L)
2.52	2.88	18	0.38			6.5	9.0	10	100	5,000	10,000	20	135	2,839	20*	10*	25	40	525		8,000
December 2021	1.78	1.88	1.0	0.015		6.5	6.6	ND (<0.50)	26	94	1,400	0.26	ND(<10)	70	1.4	6.2	11	43	160		3,200
January 2022	1.85	1.92	0.70	0.011		7.0	7.4	ND (<0.50)	12	61	1,100	0.88	10	150	2.1	6.9	ND (<5.0)	ND (<5.0)	40		NA
February 2022 (month to date)	1.86	1.91	3.8	0.059		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	ND (<5.0)	ND (<5.0)	40		NA

Daily Grab Sample Dates	Composite Sample Date	µg/L	lbs/day	Sample Date	S.U.	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	Sample Date	mg/L				
11/28 - 12/4	12/4/2021	0.91	0.91	0.013													12/1/2021	ND (<5.0)	2.5	36					
12/5 - 12/11	12/11/2021	ND (<0.31)	0.16	0.0024	12/6/2021	6.6	ND (<0.50)	ND (<0.85)	94	830	0.26	ND(<10)	5	77	--	0.098	1.5	--	0.49	7.5	12/8/2021	ND (<5.0)	2.5	38	
12/12 - 12/18	12/18/2021	ND (<0.31)	0.16	0.0022	12/13/2021	6.6	ND (<0.50)	2.7	78	940	0.26	ND(<10)	5	72	--	0.11	1.6	--	0.43	6.2	12/15/2021	43	640		
12/19 - 12/25	12/25/2021	3.7	3.7	0.055	12/20/2021	6.5	ND (<0.50)	26	49	1,400	0.25	ND(<10)	5	58	--	0.092	1.1	--	0.48	5.6	12/22/2021	ND (<5.0)	2.5	39	
12/26 - 1/1	1/1/2022	ND (<0.31)	0.16	0.0024	12/27/2021	6.5	ND (<0.50)	1.7	23	450	0.26	ND(<10)	5	78	--	0.091	1.4	--	0.34	5.3	12/29/2021	ND (<5.0)	2.5	39	
1/2 - 1/8	1/8/2022	ND (<0.31)	0.16	0.0024	1/3/2022	7.0	ND (<0.50)	4.8	11	910	0.35	14	220	--	0.13	2.0	--	0.47	7.4	1/5/2022	ND (<5.0)	2.5	39		
1/9 - 1/15	1/15/2022	0.61	0.61	0.0094	1/10/2022	7.4	ND (<0.50)	2.2	38	600	0.41	ND(<10)	5	78	--	0.18	2.8	--	0.25	3.9	1/12/2022	ND (<5.0)	2.5	38	
1/16 - 1/22	1/22/2022	0.52	0.52	0.0081	1/17/2022	7.2	ND (<0.50)	12	55	1,100	0.64	19	301	--	0.16	2.5	--	0.73	12	1/19/2022	ND (<5.0)	2.5	39		
1/23 - 1/29	1/29/2022	1.5	1.5	0.023	1/24/2022	7.0	ND (<0.50)	1.4	61	530	0.63	ND(<10)	5	78	--	0.10	1.6	--	0.34	5.3	1/26/2022	ND (<5.0)	2.5	39	
1/30 - 2/5	2/5/2022	3.8	3.8	0.059	1/31/2022	7.2	ND (<0.50)	3.1	56	720	0.88	ND(<10)	5	78	--	0.084	1.3	--	0.41	6.4	2/2/2022	ND (<5.0)	2.5	40	
					2/7/2022	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	2/9/2022	NA	NA

Note: All analytical responsibilities are performed by TestAmerica Laboratories, Inc. (TestAmerica) in Irvine, California, unless otherwise indicated.

* An additional sample was collected this week.

** Sample result has quality control (QC) qualifiers. CBOD was detected in the control blank and therefore the laboratory control sample (LCS) is outside acceptance limits.

J = Result is less than the reporting limit but greater than or equal to the method detection limit and the concentration is an approximate value.

NA = Not Available To Date

ND = Not Detected above laboratory reporting limit; concentration in adjacent cell to right is one-half the reporting limit (per Permit condition)

-- = Analyte detected; see column adjacent to right

* Total phosphorus discharge limitation of 10 lbs/day applies between March 1 and October 31; Ammonia discharge limitation of 20 lbs/day applies between April 1 and September 30; no limits apply the rest of the year.

Last Updated: February 11, 2022

Attachment B

Equipment Tracking Form

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
Main Plant Equipment						
1		Seep Wells and Lift Station 1				
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running			
1.03		Lift Station 1 Lift Pump B	Standby		2	Installed a new butterfly on the discharge of the pump.
1.04		Area in and around Lift Station 1	Running			
2		Athens Road Wells and Lift Station 3				
2.01		Athens Road Well Field, 9 wells	Running		2	Changed out the pump on ART-8A. The old pump had a worn shaft.
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running		1	Contractors performing work to relocate the MCC cabinets causing numerous shutdowns of the wells temporarily.
3		Lift Station 2 and Transmission Pipelines				
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running		1	Changed out a worn 6" gasket on the pipe of the discharge line
4		Interceptor Wells and Cr Treatment Plant				
4.01		IWF Well Field, 30 wells	Running		2	Replaced a fuse on I-Y. Replaced the 1/2 hp motor on I-AA.
4.02		Ferrous Sulfate Feed System	Running		4	Wrapped the line in insulation to keep from freezing.
4.03		Polymer Feed System	Running		4	Installed a new drain hose from the tote.
4.04		Clarifier	In operation			
4.05		Filter Press	Running			
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Running			
4.08		Interceptor Booster Pump B	Standby			
4.09		Area In And Around GWTP	Running		2	Pulled and cleaned the EFF flowmeter
5		Equalization Area and GW-11 Pond				
5.01	PID10A	Pond GW-11	In operation		3	Repaired worn splices on the NW corner. Replaced the pigtail on the SE corner.
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			
5.05	PID10A	Area in and Around EQ	In operation		3	Pulled the flowmeter from GW-11 to the EQ tanks to inspect and connect new grounding wires.

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
5.06	PID10A	Raw Water Feed Pump - P102A				
5.07	PID10A	Raw Water Feed Pump - P102B				
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running		3	Installed a new SLW backwash valve.
6		First Stage FBRs A, 1 & 2				
6.01	PID14	FBR A				
6.02	PID14	Separator Tank - 1401				
6.03	PID14	Media Return Pump - P 1401				
6.04	PID14	P1401A				
6.05	PID01A	P1401B				
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012				
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
7		First Stage FBRs 3 & 4				
7.01	PID01B	FBR 3	Running		3	Replaced the communication card for the feed valve.
7.02	PID01B	FBR 4	Running		4	Repaired the piping on the bed height pump.
7.03	PID02B	First Stage Separator Tank - T2012	Running			
7.04	PID01B	Media Return Pump - P2012	Running			
7.05	PID01B	First Stage FBR Pump - P1013	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
7.06	PID01B	First Stage FRB Pump - P1014	Running			
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723				
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
8		Second Stage FBRs 5 & 6				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running			
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
9		Second Stage FBRs 7 & 8				
9.01	PID03B	FBR 7	Running			
9.02	PID03B	FBR 8	Running			
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Running			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			
10		Aeration and DAF System				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Bio filter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump				
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running		2	Replaced the discharge pressure control valve.
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running		4	Repaired links on the S.DAF.
11		Pumping System (Old Effluent)				
11.01	PID06	Effluent Tank 601	In operation		3	Re-calibrated the level control sensor.
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602				
12		Sand Filter System				
12.01	PID17	Sand Filter			4	Rebuilt all the airlifts. Installed new sand splash guards.
12.02	PID17	Filter Reject Tank	In operation		3	Removed solids from the tank.
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
13		Effluent Tank and Pumping				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			
13.04	PID10C	Area Around Effluent and North D-1	Running			
14		Solids Collection and Pressing System				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902				
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			
Chemical Systems						
15	Electron Donor System					
15.01	PID07B	Electron Donor Tank	In operation			
15.02	PID07B	Booster Pump P739A	Running			
15.03	PID07B	Booster Pump P739B	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation		3	Replaced the pump head and the tubing.
23	PID07C	Ferric Chloride	In operation			
24	PID07B	Polymer Systems - DAF	In operation		3	Replaced the entire suction portion of the pump.
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
Utility Systems						
26	Compressed Air System					
26.01	PID08	West Compressor	Running			
26.02	PID08	East Compressor	Running			
26.03	PID08	O2 Compressor	Running			
26.04	PID08	Compressed Air Receiver Tank	In operation			
26.05	PID08	Air Dryer	Running			
26.06	PID08	Oil Removal Filter	In operation			
26.07	PID08	Particulate Filter	In operation			
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1= Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
29		Well Control System/ Allen Bradley Controls	In operation			
30		MCC FBR Pad	In operation			
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			
Miscellaneous Systems						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
Shelf Spares						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			

Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service

Criticality Codes

1 = Critical - Cannot continue with operation until repairs made
 2 = Important - Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate - Work needs to be performed, but plant can still operate with redundancy that is in place
 4 = Low - Minor repairs that in no way alter the performance of the plant

Attachment C

Facility Repair/Replacement Project Status

GWETS AMENDMENT 8 REPAIR/REPLACEMENT STATUS

PREPARED BY NEVADA ENVIRONMENTAL RESPONSE TRUST

ITEM	RESOLUTION	WORK AUTHORIZATION	STATUS AS OF 1/31/22	
1	Dissolved Air Floatation (DAF) Vessels	ETI to pilot an alternate technology (AquaDisk filters) and make a recommendation	ETI WA 22-01 \$58,203 <i>Executed 1/13/22</i>	Work Authorization approved by NERT on 1/13/22. Procurement and installation planning underway.
2	DAF Pump Skid Rebuild	On-hold pending outcome of DAF pilot and evaluation of plant hydraulics	N/A	N/A
3	Main Influent Pipeline Air/Vacuum Release Valves	ETI to replace valves and valve boxes as required	ETI WA 21-06 \$40,535 <i>Executed 12/21</i>	Procurement and installation planning underway.
4	In-kind Replacement of GWTP	GWTP replacement not required due to design/build of Chromium Treatment Subsystem	N/A	N/A
5	Wiring at Lift Station #3 (controls)	ETI to replace wiring as required	ETI WA 21-03 \$60,035 <i>Executed 11/21</i>	Site work is continuing. Current estimated completion is April/May 2022.
6	Wiring at Lift Station #1 (wells)	Project on hold due to potential modification of the SWF with ROD or due to Cadence Sports Park. NERT will authorize interim repairs if necessary.	N/A	N/A
7	Motor Control Center at Lift Station #1	ETI to replace as required	ETI WA 21-04 \$186,315 <i>Executed 12/21</i>	Procurement and installation planning underway.
8	IWF Wiring	ETI to replace as required	ETI WA 21-08 \$436,481 <i>Executed 12/21</i>	Site work has begun. Current estimated completion is May/June 2022.
9	FBR Skid Equipment Replacements	ETI to replace what is immediately required in lieu of complete replacements	-	Draft Work Authorization submitted to the Trust 12/10/21.
10	Influent / Effluent Pump Motors	ETI to procure additional motors for more frequent rotation	-	Draft Work Authorization submitted to the Trust 12/05/21.
11	Overhaul Lift Station #2 West Wet Well Turbine	ETI to overhaul as required	-	Preparation of draft Work Authorization by ETI in progress. To Trust by 2/28.
12	Replacement of Safety Showers	ETI to replace safety shower system in batches over ~2 years	ETI WA 21-05 \$131,899 <i>Executed 11/21</i>	Procurement and installation planning underway.

GWETS AMENDMENT 8 REPAIR/REPLACEMENT STATUS

PREPARED BY NEVADA ENVIRONMENTAL RESPONSE TRUST

ITEM		RESOLUTION	WORK AUTHORIZATION	STATUS AS OF 1/31/22
13	East Air Compressor	ETI to replace as required	ETI WA 21-02 \$29,784 <i>Executed 10/21</i>	Compressor installed. Project complete.
14	pH and ORP Probes	ETI to replace certain probes as required throughout FBR plant	ETI WA 21-07 \$108,893 <i>Executed 11/21</i>	Procurement and installation planning underway. Estimated completion by June 2022
15	Exterior Shell of Ethanol Storage Tank	ETI to repair as required	-	Submittal of draft Work Authorization for Trust review by 6/30/22.
16	FBR Containment Pad Concrete	ETI to monitor status of affected areas. NERT will authorize interim repairs if necessary.	N/A	N/A
17	Siemens Control System Repairs	Spare parts and software updates to be procured in lieu of a complete system replacement.	ETI WA 21-09 \$103,061 <i>Executed 11/21</i>	Procurement and installation planning underway. Spare parts currently arriving
18	Sludge Pump and Sludge Bins	ETI to replace as required	-	Draft Work Authorization submitted to the Trust 12/06/21.
19	Lift Station Repairs	ETI to replace as required	-	Draft Work Authorization submitted to the Trust 12/10/21.
20	D-1 Asbestos Evaluation	NERT to complete an asbestos survey	TT WA 21-12 \$7,400 <i>Executed 11/21</i>	Survey complete. Report preparation in progress.