

## MEMORANDUM TO FILE

**TO:** KM File

**FROM:** Brian Rakvica

**DATE:** August 4, 2004

**CC:** Todd Croft, Jennifer Carr, Jeff Johnson, Jim Najima, Jon Palm, Tamara Pelham, Alan Tinney, Leo Drozdoff, Valerie King

**RE:** KM Conference Call on August 3, 2004 at 3:30 PM

1. Attendance:
  - a. NDEP: Todd Croft, Tamara Pelham, Brian Rakvica
  - b. KM: Keith Bailey, Susan Crowley
2. Reviewed system operations.
  - a. System is operating at ~950 gpm and between 67-75% of the chemical load.
  - b. KM noted that they would like to operate the system as is for a couple of weeks or so to make sure that the system continues to operate correctly prior to increasing chemical loading. If the system is still working well KM will increase the chemical loading.
  - c. KM noted that the discharge was slightly cloudy on Sunday and Monday due to an issue with the filtrate from the filter press. KM discontinued the addition of this filtrate and is working on the problem. Discharge is currently ~ 15 NTU.
3. Discussed discharge location.
  - a. KM reviewed with Tamara. BWPC requires the change to be submitted to Nadir Sous. Tamara will include a memo to file to correct the fact sheet.
  - b. KM still needs to discuss with the County and others.
4. Next call: Tuesday, August 11, 2004 at 1:30 PM. Call in number to be provided.