



May 26, 2011

Mr. John Pekala
ENVIRON International Corporation
560 West Lake Mead Parkway
Henderson, Nevada 89015

Regarding: *Final Visual Inspection – Pipe Abatement within RZ-C-24*
Nevada Environmental Response Trust
560 West Lake Mead Parkway
Henderson, Nevada 89015
Project No. - CON111106

Dear Mr. Pekala,

Logistical Solutions (LoSo) is pleased to provide ENVIRON International Corporation this *Letter Report for Final Visual Inspection of the Pipe Abatement within RZ-C-24* conducted for the Nevada Environmental Response Trust site located at 560 West Lake Mead Parkway in Henderson, Nevada. The purpose of the final visual inspection was to identify, within reason, the presence and location of potential asbestos-containing materials (ACMs) within the regulated control zones within and adjacent to Remediation Zone RZ-C-24 (project area).

Earth Resource group excavated soil within several areas containing asbestos-wrapped pipes on May 12-13, 2011. The work area consisted of two inch-inch diameter pipes that were approximately 52 feet in length, three four-inch diameter pipes that were approximately 52 feet in length, three two-inch diameter pipes that were approximately 52 feet in length, two eight-inch diameter pipes that were approximately 27 feet in length, and one two-inch diameter pipe that that was approximately 27 feet in length. The pipes were located within and adjacent to RZ-C-24. The piping was abated due to the presence of asbestos by Earth Resource Group on May 13, 2011. The attached site plan depicts the general location of the piping that was removed.

Visual Site Inspection

On May 13, 2011, Mr. Kristopher Everett of LoSo was contacted by Steve Schafer of Earth Resource Group to conduct a final visual clearance inspection of the regulated asbestos zone located within and adjacent to RZ-C-24 of the project area. Mr. Everett performed a visual inspection on May 13, 2011 of the regulated asbestos zone upon the completion of the asbestos abatement activities. The regulated asbestos zone was assessed for signs of visible ACM debris. Asbestos and/or asbestos containing debris was not observed during the inspection of the regulated asbestos zone.

The visual inspection was conducted in a manner consistent with the recommendations specified in the American Society for Testing and Materials (ASTM) E1368-05^{e1} standard. This report applies only to the subject areas at the time of our inspection.

Limitations

This report has been prepared for the exclusive use of ENVIRON International Corporation, as it applies to the subject regulated asbestos zone at the project area. Logistical Solutions, LLC is not responsible for any claims and damages associated with interpretation of available information. This assessment should not be regarded as a guarantee that future exposure to the airborne asbestos fibers will not occur.

Our services were performed in accordance with the generally accepted standard of practice at the time this report was written. No warranty, expressed or implied, is intended.

LoSo appreciates being of service to ENVIRON International Corporation on this project. If you have any questions or require additional information, please contact us at (702) 596-2021.

Sincerely,

Logistical Solutions, LLC



Kristopher Everett, CEM
Project Manager
NV Asbestos Consultant No. IM-1569




Ty L. Salazar, CEM, OHST
Operations Manager
NV Asbestos Consultant No. IM-1413

Attachment



Aerial View - Tronox Asbestos Wrapped Pipe Abatement
Map by Earth Resource Group
AWP12 - 36° 2'39.72" N, 115° 0'10.38" W
Area was visually cleared May 13, 2011.



Aerial View - Tronox Asbestos Wrapped Pipe Abatement
Map by Earth Resource Group

AWP12 - 36° 2'39.72" N, 115° 0'10.38" W
Area was visually cleared May 13, 2011.

Note: Total Linear Footage of All Diameter Pipe Abated in this Project Area was 527 feet.