

# MEMO

---

**To:** Nevada Division of Environmental Protection  
Nevada Environmental Response Trust

---

**Cc:** Nevada Environmental Response Trust Stakeholders

---

**From:** David Bohmann/Tt

---

**Date:** October 22, 2015

---

**Subject:** NERT – GWETS Operation Monthly Report – September 2015

---

At the request of the Nevada Environmental Response Trust (Trust), Tetra Tech, Inc. (Tetra Tech) provides this summary of the groundwater extraction and treatment system (GWETS) operation and oversight tasks performed during September 2015.

### Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) reports that the GWETS mechanically operated normally in September 2015 with the exception of three diversion events that are described in more detail below. The flow rate to the plant averaged approximately 785 gallons per minute (gpm) during September 2015. At the end of the month, the GW-11 Pond volume was 45.3 million gallons (MG), which would allow 11.8 days of available additional storage in event of an emergency plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond decreased approximately 1.5 MG from the end of August. Figure 1 in this report depicts the actual and projected GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the Fluidized Bed Reactor (FBR) plant averaged 103 mg/L for the month, with a maximum concentration of 110 mg/L.

Analytical data indicate that the permitted effluent discharges at GWETS Outfall 001 were within the NPDES permitted numerical discharge limits (Please see Attachment A, prepared by ENVIRON).

### Enhanced Operational Metrics

Tetra Tech continues to move forward with the approved Enhanced Operational Metrics program to add instruments, controls, data acquisition systems, along with various other technical upgrades to improve the efficiency of GWETS data collection and reporting. An implementation schedule is presented in more detail under the GWETS Upgrades and Facility Projects section below.

Tables 1 and 2 provide a summary of the current GWETS operational metrics that provide data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 presents historical perchlorate and chromium mass flux.

## Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Henderson, Nevada Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

### 1. GW-11 Pond

- GW-11 Pond Leak Detection System: Tetra Tech continues to evaluate the data from the camera survey of the NE and NW sumps and to prepare options for managing the sumps in GW-11. A camera survey of the SE and SW sumps is scheduled for October 2015. Upon completion of the camera survey, recommendations will be made for managing the GW-11 sump wells.
- Diversions:
  - i. On September 11, 2015 an effluent diversion occurred following the failure of the micronutrient pump. The pump failure caused the effluent to be out of spec. Approximately 272,816 gallons were diverted to GW-11 between 7:27 and 10:09am until the micronutrient pump was repaired and discharging to the Las Vegas Wash resumed.
  - ii. Effluent was diverted from 10:45 am to 12:30 pm on September 15, 2015 due to a leaking valve on the effluent line in the D-1 Building. Approximately 18,931 gallons were diverted to GW-11 until the leak was repaired.
  - iii. Due to a leaking gasket on the influent line at the equalization area, the FBR plant was placed in recycle mode on September 22, 2015. The plant was in recycle from 3:21 pm until 4:31 pm when the gasket was repaired. Approximately 30,635 gallons were diverted during this time.
- Ecology:
  - i. Consistent with last year, a rapid increase in the boatman bug population in GW-11 resulted in plugging of the automatic strainers downstream of GW-11. Starting on September 2<sup>nd</sup> flows from all well fields were routed directly to the P-101 tanks at the equalization area and into the plant. This operating mode will continue until cooler weather kills off this bug bloom at which time flows will be directed back to GW-11 for equalization.

### 2. Maintenance

- Major maintenance that was performed or completed in the month included:

- i. The computer that is used to view the lift stations and the Allen-Bradley controls for the GWTP experienced a hardware malfunction and is being repaired. A new motherboard and power supply have been ordered and will be replaced. All processes at the GWTP are controlled locally so the computer malfunction did not impact operation, it just required manual collection of flow data.
- Preventative Maintenance completed or being performed in the month included:
  - i. ETI made multiple minor conduit repairs on the I-wells located between the control box and the wells within the Interceptor Well Field.
  - ii. ETI replaced the gasket and installed a blind flange on an old piping system in the equalization area.
  - iii. ETI is beginning the startup process for FBRs 5 and 6. The FBRs have been inoculated are performing well with 50 gpm forward flow. ETI will continue to bring FBRs 5 and 6 online and then transition to the rehabilitation process of FBRs 7 and 8.
  - iv. ETI completed the piping on the DAF pressure tank.
  - v. ETI removed obstructions from the DAF sludge box and suction piping.
  - vi. The suction disc and lower housing on DAF Float Pump – P502 have been replaced.
  - vii. The sand filter discharge piping was routed to the filtrate tank.
  - viii. A broken elbow on the 3-inch piping that is used to fill the caustic tank was repaired.
- Outstanding maintenance and repairs from the previous month are outlined below:
  - i. As of the date of this memo, the Raw Water Feed Pump P102B was returned from Motion Industries and repairs are now complete.

### **GWETS Upgrades and Facility Projects**

The following is a summary of initiatives in-progress during the reporting period at the direction of the Trust:

#### **1. AP-5 Solids Removal**

Tetra Tech is moving forward with the design to remove AP-5 pond solids, wash the solids to remove perchlorate salts, and relocate the perchlorate containing water to a large storage tank for eventual treatment in the GWETS. Evaluation and coordination between Tetra Tech, ETI, the Trust and NDEP on this project is ongoing.

#### **2. Enhanced Operational Metrics**

Work on site began in late August remains on schedule. Commissioning of the upgrades will be complete by mid-November, with data available for the November reporting period.

### **Equipment Availability Tracking**

ETI operators continue to update the equipment tracking form on a weekly basis at a minimum, or whenever there is a change in the status of key equipment. During regular site visits, Tetra Tech field personnel continue to verify the entries on the form, including both the operating status and confirming the inventory of required shelf spares. The equipment tracking form submitted by ETI to Tetra Tech on September 30, 2015, is attached (Please see Attachment B).

### **GWETS Staffing**

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

### **GWETS Security**

During weekly calls, ETI notifies Tetra Tech of any issues with GWETS security. There were no GWETS security issues reported during the month of September.

### **Tetra Tech Activities**

Tetra Tech conducted calls with ETI to review operation of the GWETS on September 3<sup>rd</sup>, 10<sup>th</sup>, 17<sup>th</sup>, and 24<sup>th</sup>. Becki Dano, CEM, performed visits to the GWETS on September 4<sup>th</sup>, 11<sup>th</sup>, 18<sup>th</sup>, and 25<sup>th</sup>. Ms. Dano also reviewed permit and sampling forms for the entire month to ensure each was correct and up-to-date, checked equipment status, and verified shelf spare inventory.

### **Summary**

Based on our review of available and relevant information, Tetra Tech concurs with ETI's management of the GWETS during the reporting period. No additional involvement from either the Trust or Tetra Tech is recommended at this time.

# Tables

## Operational Metrics

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) <sup>2</sup>	Chromium TR (mg/L) <sup>2</sup>	Chromium(VI) (mg/L) <sup>2,8</sup>
SWF Total Extraction <sup>5</sup>	569 <sup>1</sup>	11	0.000	Future Metric
AWF Total Extraction <sup>5</sup>	294 <sup>1</sup>	157	0.36	Future Metric
IWF Total Extraction <sup>6</sup>	63 <sup>1</sup>	800	8.32	Future Metric
GWTP Effluent <sup>7</sup>	60	809	0.49	ND
GW-11 Influent <sup>4</sup>	46 <sup>3</sup>	Future Metric	Future Metric	Future Metric
GW-11 Effluent/ FBR Influent <sup>7</sup>	46	103	0.023	0.024

## Notes:

TR = Total Recoverable; NA = Not Available; ND = not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Sum of daily average flow for individual wells .

2: All concentrations reported are monthly flow weighted averages.

3: Flow has historically been a calculated metric, but Tetra Tech transitioned to flow meter measurement beginning on April 27, 2015. Flow not directed to GW-11 during September due to boatman bugs plugging filters.

4: Following contractual amendment agreements, ETI will begin collecting analytical samples at the GW-11 influent sample tap.

5: Perchlorate sampled monthly, chromium TR sampled quarterly, values reported from TestAmerica.

6: Perchlorate and chromium TR sampled quarterly, values reported from TestAmerica.

7: Perchlorate, chromium TR and chromium (VI) sampled weekly, values reported from TestAmerica.

8: Hexavalent chromium will be analyzed and reported monthly as part of the Enhanced Operational Metrics project.

Nevada Environmental Response Trust   Groundwater Extraction and Treatment System   Monthly Stakeholder Metrics		
Location ID	Perchlorate (lbs/month) <sup>1</sup>	Chromium TR (lbs/month) <sup>1</sup>
SWF Total Extraction	2,297	0.09
AWF Total Extraction	16,681	40
IWF Total Extraction	18,150	189
GWTP Effluent	17,586	11
GW-11 Influent <sup>2</sup>	Future Metric	Future Metric
GW-11 Effluent/FBR Influent	1,694	0.38

Notes:

TR = Total Recoverable; NA = Not Available.

1: Total lbs extracted is calculated from flow weighted average concentration and average flow (see Table 1).

2: Following contractual amendment agreements, ETI will begin collecting analytical samples at the GW-11 influent sample tap.

# Figures

## Operational Metrics



**Figure 1 - GW-11 Pond Volume Projection**

Nevada Environmental Response Trust  
 GW-11 Pond Volume  
 Projected v. Actual  
 Update 09/29/2015





Figure 2 - Historical Perchlorate Mass Flux



# Attachment A

NPDES Tracking Sheet (Prepared by ENVIRON)

Continuous		Daily samples, composited weekly	
Flow Rate		Perchlorate	
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (ug/L)	30-Day Avg. (lbs/day)
1.45	1.75	18	0.22

Weekly samples								
pH	Hexavalent Chromium	Total Chromium	Total Suspended Solids (TSS)		Total Iron		Total Ammonia as N	Total Phosphorus as P
30-Day Avg. (S.U.)	Daily Max. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)
6.5 to 9.0	0.01	0.1	135	1,634	10	121.03	40	20

Weekly samples, collected separately			Quarterly sample	
BOD <sub>5</sub> (inhibited)			Manganese	
30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)
25	40	254	5	60.52

January 2015	1.20	1.39	1.3	0.013	6.59	0.00013	0.021	25	250	4.1	40	2.6	1.5	3.7	6.0	37	0.20	2.1
February 2015	1.34	1.42	1.3	0.014	6.85	0.00013	0.029	21	230	3.3	37	2.5	1.6	6	13	69		
March 2015	1.32	1.38	1.3	0.014	6.71	0.00013	0.043	26	280	4.9	54	7.4	2.0	4.6	9.2	49		
April 2015	1.30	1.34	1.3	0.014	6.83	0.00013	0.0080	13	140	3.4	36	3.4	1.4	1.9	2.9	21	0.090	0.93
May 2015	1.23	1.29	1.3	0.013	6.52	0.00034	0.0060	13	130	3.6	37	2.4	0.7	0.6	1.1	6.4		
June 2015	1.21	1.32	1.3	0.012	6.84	0.00013	0.013	17	170	4.1	41	4.0	2.0	2.3	2.6	23		
July 2015	1.24	1.37	1.3	0.013	6.72	0.00013	0.0049	13	132	3.2	32	2.1	1.0	1.4	1.8	14	0.14	1.5
August 2015	1.31	1.38	1.3	0.014	6.94	0.00013	0.011	18	198	3.6	40	1.6	1.8	3.7	5.9	40		
September 2015 (month to date)	1.32	1.43	1.3	0.013	6.91	0.00013	0.098	9.0	100	1.4	15	1.8	1.6	2.4	3.2	26		

Daily Grab Sample Dates	Composite Sample Date	ug/L	lbs/day	Sample Date	S.U.	mg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	mg/L	lbs/day
1/4 - 1/10	1/10/2015	ND (<2.5)	1.3	0.010	1/5/2015	6.53	ND (<0.00025)	0.021	24	201	4.8	40	--	0.94	7.9	1/7/2015	3.1	26	0.20	2.1
1/11 - 1/17	1/17/2015	ND (<2.5)	1.3	0.013	1/12/2015	6.64	ND (<0.00025)	0.019	19	192	3.9	39	ND (<0.10)	0.05	0.51	1/14/2015	3.9	39		
1/18 - 1/24	1/24/2015	ND (<2.5)	1.3	0.014	1/19/2015	6.65	ND (<0.00025)	0.018	25	276	3.4	38	--	0.13	1.4	1/21/2015	1.8	20		
1/25 - 1/31	1/31/2015	ND (<2.5)	1.3	0.013	1/26/2015	6.54	ND (<0.00025)	0.019	30	316	4.1	43	ND (<0.10)	0.05	0.53	1/28/2015	6.0	63		
2/1 - 2/7	2/7/2015	ND (<2.5)	1.3	0.014	2/2/2015	6.90	ND (<0.00025)	0.010	11	121	1.6	18	--	0.20	2.2	2/4/2015	4.5	49		
2/8 - 2/14	2/14/2015	ND (<2.5)	1.3	0.014	2/9/2015	6.67	ND (<0.00025)	0.024	17	196	0.66	7.6	--	0.33	3.8	2/11/2015	5.7	66		
2/15 - 2/21	2/21/2015	ND (<2.5)	1.3	0.014	2/17/2015	6.97	ND (<0.00025)	0.0064	19	212	3.9	44	--	0.21	2.3	2/18/2015	1.5	17		
2/22 - 2/28	2/28/2015	ND (<2.5)	1.3	0.014	2/23/2015	6.85	ND (<0.00025)	0.029	36	401	7.1	79	--	0.16	1.8	2/25/2015	13	145		
3/1 - 3/7	3/7/2015	ND (<2.5)	1.3	0.013	3/2/2015	6.82	ND (<0.00025)	0.043	42	441	4.9	51	--	0.22	2.3	3/5/2015	9.2	97		
3/8 - 3/14	3/14/2015	ND (<2.5)	1.3	0.014	3/9/2015	6.89	ND (<0.00025)	0.011	26	296	4.8	55	--	0.44	5.0	3/11/2015	2.6	30		
3/15 - 3/21	3/21/2015	ND (<2.5)	1.3	0.014	3/16/2015	6.64	ND (<0.00025)	0.0071	23	257	5.0	56	--	0.69	7.7	3/18/2015	2.2	25		
3/22 - 3/28	3/28/2015	ND (<2.5)	1.3	0.014	3/23/2015	6.64	ND (<0.00025)	0.013	19	211	4.8	53	--	0.71	7.9	3/25/2015	4.2	47		
3/29 - 4/4	4/4/2015	ND (<2.5)	1.3	0.014	3/30/2015	6.55	ND (<0.00025)	0.0074	20	219	4.9	54	--	1.3	14	ND (<0.025)	0.013	0.14		
4/5 - 4/11	4/11/2015	ND (<2.5)	1.3	0.013	4/6/2015	6.96	ND (<0.00025)	0.0057	18	193	4.7	50	--	0.27	2.9	4/8/2015	2.9	31		
4/12 - 4/18	4/18/2015	ND (<2.5)	1.3	0.014	4/13/2015	7.04	ND (<0.00025)	0.0080	4.7	52	0.38	4.2	--	0.37	4.1	4/15/2015	1.9	21	0.090	0.93
4/19 - 4/25	4/25/2015	ND (<2.5)	1.3	0.013	4/20/2015	6.62	ND (<0.00025)	0.0046	17	183	4.2	45	--	0.55	5.9	4/22/2015	0.85	9.1		
4/26 - 5/2	5/2/2015	ND (<2.5)	1.3	0.013	4/27/2015	6.69	ND (<0.00025)	0.0040	14	149	4.3	46	ND (<0.10)	0.05	0.53	4/29/2015	1.2	13		
5/3 - 5/9	5/9/2015	ND (<2.5)	1.3	0.012	5/4/2015	6.61	ND (<0.00025)	0.0046	8.0	77	3.7	36	--	0.22	2.1	5/6/2015	ND (<0.50)	0.25	2.4	
5/10 - 5/16	5/16/2015	ND (<2.5)	1.3	0.013	5/12/2015	6.62	ND (<0.00025)	0.0046	12	127	3.9	41	--	0.39	4.1	5/13/2015	0.57	6.0		
5/17 - 5/23	5/23/2015	ND (<2.5)	1.3	0.013	5/18/2015	6.42	0.00034	0.0060	13	138	3.7	39	--	0.11	1.2	5/20/2015	1.1	12		
5/24 - 5/30	5/30/2015	ND (<2.5)	1.3	0.013	5/26/2015	6.44	ND (<0.00025)	0.0046	18	187	3.0	31	--	0.23	2.4	5/27/2015	0.52	5.4		
6/1 - 6/6	6/6/2015	ND (<2.5)	1.3	0.012	6/1/2015	6.57	ND (<0.00025)	ND (<0.013)	10	95	3.8	36	--	0.24	2.3	6/3/2015	2.6	25		
6/7 - 6/13	6/13/2015	ND (<2.5)	1.3	0.013	6/8/2015	6.74	ND (<0.00025)	0.013	21	211	6.9	69	--	0.91	9.1	6/10/2015	1.6	16		
6/14 - 6/20	6/20/2015	ND (<2.5)	1.3	0.013	6/15/2015	7.21	ND (<0.00025)	0.0088	9.5	98	2.0	21	--	0.27	2.8	6/17/2015	2.6	27		
6/21 - 6/27	6/27/2015	ND (<2.5)	1.3	0.013	6/22/2015	6.98	ND (<0.00025)	0.0068	22	224	4.2	43	--	0.18	1.8	6/24/2015	2.3	23		
6/28 - 7/4	7/4/2015	ND (<2.5)	1.3	0.013	6/29/2015	6.70	ND (<0.00025)	0.0061	23	240	3.6	38	--	0.39	4.1	7/1/2015	1.5	16		
7/5 - 7/11	7/11/2015	ND (<2.5)	1.3	0.011	7/6/2015	6.79	ND (<0.00025)	0.0049	14	126	3.5	32	--	0.20	1.8	7/9/2015	0.93	8.4	0.14	1.5
7/12 - 7/18	7/18/2015	ND (<2.5)	1.3	0.014	7/14/2015	6.92	ND (<0.00025)	ND (<0.0025)	13	143	2.5	27	--	0.19	2.1	7/15/2015	1.5	16		
7/19 - 7/25	7/25/2015	ND (<2.5)	1.3	0.014	7/20/2015	6.48	ND (<0.00025)	ND (<0.0025)	9.4	105	2.7	30	--	0.27	3.0	7/22/2015	1.2	13		
7/26 - 8/1	8/1/2015	ND (<2.5)	1.3	0.013	7/27/2015	6.68	ND (<0.00025)	0.0046	15	154	3.9	40	--	0.13	1.3	7/29/2015	1.8	19		
8/2 - 8/8	8/8/2015	ND (<2.5)	1.3	0.014	8/3/2015	7.65	ND (<0.00025)	0.0048	18	202	3.7	42	--	0.21	2.4	8/5/2015	2.7	30		
8/9 - 8/15	8/15/2015	ND (<2.5)	1.3	0.013	8/11/2015	6.83	ND (<0.00025)	0.011	26	276	5.0	53	--	0.25	2.7	8/12/2015	5.9	63		
8/16 - 8/22	8/22/2015	ND (<2.5)	1.3	0.013	8/17/2015	6.66	ND (<0.00025)	0.0062	15	159	3.2	34	--	0.20	2.1	8/19/2015	3.1	33		
8/23 - 8/29	8/29/2015	ND (<2.5)	1.3	0.014	8/24/2015	6.84	ND (<0.00025)	ND (<0.0025)	14	156	3.4	38	ND (<0.10)	0.05	0.56	8/26/2015	2.9	32		
8/30 - 9/5	9/5/2015	ND (<2.5)	1.3	0.014	8/31/2015	6.73	ND (<0.00025)	ND (<0.0025)	18	195	2.9	31	ND (<0.10)	0.05	0.54	9/2/2015	2.2	24		
9/6 - 9/12	9/12/2015	ND (<2.5)	1.3	0.013	9/8/2015	6.89	ND (<0.00025)	0.0070	2.9	31	2.6	28	--	0.29	3.1	9/9/2015	1.7	18		
9/13 - 9/19	9/19/2015	NA	NA	NA	9/14/2015	6.93	ND (<0.00025)	0.098	15	169	0.27	3.0	ND (<0.10)	0.05	0.56	9/16/2015	3.2	36		
					9/21/2015	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	9/23/2015	NA	NA		

Note: All analytical responsibilities are performed by TestAmerica Laboratories, Inc. (TestAmerica) in Irvine, California, unless otherwise indicated.

NA = Not Available To Date

NS = No Sample

ND = Not Detected above laboratory reporting limit; concentration in adjacent cell to right is one-half the reporting limit (per Permit condition)

-- = Analyte detected; see column adjacent to right

Last Updated: October 2, 2015

# Attachment B

## Equipment Tracking Form

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
		<b>Main Plant Equipment</b>				
<b>1</b>		<b>Seep Wells and Lift Station 1</b>				
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Standby			
1.03		Lift Station 1 Lift Pump B	Running			
1.04		Area in and around Lift Station 1	Running			
<b>2</b>		<b>Athens Road Wells and Lift Station 3</b>				
2.01		Athens Road Well Field, 9 wells	Running			
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running			
<b>3</b>		<b>Lift Station 2 and Transmission Pipelines</b>				
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running			
<b>4</b>		<b>Interceptor Wells and Cr Treatment Plant</b>				
4.01		IWF Well Field, 30 wells	Running		3	ETI made multiple minor conduit repairs on the I-wells located between the control box and the wells.
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation			
4.05		Filter Press	Running			
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Standby			
4.08		Interceptor Booster Pump B	Running			
4.09		Area In And Around GWTP	Running			

<sup>1</sup>Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>5</b>		<b>Equalization Area and GW-11 Pond</b>				
5.01	PID10A	Pond GW-11	In operation			
5.02	PID10A	Pond Water Pump - P101A	Standby			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	In operation			
5.05	PID10A	Area in and Around EQ	In operation		3	ETI replaced gasket and installed blind flange on an old piping system no longer in use.
5.06	PID10A	Raw Water Feed Pump - P102A	Running			
5.07	PID10A	Raw Water Feed Pump - P102B	Maintenance		3	Motion industries received parts for the pump and work has begun.
5.08	PID10B	Carbon Absorber - LGAC 201A	Running			
5.09	PID10B	Carbon Absorber - LGAC 201B	Running			
5.10	PID10B	Carbon Absorber - LGAC 201C	Running			
<b>6</b>		<b>First Stage FBRs A, 1 &amp; 2</b>				
6.01	PID14	FBR A	Running			
6.02	PID14	Separator Tank - 1401	Running			
6.03	PID14	Media Return Pump - P 1401	Running			
6.04	PID14	P1401A	Running			
6.05	PID01A	P1401B	Standby			
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012	Running			
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Standby			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Standby			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Standby			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			

<sup>1</sup>Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
6.24	PID07B	<i>FBR 2 Electron Donor Assembly Pump - P732</i>	Running			

<sup>1</sup>Status Codes

- Running - Unit is in operation
- Standby - Spare or duplicate, not currently in operation
- Maintenance - Out of service for maintenance
- Off - Not currently needed for use, but can be placed in service



Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>7</b>		<b>First Stage FBRs 3 &amp; 4</b>				
7.01	PID01B	FBR 3	Off			
7.02	PID01B	FBR 4	Off			
7.03	PID02B	First Stage Separator Tank - T2012	Off			
7.04	PID01B	Media Return Pump - P2012	Off			
7.05	PID01B	First Stage FBR Pump - P1013	Off			
7.06	PID01B	First Stage FRB Pump - P1014	Off			
7.07	PID01B	First Stage FBR Pump - P102A	Off			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Off			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Off			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723	Off			
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Off			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Off			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Off			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Off			
<b>8</b>		<b>Second Stage FBRs 5 &amp; 6</b>				
8.01	PID03A	FBR 5	Off		3	ETI is beginning start up procedures on FBR.
8.02	PID03A	FBR 6	Off		3	ETI is beginning start up procedures on FBR.
8.03	PID03C	Second Stage Separator Tank - T3011	Off			
8.04	PID03A	Media Return Pump - P3011	Off			
8.05	PID03A	Second Stage FBR Pump - P3015	Off			
8.06	PID03A	Second Stage FBR Pump - P3016	Off			
8.07	PID03A	Second Stage FBR Pump - P301A	Off			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Off			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Off			

<sup>1</sup>Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>9</b>		<b>Second Stage FBRs 7 &amp; 8</b>				
9.01	PID03B	FBR 7	Running			
9.02	PID03B	FBR 8	Running			
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Standby			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Standby			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Standby			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			
<b>10</b>		<b>Aeration and DAF System</b>				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Biofilter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Biofilter Sump	Running			
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Biofilter Sump Pump - P402A	Standby			
10.09	PID04	Biofilter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation		3	ETI has completed piping activities on the pressure tank.
10.11	PID05	DAF Vessel - D501	Running		3	The DAF sludge box clogged up. ETI removed suction piping to clear obstructions from piping.
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running		3	ETI replaced suction disc and lower housing on pump.
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running			
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			

<sup>1</sup>Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>11</b>		<b>Pumping System (Old Effluent)</b>				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Running			
11.03	PID06	Effluent Pump - P602	Standby			
<b>12</b>		<b>Sand Filter System</b>				
12.01	PID17	Sand Filter	Running		3	Airlift 1 is stuck so ETI is attempting to pull, clear, and reinstall.
12.02	PID17	Filter Reject Tank	In operation		4	ETI piped the sandfilter discharge piping to the filtrate tank.
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
<b>13</b>		<b>Effluent Tank and Pumping</b>				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Running			
13.04	PID10C	Area Around Effluent and North D-1	Running			
<b>14</b>		<b>Solids Collection and Pressing System</b>				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation			
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902	Running			
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running			
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			

<sup>1</sup>Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>Chemical Systems</b>						
<b>15</b>		<b>Electron Donor System</b>				
15.01	PID07B	<i>Electron Donor Tank</i>	In operation			
15.02	PID07B	<i>Booster Pump P739A</i>	Running			
15.03	PID07B	<i>Booster Pump P739B</i>	Standby			
<b>17</b>	PID07C	<b>Micro Nutrient System</b>	In operation			
<b>18</b>	PID07C	<b>Hydrogen Peroxide System</b>	In operation			
<b>19</b>	PID07C	<b>De-Foam System</b>	In operation			
<b>20</b>	PID15	<b>Nutrient (Phosphoric Acid) System</b> (Tank only - pumps included in FBRs)	In operation			
<b>21</b>	PID07A	<b>Nutrient (Urea) System</b> (Tank only - pumps included in FBRs)	In operation			
<b>22</b>	PID07A	<b>pH System</b> (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation		3	ETI repaired broken elbow on 3'-inch piping to fill the caustic tank.
<b>23</b>	PID07C	<b>Ferric Chloride System</b>	In operation			
<b>24</b>	PID07B	<b>Polymer Systems - DAF</b>	In operation			
<b>25</b>	PID09	<b>Polymer System - Solids Dewatering</b> (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
<b>Utility Systems</b>						
<b>26</b>		<b>Compressed Air System</b>				
26.01	PID08	<i>West Compressor</i>	Running			
26.02	PID08	<i>East Compressor</i>	Running			
26.03	PID08	<i>O2 Compressor</i>	Running			
26.04	PID08	<i>Compressed Air Receiver Tank</i>	In operation			
26.05	PID08	<i>Air Dryer</i>	Running			
26.06	PID08	<i>Oil Removal Filter</i>	In operation			
26.07	PID08	<i>Particulate Filter</i>	In operation			
<b>27</b>	PID16	<b>Oxygen System</b>	In operation			
<b>28</b>		<b>GWETS Plant Controls/ Siemens Controls</b>	In operation			
<b>29</b>		<b>Well Control System/ Allen Bradley Controls</b>	In operation		2	The computer to view liftstations and Allen Bradley controls for the GWTP is getting repaired. The motherboard and power supply will be replaced.
<b>30</b>		<b>MCC FBR Pad</b>	In operation			
<b>31</b>		<b>MCC in D-1</b>	In operation			
<b>32</b>		<b>MCC in EQ area</b>	In operation			

<sup>1</sup>Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status <sup>1</sup>	Checked	Criticality <sup>2</sup>	Notes
<b>Miscellaneous Systems</b>						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
<b>Shelf Spares</b>						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			

<sup>1</sup> Status Codes

**Equipment**

Running                    Unit is in operation  
 Standby                   Duplicate or installed spare, not currently operating  
 Maintenance            Out for repairs or maintenance  
 Off                            Not currently needed, but available

<sup>1</sup> Criticality Codes

1 = Critical            Cannot continue with operation until repairs made  
 2 = Important        Can still operate safely and in compliance with permits, but risks are increased  
 3 = Moderate        Work needs to be performed, but plant can still operate with redundancy that is in place  
                                  - Tasks performed to either improve the existing equipment (i.e., testing new options)  
 4 = Low                - Minor repairs that in no way alter the performance of the plant

**Tanks, Pipelines, Ponds**

In operation  
 Out of service

**Spares**

In stock

<sup>1</sup> Status Codes

Running - Unit is in operation  
 Standby - Spare or duplicate, not currently in operation  
 Maintenance - Out of service for maintenance  
 Off - Not currently needed for use, but can be placed in service