

MEMO

To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: David Bohmann, Deena Garland

Date: November 23, 2015

Subject: NERT – GWETS Operation Monthly Report – October 2015

At the request of the Nevada Environmental Response Trust (Trust), Tetra Tech, Inc. (Tetra Tech) provides this summary of the groundwater extraction and treatment system (GWETS) operation and oversight tasks performed during October 2015.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) reports that the GWETS mechanically operated normally in October 2015 with the exception of three diversion events that are described in more detail below. The flow rate to the plant averaged approximately 874 gallons per minute (gpm) during October 2015. At the end of the month, the GW-11 Pond volume was 44 million gallons (MG), which would allow 12.8 days of available additional storage in event of an emergency plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond decreased approximately 1.3 MG from the end of September. Figure 1 in this report depicts the actual and projected GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the Fluidized Bed Reactor (FBR) plant averaged 86 mg/L for the month, with a maximum concentration of 97 mg/L.

Analytical data indicate that the permitted effluent discharges at GWETS Outfall 001 were within the NPDES permitted numerical discharge limits (Please see Attachment A, prepared by ENVIRON).

Enhanced Operational Metrics

Tetra Tech continues to move forward with the approved Enhanced Operational Metrics program to add instruments, controls, data acquisition systems, along with various other technical upgrades to improve the efficiency of GWETS data collection and reporting. An implementation schedule is presented in more detail under the GWETS Upgrades and Facility Projects section below.

Tables 1 and 2 provide a summary of the current GWETS operational metrics that provide data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 presents historical perchlorate and chromium mass flux.

Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Henderson, Nevada Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11 Pond

- GW-11 Pond Leak Detection System: Tetra Tech completed camera surveys of the SE and SW sump riser pipes and based on those surveys, is preparing recommendations for repair of the NE sump riser pipe, resetting the SW, NW, and NE pumps to a lower depth, and reinforcement of the NW, SE, and SW sump riser pipes.
- Diversions:
 - i. A triple diversion event occurred on October 9, 2015 due to high sulfides in the effluent, a pig launcher stuck in the effluent line, and a leaking gasket in the EQ area. Approximately 395,444 total gallons were diverted to GW-11. The three diversions occurred during the times noted below:
 1. Water was diverted from 6:23 am to 12:14 pm due to high sulfides in the effluent.
 2. Water was diverted from 2:33 pm to 2:55 pm due to the pig launcher stuck in the effluent pipeline.
 3. Water was diverted from 4:24 pm to 4:34 pm due to the gasket leak at the EQ area.
 - ii. On October 16, 2015, a precautionary effluent diversion occurred in response to a suspect perchlorate reading on the Ion Chromatograph (IC) unit. ETI operators diverted water while confirming the perchlorate concentration in the effluent, and discharge returned to the wash once perchlorate concentrations were confirmed to be within the numerical discharge limits. Approximately 23,256 gallons were diverted to GW-11 from 10:39am to 11:03am.
 - iii. Effluent was diverted from 9:00 pm on October 21, 2015 to 12:36 pm on October 22, 2015 due to a power outage. The power outage was caused by the VFD for P-1302A that experienced an electrical short and caused internal arcing and tripped the main breaker at the plant. Approximately 186,645 gallons were diverted to GW-11 until power was restored.
- Ecology:
 - i. Consistent with similar occurrences in the fall of last year, a rapid increase in the boatman bug population in GW-11 caused temporary plugging of

automatic strainers downstream of GW-11. To alleviate this issue, flows from all well fields were routed directly to the P-101 tanks at the equalization area and into the plant from September 2, 2015 until October 13, 2015 when the boatman bug population declined sufficiently to allow use of the automatic strainers and resume normal flow operation.

2. Maintenance

- Major maintenance that was performed or completed in the month included:
 - i. The computer that is used to view the lift stations and the Allen-Bradley controls for the GWTP experienced a hardware malfunction on September 27, 2015 and was replaced and brought back online October 13, 2015. The computer was sent to Matrix Technologies, Incorporated (Matrix) for repair. Matrix had to honor the warranty on the computer and attempt to repair the unit before a full replacement was permitted causing a delay in getting the computer back online.
 - ii. Effluent Booster Pump P-1302A VFD experienced an electrical short and internal arcing which tripped the main breaker. A new VFD and breaker were ordered and ETI expects the replacements will be completed in November. In the interim, the backup pump is operating in the lead position with a rental pump on standby if needed.

- Preventative Maintenance completed or being performed in the month included:
 - i. ETI tightened the packing gland on Lift Station 1 Lift Pump B.
 - ii. ETI replaced the gasket on the 3-inch pipe flange for PC-133. ETI cleaned crust from the lines tapped for sample ports and added compression connectors for the sample port taps.
 - iii. ETI replaced multiple gaskets and removed the damaged flowmeter taps on the AWF wells for replacement.
 - iv. ETI replaced a gasket on the piping from the submersible pump at Lift Station 2.
 - v. ETI replaced a gasket on well I-I at a steel flange.
 - vi. ETI replaced the belt on Media Return Pump P-1401.
 - vii. ETI ordered replacement bearings for Media Return Pump P-3011.
 - viii. ETI ordered a new mechanical seal for the DAF Pressure Pump P-551 and will replace upon arrival in November.
 - ix. ETI repaired a slide air valve on Filter Press Pump P-901.
 - x. ETI is continuing work on the East Filter Press plate shifter.
 - xi. ETI removed obsolete piping from the old polymer system.

- Outstanding or ongoing maintenance and repairs from the previous month are outlined below:
 - i. FBRs 7 and 8 are currently in the rehabilitation process and all forward flow is being sent to FBRs 5 and 6.

GWETS Upgrades and Facility Projects

The following is a summary of the initiatives in-progress during the reporting period at the direction of the Trust:

1. AP-5 Solids Removal

Tetra Tech is moving forward with the design to remove the AP-5 pond solids, wash the solids to remove perchlorate salts, and relocate the perchlorate containing water to a large storage tank for eventual treatment in the GWETS. Evaluation and coordination between Tetra Tech, ETI, the Trust and NDEP on this project is ongoing.

2. Enhanced Operational Metrics

Work on site began in late August remains underway. Metrics data collection will commence as planned in mid-November and final system commissioning is scheduled for mid- to late December.

Equipment Availability Tracking

ETI operators continue to update the equipment tracking form on a weekly basis at a minimum, or whenever there is a change in the status of key equipment. During regular site visits, Tetra Tech field personnel continue to verify the entries on the form, including both the operating status and confirming the inventory of required shelf spares. The equipment tracking form submitted by ETI to Tetra Tech on October 30, 2015 is included as Attachment B.

GWETS Staffing

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

GWETS Security

During weekly calls, ETI notifies Tetra Tech of any issues with GWETS security. There were no GWETS security issues reported during the month of October.

Tetra Tech Activities

Tetra Tech conducted calls with ETI to review operation of the GWETS on October 1st, 8th, 15th, 22nd, and 29th. Becki Dano, CEM, performed visits to the GWETS on October 2nd and 9th. Ms. Dano transitioned her oversight duties to Kyle Hansen, CEM, and they both performed the GWETS review on October 16th. Mr. Hansen performed subsequent GWETS reviews on October 23rd and 30th. Mr. Hansen also reviewed permit and sampling forms for the entire month to ensure each form was correct and up-to-date, checked equipment status, and verified shelf spare inventory.

Summary

Based on our review of available and relevant information, Tetra Tech concurs with ETI's management of the GWETS during the reporting period. No additional involvement from either the Trust or Tetra Tech is recommended at this time.

Tables

Operational Metrics

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) ²	Chromium TR (mg/L) ²	Chromium(VI) (mg/L) ^{2,8}
SWF Total Extraction ⁵	536 ¹	11	0.000	Future Metric
AWF Total Extraction ⁵	240 ¹	167	0.39	Future Metric
IWF Total Extraction ⁶	62 ¹	805	8.68	Future Metric
GWTP Effluent ⁷	63	810	0.48	ND
GW-11 Influent ⁴	612 ³	Future Metric	Future Metric	Future Metric
GW-11 Effluent/ FBR Influent ⁷	874	64	0.025	0.007

Notes:

TR = Total Recoverable; ND = not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Sum of daily average flow for individual wells.

2: All concentrations reported are monthly flow weighted averages.

3: Flow has historically been a calculated metric, but Tetra Tech transitioned to flow meter measurement beginning on April 27, 2015. Flow not directed to GW-11 during beginning of October due to boatman bugs plugging filters.

4: Following contractual amendment agreements, ETI will begin collecting analytical samples at the GW-11 influent sample tap.

5: Perchlorate sampled monthly, chromium TR sampled quarterly, values reported from TestAmerica.

6: Perchlorate and chromium TR sampled quarterly, values reported from TestAmerica.

7: Perchlorate, chromium TR and chromium (VI) sampled weekly, values reported from TestAmerica.

8: Hexavalent chromium will be analyzed and reported monthly as part of the Enhanced Operational Metrics project.

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics		
Location ID	Perchlorate (lbs/month) ¹	Chromium TR (lbs/month) ¹
SWF Total Extraction	2,186	0.09
AWF Total Extraction	14,949	35
IWF Total Extraction	18,531	200
GWTP Effluent	19,007	11
GW-11 Influent ²	Future Metric	Future Metric
GW-11 Effluent/FBR Influent	14,564	5.68

Notes:

TR = Total Recoverable.

1: Total lbs extracted is calculated from flow weighted average concentration and average flow (see Table 1).


2: Following contractual amendment agreements, ETI will begin collecting analytical samples at the GW-11 influent sample tap.

Figures

Operational Metrics

Figure 1 - GW-11 Volume Projection


Nevada Environmental Response Trust
 GW-11 Pond Volume
 Projected v. Actual
 Update 10/27/2015



Notes:

- 1: Monthly GW-11 withdrawals exceed influent flows by approximately 50 gpm.
- 2: Monthly GW-11 withdrawals exceed influent flows by approximately 20 gpm with seasonally changing influent additions each month (ie.- higher GAC backwash volume in summer).
- 3: Monthly GW-11 withdrawals exceed influent flows by approximately 50 gpm with an assumed 2.8 million gallons of influent additions each month.
- 4: Monthly evaporation was calculated using Shevenell, 1996. Statewide Potential Evapotranspiration Maps for Nevada. Nevada Bureau of Mines and Geology Report 48. University of Nevada Reno.
- 5: Average monthly rainfall was estimated from rain gage 4774 data on TIMET property.

Figure 2 - Historical Perchlorate Mass Flux



Attachment A

NPDES Tracking Sheet (Prepared by ENVIRON)

Continuous		Daily samples, composited weekly	
Flow Rate		Perchlorate	
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (ug/L)	30-Day Avg. (lbs/day)
1.45	1.75	18	0.22

Weekly samples								
pH	Hexavalent Chromium	Total Chromium	Total Suspended Solids (TSS)		Total Iron		Total Ammonia as N	Total Phosphorus as P
30-Day Avg. (S.U.)	Daily Max. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)
6.5 to 9.0	0.01	0.1	135	1,634	10	121.03	40	20

Weekly samples, collected separately			Quarterly sample	
BOD ₅ (inhibited)			Manganese	
30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)
25	40	254	5	60.52

January 2015	1.20	1.39	1.3	0.013	6.59	0.00013	0.021	25	250	4.1	40	2.6	1.5	3.7	6.0	37	0.20	2.1
February 2015	1.34	1.42	1.3	0.014	6.85	0.00013	0.029	21	230	3.3	37	2.5	1.6	6	13	69		
March 2015	1.32	1.38	1.3	0.014	6.71	0.00013	0.043	26	280	4.9	54	7.4	2.0	4.6	9.2	49		
April 2015	1.30	1.34	1.3	0.014	6.83	0.00013	0.0080	13	140	3.4	36	3.4	1.4	1.9	2.9	21	0.090	0.93
May 2015	1.23	1.29	1.3	0.013	6.52	0.00034	0.0060	13	130	3.6	37	2.4	0.7	0.6	1.1	6.4		
June 2015	1.21	1.32	1.3	0.012	6.84	0.00013	0.013	17	170	4.1	41	4.0	2.0	2.3	2.6	23		
July 2015	1.24	1.37	1.3	0.013	6.88	0.00013	0.0049	13	130	3.2	32	2.1	1.0	1.4	1.8	14	0.14	1.5
August 2015	1.31	1.38	1.3	0.014	6.94	0.00013	0.011	18	200	3.6	40	1.6	1.8	3.7	5.9	40		
September 2015	1.35	1.51	1.3	0.014	6.98	0.00013	0.098	7	84	1.5	17	2.1	1.7	2.2	3.2	24		
October 2015 (month to date)	1.37	1.54	1.3	0.014	7.07	0.00029	0.0059	15	170	2.9	34	2.5	0.9	1.3	1.3	15	NA	NA

Daily Grab Sample Dates	Composite Sample Date	ug/L	lbs/day	Sample Date	S.U.	mg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	mg/L	lbs/day
1/4 - 1/10	1/10/2015	ND (<2.5)	1.3	0.010	1/5/2015	6.53	ND (<0.00025)	0.021	24	201	4.8	40	--	0.94	7.9	1/7/2015	3.1	26	0.20	2.1
1/11 - 1/17	1/17/2015	ND (<2.5)	1.3	0.013	1/12/2015	6.64	ND (<0.00025)	0.019	19	192	3.9	39	ND (<0.10)	0.05	0.51	1/14/2015	3.9	39		
1/18 - 1/24	1/24/2015	ND (<2.5)	1.3	0.014	1/19/2015	6.65	ND (<0.00025)	0.018	25	276	3.4	38	--	0.13	1.4	1/21/2015	1.8	20		
1/25 - 1/31	1/31/2015	ND (<2.5)	1.3	0.013	1/26/2015	6.54	ND (<0.00025)	0.019	30	316	4.1	43	ND (<0.10)	0.05	0.53	1/28/2015	6.0	63		
2/1 - 2/7	2/7/2015	ND (<2.5)	1.3	0.014	2/2/2015	6.90	ND (<0.00025)	0.010	11	121	1.6	18	--	0.20	2.2	2/4/2015	4.5	49		
2/8 - 2/14	2/14/2015	ND (<2.5)	1.3	0.014	2/9/2015	6.67	ND (<0.00025)	0.024	17	196	0.66	7.6	--	0.33	3.8	2/11/2015	5.7	66		
2/15 - 2/21	2/21/2015	ND (<2.5)	1.3	0.014	2/17/2015	6.97	ND (<0.00025)	0.0064	19	212	3.9	44	--	0.21	2.3	2/18/2015	1.5	17		
2/22 - 2/28	2/28/2015	ND (<2.5)	1.3	0.014	2/23/2015	6.85	ND (<0.00025)	0.029	36	401	7.1	79	--	0.16	1.8	2/25/2015	13	145		
3/1 - 3/7	3/7/2015	ND (<2.5)	1.3	0.013	3/2/2015	6.82	ND (<0.00025)	0.043	42	441	4.9	51	--	0.22	2.3	3/5/2015	9.2	97		
3/8 - 3/14	3/14/2015	ND (<2.5)	1.3	0.014	3/9/2015	6.89	ND (<0.00025)	0.011	26	296	4.8	55	--	0.44	5.0	3/11/2015	2.6	30		
3/15 - 3/21	3/21/2015	ND (<2.5)	1.3	0.014	3/16/2015	6.64	ND (<0.00025)	0.0071	23	257	5.0	56	--	0.69	7.7	3/18/2015	2.2	25		
3/22 - 3/28	3/28/2015	ND (<2.5)	1.3	0.014	3/23/2015	6.64	ND (<0.00025)	0.013	19	211	4.8	53	--	0.71	7.9	3/25/2015	4.2	47		
3/29 - 4/4	4/4/2015	ND (<2.5)	1.3	0.014	3/30/2015	6.55	ND (<0.00025)	0.0074	20	219	4.9	54	--	1.3	14	4/1/2015	2.7	30		
4/5 - 4/11	4/11/2015	ND (<2.5)	1.3	0.013	4/6/2015	6.96	ND (<0.00025)	0.0057	18	193	4.7	50	--	0.27	2.9	4/8/2015	2.9	31		
4/12 - 4/18	4/18/2015	ND (<2.5)	1.3	0.014	4/13/2015	7.04	ND (<0.00025)	0.0080	4.7	52	0.38	4.2	--	0.37	4.1	4/15/2015	1.9	21	0.090	0.93
4/19 - 4/25	4/25/2015	ND (<2.5)	1.3	0.013	4/20/2015	6.62	ND (<0.00025)	0.0046	17	183	4.2	45	--	0.55	5.9	4/22/2015	0.85	9.1		
4/26 - 5/2	5/2/2015	ND (<2.5)	1.3	0.013	4/27/2015	6.69	ND (<0.00025)	0.0040	14	149	4.3	46	ND (<0.10)	0.05	0.53	4/29/2015	1.2	13		
5/3 - 5/9	5/9/2015	ND (<2.5)	1.3	0.012	5/4/2015	6.61	ND (<0.00025)	0.0046	8.0	77	3.7	36	--	0.22	2.1	5/6/2015	ND (<0.50)	0.25	2.4	
5/10 - 5/16	5/16/2015	ND (<2.5)	1.3	0.013	5/12/2015	6.62	ND (<0.00025)	0.0046	12	127	3.9	41	--	0.39	4.1	5/13/2015	0.57	6.0		
5/17 - 5/23	5/23/2015	ND (<2.5)	1.3	0.013	5/18/2015	6.42	0.00034	0.0060	13	138	3.7	39	--	0.11	1.2	5/20/2015	1.1	12		
5/24 - 5/30	5/30/2015	ND (<2.5)	1.3	0.013	5/26/2015	6.44	ND (<0.00025)	0.0046	18	187	3.0	31	--	0.23	2.4	5/27/2015	0.52	5.4		
5/31 - 6/6	6/6/2015	ND (<2.5)	1.3	0.012	6/1/2015	6.57	ND (<0.00025)	ND (<0.013)	10	95	3.8	36	--	0.24	2.3	6/3/2015	2.6	25		
6/7 - 6/13	6/13/2015	ND (<2.5)	1.3	0.013	6/8/2015	6.74	ND (<0.00025)	0.013	21	211	6.9	69	--	0.91	9.1	6/10/2015	1.6	16		
6/14 - 6/20	6/20/2015	ND (<2.5)	1.3	0.013	6/15/2015	7.21	ND (<0.00025)	0.0088	9.5	98	2.0	21	--	0.27	2.8	6/17/2015	2.6	27		
6/21 - 6/27	6/27/2015	ND (<2.5)	1.3	0.013	6/22/2015	6.98	ND (<0.00025)	0.0068	22	224	4.2	43	--	0.18	1.8	6/24/2015	2.3	23		
6/28 - 7/4	7/4/2015	ND (<2.5)	1.3	0.013	6/29/2015	6.70	ND (<0.00025)	0.0061	23	240	3.6	38	--	0.39	4.1	7/1/2015	1.5	16		
7/5 - 7/11	7/11/2015	ND (<2.5)	1.3	0.011	7/6/2015	6.79	ND (<0.00025)	0.0049	14	126	3.5	32	--	0.20	1.8	7/9/2015	0.93	8.4	0.14	1.5
7/12 - 7/18	7/18/2015	ND (<2.5)	1.3	0.014	7/14/2015	7.55	ND (<0.00025)	ND (<0.0025)	13	143	2.5	27	--	0.19	2.1	7/15/2015	1.5	16		
7/19 - 7/25	7/25/2015	ND (<2.5)	1.3	0.014	7/20/2015	6.48	ND (<0.00025)	ND (<0.0025)	9.4	105	2.7	30	--	0.27	3.0	7/22/2015	1.2	13		
7/26 - 8/1	8/1/2015	ND (<2.5)	1.3	0.013	7/27/2015	6.68	ND (<0.00025)	0.0046	15	154	3.9	40	--	0.13	1.3	7/29/2015	1.8	19		
8/2 - 8/8	8/8/2015	ND (<2.5)	1.3	0.014	8/3/2015	7.65	ND (<0.00025)	0.0048	18	202	3.7	42	--	0.21	2.4	8/5/2015	2.7	30		
8/9 - 8/15	8/15/2015	ND (<2.5)	1.3	0.013	8/11/2015	6.83	ND (<0.00025)	0.011	26	276	5.0	53	--	0.25	2.7	8/12/2015	5.9	63		
8/16 - 8/22	8/22/2015	ND (<2.5)	1.3	0.013	8/17/2015	6.66	ND (<0.00025)	0.0062	15	159	3.2	34	--	0.20	2.1	8/19/2015	3.1	33		
8/23 - 8/29	8/29/2015	ND (<2.5)	1.3	0.014	8/24/2015	6.84	ND (<0.00025)	ND (<0.0025)	14	156	3.4	38	ND (<0.10)	0.05	0.56	8/26/2015	2.9	32		
8/30 - 9/5	9/5/2015	ND (<2.5)	1.3	0.014	8/31/2015	6.73	ND (<0.00025)	ND (<0.0025)	18	195	2.9	31	ND (<0.10)	0.05	0.54	9/2/2015	2.2	24		
9/6 - 9/12	9/12/2015	ND (<2.5)	1.3	0.013	9/8/2015	6.89	ND (<0.00025)	0.0070	2.9	31	2.6	28	--	0.29	3.1	9/9/2015	1.7	18		
9/13 - 9/19	9/19/2015	ND (<2.5)	1.3	0.014	9/14/2015	6.93	ND (<0.00025)	0.098	15	169	0.27	3.0	ND (<0.10)	0.05	0.56	9/16/2015	3.2	36		
9/20 - 9/26	9/26/2015	ND (<2.5)	1.3	0.015	9/21/2015	7.34	ND (<0.00025)	0.0038	3.7	44	1.9	22	--	0.26	3.1	9/23/2015	1.9	22		
9/27 - 10/3	10/3/2015	ND (<2.5)	1.3	0.015	9/28/2015	6.75	ND (<0.00025)	0.0030	8.0	93	1.4	16	--	0.13	1.5	9/30/2015	1.8	21		
10/4 - 10/10	10/10/2015	ND (<2.5)	1.3	0.014	10/5/2015	6.95	ND (<0.00025)	0.0059	14	158	3.4	38	--	0.17	1.9	10/7/2015	1.3	15		
10/11 - 10/17	10/17/2015	NA	NA	NA	10/12/2015	7.18	0.00029	0.0041	15	183	2.4	29	--	0.26	3.2	10/14/2015	1.3	16	NA	

Attachment B

Equipment Tracking Form

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
		Main Plant Equipment				
1		Seep Wells and Lift Station 1				
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Standby			
1.03		Lift Station 1 Lift Pump B	Running		3	ETI tightened packing gland.
1.04		Area in and around Lift Station 1	Running		2	ETI replaced gasket on 3" pipe flange for PC-133. ETI cleaned crust from tapped lines for sample ports and added compression connectors for sample port taps.
2		Athens Road Wells and Lift Station 3				
2.01		Athens Road Well Field, 9 wells	Running		2	ETI replaced multiple gaskets and removed damaged flowmeter taps and replaced with rebuilt taps.
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station 3	Running			
3		Lift Station 2 and Transmission Pipelines				
3.01		Influent Pipeline	In operation		2	ETI replaced gasket from submersible line to influent line.
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running			
4		Interceptor Wells and Cr Treatment Plant				
4.01		IWF Well Field, 30 wells	Running		2	ETI replaced gasket on I-I at steel flange.
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation			
4.05		Filter Press	Running			
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Standby			
4.08		Interceptor Booster Pump B	Running			
4.09		Area In And Around GWTP	Running			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
5		Equalization Area and GW-11 Pond				
5.01	PID10A	Pond GW-11	In operation			
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Running			
5.04	PID10A	Equalization Tanks	In operation			
5.05	PID10A	Area in and Around EQ	In operation			
5.06	PID10A	Raw Water Feed Pump - P102A	Standby			
5.07	PID10A	Raw Water Feed Pump - P102B	Running			
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running			
6		First Stage FBRs A, 1 & 2				
6.01	PID14	FBR A	Running			
6.02	PID14	Separator Tank - 1401	Running			
6.03	PID14	Media Return Pump - P 1401	Maintenance		3	The belt is being replaced.
6.04	PID14	P1401A	Running			
6.05	PID01A	P1401B	Standby			
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012	Running			
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Standby			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Standby			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Standby			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
6.21	PID15	<i>FBR 2 Nutrient (Phos Acid) Feed Pump - P1522</i>	Running			
6.22	PID07B	<i>FBR A Electron Donor Assembly Pump - P73A</i>	Running			
6.23	PID07B	<i>FBR 1 Electron Donor Assembly Pump - P731</i>	Running			
6.24	PID07B	<i>FBR 2 Electron Donor Assembly Pump - P732</i>	Running			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
7		First Stage FBRs 3 & 4				
7.01	PID01B	FBR 3	Off			
7.02	PID01B	FBR 4	Off			
7.03	PID02B	First Stage Separator Tank - T2012	Off			
7.04	PID01B	Media Return Pump - P2012	Off			
7.05	PID01B	First Stage FBR Pump - P1013	Off			
7.06	PID01B	First Stage FRB Pump - P1014	Off			
7.07	PID01B	First Stage FBR Pump - P102A	Off			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Off			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Off			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723	Off			
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Off			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Off			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Off			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Off			
8		Second Stage FBRs 5 & 6				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Maintenance		3	The bearings need to be replaced on pump and are on order.
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Standby			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Standby			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
9		Second Stage FBRs 7 & 8				
9.01	PID03B	FBR 7	Running		4	FBR's currently in recycle. All flow sent to FBR's 5&6.
9.02	PID03B	FBR 8	Running		4	FBR's currently in recycle. All flow sent to FBR's 5&6.
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Standby			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Standby			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Standby			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Standby			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Standby			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Standby			
10		Aeration and DAF System				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Biofilter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Biofilter Sump	Running			
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Biofilter Sump Pump - P402A	Standby			
10.09	PID04	Biofilter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running		3	The mechanical seal needs to be replaced and a new one is on order.
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
11		Pumping System (Old Effluent)				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Standby			
11.03	PID06	Effluent Pump - P602	Running			
12		Sand Filter System				
12.01	PID17	Sand Filter	Running			
12.02	PID17	Filter Reject Tank	In operation			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
13		Effluent Tank and Pumping				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Maintenance		2	Windings need to be replaced so sent to Henderson Electric. VFD burned up and the breaker has blown and tripped the main breaker. A new VFD and breaker have been ordered. ETI is coordinating installation upon arrival.
13.03	PID10C	Effluent Booster Pump - P1302B	Running			
13.04	PID10C	Area Around Effluent and North D-1	Running			
14		Solids Collection and Pressing System				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation			
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running		3	ETI repaired slide air valve.
14.06	PID09	Filter Press Pump - P902	Running			
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running		3	Work is continuing on plate shifter.
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			

¹Status Codes

- Running - Unit is in operation
- Standby - Spare or duplicate, not currently in operation
- Maintenance - Out of service for maintenance
- Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
Chemical Systems						
15		Electron Donor System				
15.01	PID07B	<i>Electron Donor Tank</i>	In operation			
15.02	PID07B	<i>Booster Pump P739A</i>	Running			
15.03	PID07B	<i>Booster Pump P739B</i>	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23	PID07C	Ferric Chloride System	In operation			
24	PID07B	Polymer Systems - DAF	In operation		4	ETI began removing obsolete piping from old polymer system.
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
Utility Systems						
26		Compressed Air System				
26.01	PID08	<i>West Compressor</i>	Running			
26.02	PID08	<i>East Compressor</i>	Running			
26.03	PID08	<i>O2 Compressor</i>	Running			
26.04	PID08	<i>Compressed Air Receiver Tank</i>	In operation			
26.05	PID08	<i>Air Dryer</i>	Running			
26.06	PID08	<i>Oil Removal Filter</i>	In operation			
26.07	PID08	<i>Particulate Filter</i>	In operation			
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
29		Well Control System/ Allen Bradley Controls	In operation		2	ETI received their repaired computer and it is back in service.
30		MCC FBR Pad	In operation			
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
Miscellaneous Systems						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
Shelf Spares						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			

¹ Status Codes

Equipment

Running Unit is in operation
 Standby Duplicate or installed spare, not currently operating
 Maintenance Out for repairs or maintenance
 Off Not currently needed, but available

¹ Criticality Codes

1 = Critical Cannot continue with operation until repairs made
 2 = Important Can still operate safely and in compliance with permits, but risks are increased
 3 = Moderate Work needs to be performed, but plant can still operate with redundancy that is in place
 - Tasks performed to either improve the existing equipment (i.e., testing new options)
 4 = Low - Minor repairs that in no way alter the performance of the plant

Tanks, Pipelines, Ponds

In operation
 Out of service

Spares

In stock

¹ Status Codes

Running - Unit is in operation
 Standby - Spare or duplicate, not currently in operation
 Maintenance - Out of service for maintenance
 Off - Not currently needed for use, but can be placed in service