

MEMO

To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: David Bohmann, Deena Garland

Date: December 22, 2015

Subject: NERT – GWETS Operation Monthly Report – November 2015

At the request of the Nevada Environmental Response Trust (Trust), Tetra Tech, Inc. (Tetra Tech) provides this summary of the groundwater extraction and treatment system (GWETS) operation and oversight tasks performed during November 2015.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) reports that the GWETS mechanically operated normally in November 2015 with the exception of one spill that is described in more detail below. The flow rate to the plant averaged approximately 904 gallons per minute (gpm) during November 2015. At the end of the month, the GW-11 Pond volume was 43.1 million gallons (MG), which would allow 13.4 days of available additional storage in event of an emergency plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond decreased approximately 0.9 MG from the end of October. Figure 1 in this report depicts the actual and projected GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the Fluidized Bed Reactor (FBR) plant averaged 82 mg/L for the month, with a maximum concentration of 88 mg/L.

Analytical data indicate that the permitted effluent discharges at GWETS Outfall 001 were within the NPDES permitted numerical discharge limits (Please see Attachment A, prepared by ENVIRON).

Enhanced Operational Metrics

Tetra Tech continues to move forward with the approved Enhanced Operational Metrics program to add instruments, controls, data acquisition systems, along with various other technical upgrades to improve the efficiency of GWETS data collection and reporting. An implementation schedule is presented in more detail under the GWETS Upgrades and Facility Projects section below.

Tables 1 and 2 provide a summary of the current GWETS operational metrics that provide data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 presents historical perchlorate and chromium mass flux.

Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Henderson, Nevada Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11 Pond

- GW-11 Pond Leak Detection System: Tetra Tech prepared a summary of the camera surveys it performed of the SE and SW sump riser pipes for Trust review. Tetra Tech also prepared a recommended procedure to repair the NE sump riser pipe, and reinforcement of the NW, SE, and SW sump riser pipes. The Trust is reviewing the procedure.

2. Spill

- A pinhole leak was discovered on the flexible discharge hose attached to the hard discharge line from well PC-99R2/R3 at Lift Station 1 at approximately 11:10 AM PST on November 27, 2015. The volume spilled is estimated to be less than 5 gallons. Well PC-99R2/R3 was offline from 11:37 AM PST to 3:22 PM PST on November 27th to replace the entire length of hose. The incident was reported at approximately 4:05 PM PST on November 27th to the NDEP Spill Notification line. The incident was assigned Spill Incident No. 151127-01.

3. Maintenance

- Major maintenance that was performed or completed in the month included:
 - i. A new VFD and breaker for Effluent Booster Pump P-1302A were received and the replacements and software upgrades were completed on November 30th.
 - ii. Old, worn wiring for the IWF wells was discovered underground and replaced.
 - iii. A new hose was installed on the PC 99R2/R3 to replace a worn hose in response to a pinhole leak.
- Preventative Maintenance completed or being performed in the month included:
 - i. The combination valve on the effluent line was replaced at the EQ area. ETI also inspected the sump pump and adjusted the level indicator.
 - ii. A damaged airline used to control bed height was repaired and piping was replaced on the discharge side of the bed height pump for FBR A.

- iii. The discharge line for the Media Return Pump P-2011 was cleared to the top of the FBRs.
 - iv. The glue fitting on piping at the injection point for FBR 3 was found to be damaged and was subsequently repaired.
 - v. Bearings were ordered and received for Media Return Pump P-3011. Repairs and replacement work began the week of December 7th.
 - vi. A replacement seal was received for DAF Pressure Pump P-551 and repair work will begin the week of December 7th.
 - vii. ETI relocated the polymer system to the north side of the D-1 building to reduce the amount of time polymer is in direct sunlight.
 - viii. The flow meter for I-Q is out of service and pending replacement under warranty.
 - ix. A manual bleed valve was installed on the compressed air receiver tank until a new switch is received in December.
- Outstanding or ongoing maintenance and repairs from the previous month are outlined below:
 - i. FBRs 7 and 8 are currently in the rehabilitation process and all forward flow is being sent to FBRs 5 and 6.
 - ii. The pneumatic cylinder on the East Filter Press needs to be serviced. ETI is currently in the process of replacing the airlines to the plate switch. The press can still operate and the plates can be moved manually while work is being completed.

GWETS Upgrades and Facility Projects

The following is a summary of the initiatives in-progress during the reporting period at the direction of the Trust:

1. AP-5 Solids Removal

Tetra Tech is moving forward with the design to remove the AP-5 pond solids, wash the solids to remove perchlorate salts, and relocate the perchlorate containing water to a large storage tank for eventual treatment in the GWETS. Evaluation and coordination between Tetra Tech, ETI, the Trust and NDEP on this project is ongoing. Additional AP5 material sampling for off-site analysis and testing will be conducted the week of December 7. Tank purchase is on hold pending test results.

2. Enhanced Operational Metrics

Work on site that began in late August remains underway. Metrics data collection commenced as planned in mid-November and final system commissioning is scheduled for mid- to late December. A new flow meter was installed at Lift Station 2 on November 5, 2015 which resulted in a shutdown of the SWF, AWF, and Lift Stations 1, 2, and 3. The Stakeholders were notified during the Quarterly Call on November 4, 2015 and via e-mail on November 6, 2015.

Equipment Availability Tracking

ETI operators continue to update the equipment tracking form on a weekly basis at a minimum, or whenever there is a change in the status of key equipment. During regular site visits, Tetra Tech field personnel continue to verify the entries on the form, including both the operating status and confirming the inventory of required shelf spares. The equipment tracking form submitted by ETI to Tetra Tech on November 30, 2015 is included as Attachment B.

GWETS Staffing

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

GWETS Security

During weekly calls, ETI notifies Tetra Tech of any issues with GWETS security. There were no GWETS security issues reported during the month of November.

Tetra Tech Activities

Tetra Tech conducted calls with ETI to review operation of the GWETS on November 5th, 12th, and 19th. No call was held on Thanksgiving. Kyle Hansen, CEM, performed the GWETS oversight and review activities on November 6th, 13th, 20th, and 30th. Mr. Hansen also reviewed permit and sampling forms for the entire month to ensure each form was correct and up-to-date, checked equipment status, and verified shelf spare inventory.

Summary

Based on our review of available and relevant information, Tetra Tech concurs with ETI's management of the GWETS during the reporting period. No additional involvement from either the Trust or Tetra Tech is recommended at this time.

Tables

Operational Metrics

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) ²	Chromium TR (mg/L) ²	Chromium(VI) (mg/L) ^{2,8}
SWF Total Extraction ⁵	444 ¹	12	ND	Future Metric
AWF Total Extraction ⁵	297 ¹	178	0.35	Future Metric
IWF Total Extraction ⁶	54 ¹	896	8.31	Future Metric
GWTP Effluent ⁷	63	799	0.22	ND
GW-11 Influent ⁴	51 ³	Future Metric	Future Metric	Future Metric
GW-11 Effluent/ FBR Influent ⁷	904	4	0.04	ND

Notes:

TR = Total Recoverable; ND = not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Sum of daily average flow for individual wells.

2: All concentrations reported are monthly flow weighted averages.

3: Flow has historically been a calculated metric, but Tetra Tech transitioned to flow meter measurement beginning on April 27, 2015.

4: Following contractual amendment agreements, ETI will begin collecting analytical samples at the GW-11 influent sample tap.

5: Perchlorate sampled monthly, chromium TR sampled quarterly, values reported from TestAmerica.

6: Perchlorate and chromium TR sampled quarterly, values reported from TestAmerica.

7: Perchlorate, chromium TR and chromium (VI) sampled weekly, values reported from TestAmerica.

8: Hexavalent chromium will be analyzed and reported monthly as part of the Enhanced Operational Metrics project.

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics		
Location ID	Perchlorate (lbs/month) ¹	Chromium TR (lbs/month) ¹
SWF Total Extraction	1,947	0
AWF Total Extraction	19,038	38
IWF Total Extraction	16,095	149
GWTP Effluent	18,166	5
GW-11 Influent ²	Future Metric	Future Metric
GW-11 Effluent/FBR Influent	82	0.74

Notes:

TR = Total Recoverable.

1: Total lbs extracted is calculated from flow weighted average concentration and average flow (see Table 1).

2: Following contractual amendment agreements, ETI will begin collecting analytical samples at the GW-11 influent sample tap.

Figures

Operational Metrics

Figure 1 - GW-11 Pond Volume Projection





Figure 2 - Historical Perchlorate Mass Flux



Attachment A

NPDES Tracking Sheet (Prepared by ENVIRON)

Summary table for Continuous and Daily samples, composited weekly. Columns: Flow Rate (30-Day Avg. MGD, Daily Maximum MGD), Perchlorate (30-Day Avg. ug/L, 30-Day Avg. lbs/day). Values: 1.45, 1.75, 18, 0.22.

Summary table for Weekly samples. Columns: pH, Hexavalent Chromium, Total Chromium, Total Suspended Solids (TSS), Total Iron, Total Ammonia as N, Total Phosphorus as P. Values range from 6.5 to 9.0 for pH and 0.01 to 1.634 for TSS.

Summary table for Weekly samples, collected separately and Quarterly sample. Columns: BOD5 (Inhibited) (30-Day Avg. mg/L, Daily Max. mg/L, 30-Day Avg. lbs/day), Manganese (30-Day Avg. mg/L, 30-Day Avg. lbs/day). Values: 25, 40, 254, 5, 60.52.

Monthly summary table for 2015. Columns: Month, Flow Rate (30-Day Avg. MGD, Daily Maximum MGD), Perchlorate (30-Day Avg. ug/L, 30-Day Avg. lbs/day), and various chemical parameters (pH, Hexavalent Chromium, Total Chromium, TSS, Total Iron, Total Ammonia as N, Total Phosphorus as P, BOD5, Manganese).

Main data table with columns for Daily Grab Sample Dates, Composite Sample Date, ug/L, lbs/day, Sample Date, S.U., mg/L, mg/L, mg/L, lbs/day, mg/L, lbs/day, mg/L, lbs/day, mg/L, lbs/day, mg/L, lbs/day, Sample Date, mg/L, lbs/day, mg/L, lbs/day. Contains detailed analytical data for each day in 2015.

Note: All analytical responsibilities are performed by TestAmerica Laboratories, Inc. (TestAmerica) in Irvine, California, unless otherwise indicated.

NA = Not Available To Date
NS = No Sample
ND = Not Detected above laboratory reporting limit; concentration in adjacent cell to right is one-half the reporting limit (per Permit condition)
-- = Analyte detected; see column adjacent to right
Last Updated: December 4, 2015

Attachment B

Equipment Tracking Form

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
		Main Plant Equipment				
1		Seep Wells and Lift Station 1				
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Standby			
1.03		Lift Station 1 Lift Pump B	Running			
1.04		Area in and around Lift Station 1	Running		2	ETI installed a new hose on center well discharge to replace worn hose.
2		Athens Road Wells and Lift Station 3				
2.01		Athens Road Well Field, 9 wells	Running			
2.02		Lift Station 3 Lift Pump A	Running			
2.03		Lift Station 3 Lift Pump B	Standby			
2.04		Area in and around Lift Station 3	Running			
3		Lift Station 2 and Transmission Pipelines				
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running			
4		Interceptor Wells and Cr Treatment Plant				
4.01		IWF Well Field, 30 wells	Running		1	IWF breakers burnt up. Discovered old worn wiring underground. Repaired wiring and put well field back online.
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation			
4.05		Filter Press	Running			
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Standby			
4.08		Interceptor Booster Pump B	Running			
4.09		Area In And Around GWTP	Running			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
5		Equalization Area and GW-11 Pond				
5.01	PID10A	Pond GW-11	In operation			
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Running			
5.04	PID10A	Equalization Tanks	In operation			
5.05	PID10A	Area in and Around EQ	In operation		3	ETI repaired the combo valve on the effluent line. ETI inspected the sump pump and adjusted level indicator for more efficient use.
5.06	PID10A	Raw Water Feed Pump - P102A	Standby			
5.07	PID10A	Raw Water Feed Pump - P102B	Running			
5.08	PID10A	F-101 Filters	Running		3	ETI repaired a small leak (inside containment) at the auto flush system.
5.09	PID10B	Carbon Absorber - LGAC 201A	Running			
5.10	PID10B	Carbon Absorber - LGAC 201B	Running			
5.11	PID10B	Carbon Absorber - LGAC 201C	Running			
6		First Stage FBRs A, 1 & 2				
6.01	PID14	FBR A	Running		3	ETI reconnected damaged air line for bed height control and replaced piping on the discharge side of the bed height pump.
6.02	PID14	Separator Tank - 1401	Running			
6.03	PID14	Media Return Pump - P 1401	Running			
6.04	PID14	P1401A	Running			
6.05	PID01A	P1401B	Standby			
6.06	PID01A	FBR 1	Running			
6.07	PID02A	FBR 2	Running			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Maintenance		3	ETI cleared discharge line to the top of the FBR's.
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012	Running			
6.12	PID01A	First Stage FRB Pump - P101A	Running			
6.13	PID07A	FBR A pH Feed Pump - P71A	Off			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
6.14	PID07A	FBR 1 pH Feed Pump - P711	Off			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Off			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Off			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Off			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Off			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Running			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
7		First Stage FBRs 3 & 4				
7.01	PID01B	FBR 3	Off		2	ETI repaired worn glue fitting at injection point.
7.02	PID01B	FBR 4	Off			
7.03	PID02B	First Stage Separator Tank - T2012	Off			
7.04	PID01B	Media Return Pump - P2012	Off			
7.05	PID01B	First Stage FBR Pump - P1013	Off			
7.06	PID01B	First Stage FRB Pump - P1014	Off			
7.07	PID01B	First Stage FBR Pump - P102A	Off			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Off			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Off			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723	Off			
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P 724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Off			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Off			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Off			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Off			
8		Second Stage FBRs 5 & 6				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Maintenance		3	Bearings were ordered and received. Replacement work starting 12/7.
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			

¹Status Codes

- Running - Unit is in operation
- Standby - Spare or duplicate, not currently in operation
- Maintenance - Out of service for maintenance
- Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
9		Second Stage FBRs 7 & 8				
9.01	PID03B	FBR 7	Running		4	ETI is transferring carbon from FBR 8 into 7
9.02	PID03B	FBR 8	Running		4	ETI is transferring carbon from FBR 8 into 7. Began draining FBR
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Standby			
9.05	PID03B	Second Stage FBR Pump - P3017	Running			
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Standby			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Standby			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Standby			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Standby			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Standby			
10		Aeration and DAF System				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Biofilter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Biofilter Sump	Running			
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Biofilter Sump Pump - P402A	Standby			
10.09	PID04	Biofilter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running		3	ETI is replacing the seal and repairing pump beginning 12/7.
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			

¹Status Codes

- Running - Unit is in operation
- Standby - Spare or duplicate, not currently in operation
- Maintenance - Out of service for maintenance
- Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
10.18	PID05	Skimmer Drive	Running			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
11		Pumping System (Old Effluent)				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Standby			
11.03	PID06	Effluent Pump - P602	Running			
12		Sand Filter System				
12.01	PID17	Sand Filter	Running		4	New water line run to the top of the sand filter
12.02	PID17	Filter Reject Tank	In operation			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
13		Effluent Tank and Pumping				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Maintenance		2	The pump, motor, and software programming completed.
13.03	PID10C	Effluent Booster Pump - P1302B	Running			
13.04	PID10C	Area Around Effluent and North D-1	Running			
14		Solids Collection and Pressing System				
14.01	PID16	Sludge Storage Tank	In operation			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	In operation			
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902	Running			
14.07	PID09	West Press	Standby			
14.08	PID09	East Press	Running		3	ETI is replacing the air lines to the plate shifter.
14.09	PID09	Filtrate Tank	In operation			
14.10	PID09	Filtrate Tank Effluent (recycle) Pump - P903	Running			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
Chemical Systems						
15		Electron Donor System				
15.01	PID07B	<i>Electron Donor Tank</i>	In operation			
15.02	PID07B	<i>Booster Pump P739A</i>	Running			
15.03	PID07B	<i>Booster Pump P739B</i>	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23	PID07C	Ferric Chloride System	In operation			
24	PID07B	Polymer Systems - DAF	In operation		4	Polymer system relocated to north side of the D-1 building to reduce the amount of time polymer is in direct sunlight.
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
Utility Systems						
26		Compressed Air System				
26.01	PID08	<i>West Compressor</i>	Running			
26.02	PID08	<i>East Compressor</i>	Running			
26.03	PID08	<i>O2 Compressor</i>	Running			
26.04	PID08	<i>Compressed Air Receiver Tank</i>	In operation		3	ETI installed manual bleed valve until new switch is received.
26.05	PID08	<i>Air Dryer</i>	Running			
26.06	PID08	<i>Oil Removal Filter</i>	In operation			
26.07	PID08	<i>Particulate Filter</i>	In operation			
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			
29		Well Control System/ Allen Bradley Controls	In operation			
30		MCC FBR Pad	In operation			

¹Status Codes

- Running - Unit is in operation
- Standby - Spare or duplicate, not currently in operation
- Maintenance - Out of service for maintenance
- Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			

¹Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
Miscellaneous Systems						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
Shelf Spares						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock			
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			

¹ Status Codes

Equipment

Running

Unit is in operation

Standby

Duplicate or installed spare, not currently operating

Maintenance

Out for repairs or maintenance

Off

Not currently needed, but available

¹ Criticality Codes

1 = Critical Cannot continue with operation until repairs made

2 = Important Can still operate safely and in compliance with permits, but risks are increased

3 = Moderate Work needs to be performed, but plant can still operate with redundancy that is in place

4 = Low
 - Tasks performed to either improve the existing equipment (i.e., testing new options)
 - Minor repairs that in no way alter the performance of the plant

Tanks, Pipelines, Ponds

In operation

Out of service

Spares

In stock

¹ Status Codes

Running - Unit is in operation

Standby - Spare or duplicate, not currently in operation

Maintenance - Out of service for maintenance

Off - Not currently needed for use, but can be placed in service