



To: Nevada Division of Environmental Protection
Nevada Environmental Response Trust

Cc: Nevada Environmental Response Trust Stakeholders

From: Jeff Lance

Date: February 20, 2016

Subject: NERT – GWETS Operation Monthly Report – January 2016

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies Inc. (ETI) provides this summary of the groundwater extraction and treatment system (GWETS) operation and performance during January 2016.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS normally in January 2016. The flow rate to the plant averaged approximately 926 gallons per minute (gpm) during January 2016. At the end of the month, the GW-11 Pond volume was 44.0 million gallons (MG), which would allow 12.8 days of available additional storage in event of an emergency plant shutdown with continued well field pumping. The water volume stored in the GW-11 Pond increased approximately 0.6 MG from the end of December. Figure 1 in this report depicts the actual and projected GW-11 pond volumes and additional storage available.

The influent perchlorate concentration to the FBR plant averaged 81 mg/L for the month, with a maximum concentration of 90 mg/L.

Analytical data indicate that the permitted effluent discharges at GWETS Outfall 001 were within the NPDES permitted numerical discharge limits (Please see Attachment A, prepared by Ramboll Environ).

Enhanced Operational Metrics

Tetra Tech testing and transfer of operations with the newly installed software and instruments to ETI was completed in December. Final project items are presented in more detail under the GWETS Upgrades and Facility Projects section below.

Tables 1 and 2 provide a summary of the current GWETS operational metrics that provide data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 presents historical perchlorate and chromium mass flux.



Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Henderson, Nevada Operations Manual. The following is a list of operational issues and major repairs and/or equipment replaced during this reporting period.

1. GW-11 Pond

- GW-11 Pond Leak Detection System: ETI is currently evaluating options to repair the NE riser pipe to enable the pump to be set at its proper depth. ETI anticipates implementation of the repair by 25 March 2016.
- Tetra Tech has performed an initial site inspection for the installation of a stilling well in GW-11. The stilling well will house an electronic transducer that will transmit water level data to the control room in the D1 Bldg. Installation is scheduled for March 2016.

2. Biological Plant

- The Plant operated with no interruptions or unplanned diversions for the month of January.
- Planned Shut Down: The biological plant diverted flow for a planned maintenance operation on a combo valve in the effluent pipeline on January 05, 2016, a total of 13,807 gals was diverted to GW-11.

3. Spill

- No reportable spills occurred in January 2016.

4. Maintenance

- Major maintenance that was performed or completed in the month included:
 - i. ETI replaced the pump & motor on well PC99R3.
 - ii. ETI installed new motor starter and contactors on well PC99R3.
 - iii. ETI installed new seals in P1302A effluent pump and placed the pump back on-line.
 - iv. South DAF taken off-line and drained to perform inspection and repairs.
 - v. Sand filter header repaired and put back on-line.
- Preventative Maintenance completed or being performed in the month included:
 - i. Sump pump adjacent to the DAF's replaced.
 - ii. Media Return Pump P3011 was rebuilt and is back on-line.
 - iii. Pumps P-602 and 601 rotated lead/lag.
 - iv. Performed semi- annual inspection of Vertical Turbine pumps VT 200N.
 - v. P-758B Ferric Chloride pump inspected and rotated.



- Outstanding or ongoing maintenance and repairs from the previous month are outlined below:
 - i. FBR 8 is offline and currently in the rehabilitation process and all forward flow is being sent to FBRs 5 and 6, on -going from last month.

GWETS Upgrades and Facility Projects

The following is a summary of the initiatives in-progress during the reporting period at the direction of the Trust:

1. AP-5 Solids Removal

Tetra Tech is moving forward with the design to remove the AP-5 pond solids, wash the solids to remove perchlorate salts, and relocate the perchlorate containing water to a large storage tank for eventual treatment in the GWETS. Evaluation and coordination between Tetra Tech, ETI, the Trust and NDEP on this project is ongoing. Tetra Tech is continuing to evaluate the sample results of the pond sediments. In February an investigation will be performed on the berms to determine the safety of walking on the berm due to potential presence of elevated concentrations of perchlorate.

ETI has resumed the pumping of the interstitial space between the liners to check the liner integrity.

2. Enhanced Operational Metrics

ETI has taken control of system and continues to make adjustments to the newly installed controls and software. The punch-list was finalized and a number of items need resolution that were discovered over the course of the upgrade that were not apparent during the design phase. As such, a list of recommendations for tasks that are outside of Tetra Techs original scope has been forwarded to the Trust for review and approval. The specified spare parts list and Operation and Maintenance Manuals have been delivered to ETI, while as-built documents for close-out are still pending.

Equipment Availability Tracking

ETI operators continue to update the equipment tracking form on a weekly basis at a minimum, or whenever there is a change in the status of key equipment. During regular site visits, Tetra Tech field personnel verify the entries on the form, including both the operating status and confirmation of the inventory of required shelf spares. The equipment tracking form is included as Attachment B.

GWETS Staffing

ETI continues with 24-hour staffing of the GWETS at the direction of the Trust and continues to follow the security procedures in the Standard Operating Procedures (SOP).

GWETS Security

During weekly calls, ETI notifies Tetra Tech of any issues with GWETS security. There were no GWETS security issues reported during the month of January.



Tables

Operational Metrics

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics				
Location ID	Average Flow Rate (gpm)	Perchlorate (mg/L) ²	Chromium TR (mg/L) ²	Chromium(VI) (mg/L) ^{2,5}
SWF Total Extraction ³	529 ¹	13	0.001	Future Metric
AWF Total Extraction ³	254 ¹	124	0.33	Future Metric
IWF Total Extraction ³	59 ¹	780	9.02	Future Metric
GWTP Effluent ⁴	56	786	0.77	ND
GW-11 Influent	859	110	0.10	0.062
GW-11 Effluent/ FBR Influent ⁴	926	85	0.03	ND

Notes:

TR = Total Recoverable; ND = not detectable above laboratory method detection limit (Chromium (VI) = 0.25 ug/L).

1: Sum of daily average flow for individual wells.

2: All concentrations reported are monthly flow weighted averages.

3: Perchlorate and chromium TR sampled monthly, values reported from TestAmerica.

4: Perchlorate, chromium TR and chromium (VI) sampled weekly, values reported from TestAmerica.

5: Hexavalent chromium will be analyzed and reported monthly beginning in 2016.

Nevada Environmental Response Trust Groundwater Extraction and Treatment System Monthly Stakeholder Metrics		
Location ID	Perchlorate (lbs/month) ¹	Chromium TR (lbs/month) ¹
SWF Total Extraction	2,633	0.2
AWF Total Extraction	11,778	31
IWF Total Extraction	17,136	198
GWTP Effluent	16,419	16
GW-11 Influent	35,225	32
GW-11 Effluent/FBR Influent	27,159	10

Notes:

TR = Total Recoverable.

1: Total lbs extracted is calculated from flow weighted average concentration and average flow (see Table 1).



A Lifecycle Performance Company

Figures

Operational Metrics





Figure 2 - Historical Perchlorate Mass Flux



Note: Total perchlorate shown on this graph was calculated from the sum of perchlorate extracted from wells. It should be noted that due to the accuracy of existing flow meters, this total may not align with total perchlorate reported in FBR influent flow.



A Lifecycle Performance Company

Attachment A

NPDES Tracking Sheet (Prepared by ENVIRON)

Continuous		Daily samples, composited weekly	
Flow Rate		Perchlorate	
30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (ug/L)	30-Day Avg. (lbs/day)
1.45	1.75	18	0.22

Weekly samples								
pH	Hexavalent Chromium	Total Chromium	Total Suspended Solids (TSS)		Total Iron		Total Ammonia as N	Total Phosphorus as P
30-Day Avg. (S.U.)	Daily Max. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)	30-Day Avg. (lbs/day)
6.5 to 9.0	0.01	0.1	135	1,634	10	121.03	40	20

Weekly samples, collected separately			Quarterly sample	
BOD ₅ (inhibited)			Manganese	
30-Day Avg. (mg/L)	Daily Max. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)
25	40	254	5	60.52

December 2015	1.32	1.43	1.3	0.014	6.94	0.00013	0.011	16	170	2.2	24	3.7	0.6	8	20	92
January 2016	1.28	1.39	1.3	0.013	6.89	0.00013	0.022	24	250	4.5	47	9	0.25	5.8	6.5	61
February 2016 (month to date)	1.27	1.35	NA	NA	6.94	0.00013	0.015	35	380	4.5	49	2	0.64	NA	NA	NA

Daily Grab Sample Dates	Composite Sample Date	ug/L	lbs/day	Sample Date	S.U.	mg/L	mg/L	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	mg/L	lbs/day	Sample Date	mg/L	lbs/day	mg/L	lbs/day	
11/29 - 12/5	12/5/2015	ND (<2.5)	1.3	0.014	11/30/2015	7.00	ND (<0.00025)	0.014	21	239	4.4	50	ND (<0.10)	0.05	0.57	ND (<0.025)	0.013	0.14	12/2/2015	7.7	88		
12/6 - 12/12	12/12/2015	ND (<2.5)	1.3	0.012	12/7/2015	6.85	ND (<0.00025)	0.0082	19	190	3.5	35	--	0.23	2.3	ND (<0.025)	0.013	0.12	12/9/2015	4.2	42		
12/13 - 12/19	12/19/2015	ND (<2.5)	1.3	0.015	12/14/2015	6.86	ND (<0.00025)	0.0075	18	211	1.8	21	--	0.81	9.5	--	0.11	1.3	12/16/2015	1.8	21		
12/20 - 12/26	12/26/2015	ND (<2.5)	1.3	0.014	12/21/2014	7.10	ND (<0.00025)	0.0090	19	208	3.1	34	--	0.14	1.5	--	0.036	0.39	12/23/2015	7.4	81		
12/27 - 1/2	1/2/2016	ND (<2.5)	1.3	0.014	12/29/2015	6.94	ND (<0.00025)	0.011	6.6	75	0.51	5.8	--	0.14	1.6	--	0.060	0.68	12/30/2015	20	227		
1/3 - 1/9	1/9/2016	ND (<2.5)	1.3	0.013	1/4/2016	6.92	ND (<0.00025)	0.0070	18	193	3.9	42	--	0.32	3.4	--	0.028	0.30	1/6/2016	5.7	61		
1/10 - 1/16	1/16/2016	ND (<2.5)	1.3	0.013	1/11/2016	7.02	ND (<0.00025)	0.022	25	260	5.0	52	--	1.8	19	ND (<0.025)	0.013	0.13	1/13/2016	6.5	68		
1/17 - 1/23	1/23/2016	ND (<2.5)	1.3	0.013	1/19/2016	6.62	ND (<0.00025)	0.016	30	311	5.1	53	--	0.96	10	ND (<0.025)	0.013	0.13	1/20/2016	6.0	62		
1/24 - 1/30	1/30/2016	ND (<2.5)	1.3	0.013	1/25/2016	7.01	ND (<0.00025)	0.014	23	255	3.8	42	--	0.19	2.1	--	0.040	0.44	1/27/2016	4.8	53		
1/31 - 2/6	2/6/2016	NA	NA	NA	2/1/2016	6.94	ND (<0.00025)	0.015	35	381	4.50	49	--	0.18	2.0	--	0.059	0.64	2/3/2016	NA	NA		
2/7-2/13	2/13/2016	NA	NA	NA	2/8/2016	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	MA	NA	NA	2/10/2016	NA	NA		

Note: All analytical responsibilities are performed by TestAmerica Laboratories, Inc. (TestAmerica) in Irvine, California, unless otherwise indicated.

NA = Not Available To Date

ND = Not Detected above laboratory reporting limit; concentration in adjacent cell to right is one-half the reporting limit (per Permit condition)

-- = Analyte detected; see column adjacent to right

Last Updated: February 12, 2016



A Lifecycle Performance Company

Attachment B

Equipment Tracking Form

Report Date: Jan 27 2016

Sub-System	P&ID	Description	Status ¹	Checked	Criticality ²	Notes
		Main Plant Equipment				
1		Seep Wells and Lift Station 1				
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Standby			
1.03		Lift Station 1 Lift Pump B	Running			
1.04		Area in and around Lift Station 1	Running			
2		Athens Road Wells and Lift Station 3				
2.01		Athens Road Well Field, 9 wells	Running			
2.02		Lift Station 3 Lift Pump A	Running			
2.03		Lift Station 3 Lift Pump B	Standby			
2.04		Area in and around Lift Station 3	Running			
3		Lift Station 2 and Transmission Piplines				
3.01		Influent Pipeline	In operation			
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station 2	Running		3	Testing the float switches in the well. Discovered wrong wiring in the panel.
4		Interceptor Wells and Cr Treatment Plant				
4.01		IWF Well Field, 30 wells	Running		2	Replaced pigtail connecting power to the motor
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	In operation			
4.05		Filter Press	Running			
4.06		GWTP Effluent Tank	In operation			
4.07		Interceptor Booster Pump A	Standby			
4.08		Interceptor Booster Pump B	Running		3	Replaced the discharge hose and installed cam lock fitting
4.09		Area In And Around GWTP	Running			
5		Equalization Area and GW-11 Pond				

5.01	PID10A	<i>Pond GW-11</i>	In operation			
5.02	PID10A	<i>Pond Water Pump - P101A</i>	Running			
5.03	PID10A	<i>Pond Water Pump - P101B</i>	Maintenance		3	Mechanical seal leaking. New one on order.
5.04	PID10A	<i>Equalization Tanks</i>	In operation			
5.05	PID10A	<i>Area in and Around EQ</i>	In operation			
5.06	PID10A	<i>Raw Water Feed Pump - P102A</i>	Running			
5.07	PID10A	<i>Raw Water Feed Pump - P102B</i>	Standby			
5.08	PID10A	<i>F-101 Filters</i>	Running			
5.09	PID10B	<i>Carbon Absorber - LGAC 201A</i>	Running			
5.10	PID10B	<i>Carbon Absorber - LGAC 201B</i>	Running			
5.11	PID10B	<i>Carbon Absorber - LGAC 201C</i>	Running			
6		First Stage FBRs A, 1 & 2				
6.01	PID14	<i>FBR A</i>	Running			
6.02	PID14	<i>Separator Tank - 1401</i>	Running			
6.03	PID14	<i>Media Return Pump - P 1401</i>	Running			
6.04	PID14	<i>P1401A</i>	Standby			
6.05	PID01A	<i>P1401B</i>	Running			
6.06	PID01A	<i>FBR 1</i>	Running			
6.07	PID02A	<i>FBR 2</i>	Running			
6.08	PID01A	<i>First Stage Separator Tank - T2011</i>	Running			
6.09	PID01A	<i>Media Return Pump - P2011</i>	Running		3	Flushed line and replaced belt
6.10	PID01A	<i>First Stage FBR Pump - P1011</i>	Standby			
6.11	PID01A	<i>First Stage FBR Pump - P1012</i>	Running			
6.12	PID01A	<i>First Stage FRB Pump - P101A</i>	Running			
6.13	PID07A	<i>FBR A pH Feed Pump - P71A</i>	Off			
6.14	PID07A	<i>FBR 1 pH Feed Pump - P711</i>	Off			
6.15	PID07A	<i>FBR 2 pH Feed Pump - P712</i>	Off			
6.16	PID07A	<i>FBR A Nutrient (Urea) Feed Pump - P72A</i>	Off			
6.17	PID07A	<i>FBR 1 Nutrient (Urea) Feed Pump - P721</i>	Off			
6.18	PID07A	<i>FBR 2 Nutrient (Urea) Feed Pump - P722</i>	Off			
6.19	PID15	<i>FBR A Nutrient (Phos Acid) Feed Pump - P1520A</i>	Running			
6.20	PID15	<i>FBR 1 Nutrient (Phos Acid) Feed Pump - P1521</i>	Running			
6.21	PID15	<i>FBR 2 Nutrient (Phos Acid) Feed Pump - P1522</i>	Running			
6.22	PID07B	<i>FBR A Electron Donor Assembly Pump - P73A</i>	Running			
6.23	PID07B	<i>FBR 1 Electron Donor Assembly Pump - P731</i>	Running			
6.24	PID07B	<i>FBR 2 Electron Donor Assembly Pump - P732</i>	Running			

7		First Stage FBRs 3 & 4				
7.01	PID01B	FBR 3	Off			
7.02	PID01B	FBR 4	Off			
7.03	PID02B	First Stage Separator Tank - T2012	Off			
7.04	PID01B	Media Return Pump - P2012	Off			
7.05	PID01B	First Stage FBR Pump - P1013	Off			
7.06	PID01B	First Stage FRB Pump - P1014	Off			
7.07	PID01B	First Stage FBR Pump - P102A	Off			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Off			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Off			
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723	Off			
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P724	Off			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Off			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Off			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Off			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Off			
8		Second Stage FBRs 5 & 6				
8.01	PID03A	FBR 5	Running			
8.02	PID03A	FBR 6	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running	3		Cam is wearing out on the shaft. Pump is still operating, scheduled for repair
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Off			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Off			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Off			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Off			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
9		Second Stage FBRs 7 & 8				
9.01	PID03B	FBR 7	Off			
9.02	PID03B	FBR 8	Off	4		Continuing to remove carbon from FBR.
9.03	PID03D	Second Stage Separator Tank - T3012	Off			
9.04	PID03B	Media Return Pump - P3012	Off			

9.05	PID03B	Second Stage FBR Pump - P3017	Off			
9.06	PID03B	Second Stage FBR Pump - P3018	Off			
9.07	PID03B	Second Stage FBR Pump - P302A	Off			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Off			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Off			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Off			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Off			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Off			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Off			
10		Aeration and DAF System				
10.01	PID04	Aeration Tank	In operation			
10.02	PID04	Aeration Blower - B401	Running			
10.03	PID04	Biofilter	In operation			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Biofilter Sump	Running			
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Biofilter Sump Pump - P402A	Standby			
10.09	PID04	Biofilter Blower	Running			
10.10	PID05	DAF Pressure Tanks	In operation			
10.11	PID05	DAF Vessel - D501	Running	2		DAF down for repairs on the vessel. Contractors are scheduled for this week.
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Running			
10.15	PID05	DAF Pressure Pump - P551	Running	3		New casing gasket on order.
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			
11		Pumping System (Old Effluent)				
11.01	PID06	Effluent Tank 601	In operation			
11.02	PID06	Effluent Pump - P601	Standby			
11.03	PID06	Effluent Pump - P602	Running			
12		Sand Filter System				
12.01	PID17	Sand Filter	Maintenance	2		Header cap failed supplying to the air lifts. Sand filter is down. Repair plan is in process to repair.

12.02	PID17	<i>Filter Reject Tank</i>	Out of service			
12.03	PID17	<i>Filter Reject Pump - P1701A</i>	Standby			
12.04	PID17	<i>Filter Reject Pump - P1701B</i>	Standby			
13		Effluent Tank and Pumping				
13.01	PID10C	<i>UV Effluent Tank</i>	Running			
13.02	PID10C	<i>Effluent Booster Pump - P1302A</i>	Running	2		Installed new motor and pump that was rebuilt.
13.03	PID10C	<i>Effluent Booster Pump - P1302B</i>	Standby			
13.04	PID10C	<i>Area Around Effluent and North D-1</i>	Running			
14		Solids Collection and Pressing System				
14.01	PID16	<i>Sludge Storage Tank</i>	In operation			
14.02	PID16	<i>Solids Storage Effluent Pump - P1601</i>	Running			
14.03	PID16	<i>Solids Cond. Tank</i>	In operation			
14.04	PID09	<i>Sludge Mixer</i>	Running			
14.05	PID09	<i>Filter Press Pump - P901</i>	Running			
14.06	PID09	<i>Filter Press Pump - P902</i>	Running			
14.07	PID09	<i>West Press</i>	Standby			
14.08	PID09	<i>East Press</i>	Running	4		Calling J-press to perform repairs on components of the press system. Press is still operational.
14.09	PID09	<i>Filtrate Tank</i>	In operation			
14.10	PID09	<i>Filtrate Tank Effluent (recycle) Pump - P903</i>	Running			
		Chemical Systems				
15		Electron Donor System				
15.01	PID07B	<i>Electron Donor Tank</i>	In operation			
15.02	PID07B	<i>Booster Pump P739A</i>	Running			
15.03	PID07B	<i>Booster Pump P739B</i>	Standby			
17	PID07C	Micro Nutrient System	In operation			
18	PID07C	Hydrogen Peroxide System	In operation			
19	PID07C	De-Foam System	In operation			
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	In operation			
21	PID07A	Nutrient (Urea) System (Tank only - pumps included in FBRs)	In operation			
22	PID07A	pH System (Tank and effluent pH feed pump only - other pumps included in FBRs)	In operation			
23	PID07C	Ferric Chloride System	In operation			
24	PID07B	Polymer Systems - DAF	In operation			

25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	In operation			
Utility Systems						
26		Compressed Air System				
26.01	PID08	West Compressor	Running			
26.02	PID08	East Compressor	Running			
26.03	PID08	O2 Compressor	Running			
26.04	PID08	Compressed Air Receiver Tank	In operation		3	installed manual bleed valve until new switch is received.
26.05	PID08	Air Dryer	Running			
26.06	PID08	Oil Removal Filter	In operation			
26.07	PID08	Particulate Filter	In operation			
27	PID16	Oxygen System	In operation			
28		GWETS Plant Controls/ Siemens Controls	In operation			
29		Well Control System/ Allen Bradley Controls	In operation			
30		MCC FBR Pad	In operation			
31		MCC in D-1	In operation			
32		MCC in EQ area	In operation			
Miscellaneous Systems						
33		Operations Office/Network	In operation			
34		Laboratory Analyzers	In operation			
35		Security Systems	In operation			
Shelf Spares						
		Media Return Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			
		Interceptor Well Pumps (4 each)	In stock			
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock		4	New pump and motor on order to replace the ones used for PC -99R3
		Athens Road Well Pump (1 each, same as Seep so total of 2)	In stock			

¹Status Codes

Equipment

Running

Unit is in operation

¹Criticality Codes

1 = Critical

2 =

Important

Cannot continue with operation until repairs made
Can still operate safely and in compliance with permits, but risks are increased



Standby

Duplicate or installed spare, not currently operating

3 =
Moderate

Work needs to be performed, but plant can still operate with redundancy that is in place

Maintenance

Out for repairs or maintenance

4 = Low

- Tasks performed to either improve the existing equipment (i.e., testing new options)

Off

Not currently needed, but available

- Minor repairs that in no way alter the performance of the plant

Tanks, Pipelines, Ponds

In operation

Out of service

Spares

In stock