



CONTAINMENT EXTENDS UNDER ALL CHROME TREATMENT FACILITY EQUIPMENT

GENERAL NOTE:

- FOR PROCESS INTERLOCK NOTES, SEE DWG 1373-PID-N100.

M-3A/B	T-3A/B	C-3	T-5	P-5A/B
FLASH/FLOC MIXER	FLASH/FLOC TANK	INCLINED PLATE SEPARATOR	EFFLUENT TANK	EFFLUENT PUMP
TYPE: TOP MOUNT MOTOR: 0.5 HP, 460V	CAPACITY: 70-500 GAL. DIMENSIONS: 8'-4" x 4'-3" MAT'L: PAINTED CARBON STEEL	FLOW: 350 GPM PROTECTED AREA: 840 SQ. FT. DIMENSIONS: 15'-8"L x 8'-0"W x 22'-5"H	CAPACITY: 8,400 GAL. DIMENSIONS: 8' x 8' x 25'-8" MAT'L: PAINTED CARBON STEEL	TYPE: CENTRIFUGAL CAPACITY: 300 GPM @ 28' TDH MOTOR: INVERTER DUTY 5 HP, 230/460V, 3ø, 60Hz MODEL: GOULDS 3196

DESIGNED BY/DATE	DW 08-09-16	DRAWING SCALE	N/A
DRAWN BY/DATE	DL 08-12-16	ISSUED FOR NDEP REVIEW	08-22-16
CHECKED BY/DATE	DW 08-12-16	DESCRIPTION OF REVISION	
THIS IS A COMPUTER GENERATED DRAWING AND ONLY EDITS CONSISTENT WITH ENVIROGEN'S ORIGINAL CAD FORMAT SHALL BE CONSIDERED VALID COPIES.			

THIS DRAWING IS A VISUAL REPRESENTATION OF THE EQUIPMENT AND/OR SYSTEM PROPOSED. IT IS NOT INTENDED FOR CONSTRUCTION PURPOSES.



ALL INFORMATION CONTAINED ON THIS DOCUMENT IS THE PROPERTY OF ENVIROGEN TECHNOLOGIES, INC. ("ENVIROGEN") AND/OR ITS AFFILIATES. THE DESIGN CONCEPTS AND INFORMATION CONTAINED HEREIN ARE PROPERTY OF ENVIROGEN AND ARE SUBMITTED IN CONFIDENCE. THEY ARE NOT TRANSFERABLE AND MUST BE USED ONLY FOR THE USE AND PROJECT FOR WHICH THE DOCUMENT IS EXPRESSLY SUBMITTED. THEY MUST NOT BE DISCLOSED, REPRODUCED, LOANED OR USED IN ANY OTHER MANNER WITHOUT THE EXPRESS WRITTEN CONSENT OF ENVIROGEN. ENVIROGEN ASSUMES NO RESPONSIBILITY OR LIABILITY FOR THE USE OF THIS DOCUMENT OR THE DESIGN CONCEPTS AND INFORMATION CONTAINED HEREIN FOR ANOTHER PROJECT, OR IN A MANNER THAT DOES NOT RELATE TO THE ORIGINALLY INTENDED USE OF THIS DOCUMENT. IN NO EVENT SHALL THIS DOCUMENT OR THE DESIGN CONCEPTS AND INFORMATION CONTAINED HEREIN BE USED IN ANY MANNER DETRIMENTAL TO THE INTEREST OF ENVIROGEN. THE RIGHTS AND OBLIGATIONS OF ENVIROGEN AND ITS CUSTOMER ARE FURTHER LIMITED IN THE AGREEMENT BETWEEN THEM FOR THIS PROJECT. ALL PATENT AND OTHER RIGHTS ARE RESERVED. ACCEPTANCE OF THE DELIVERY OF THIS DOCUMENT CONSTITUTES AGREEMENT TO THESE TERMS AND CONDITIONS.

NERT
HENDERSON, NV.

**PIPING AND INSTRUMENTATION DIAGRAM
CLARIFICATION AND SOLIDS REMOVAL
REPLACEMENT CHROMIUM TREATMENT FACILITY**

SHEET 1 OF 1
DRAWING # 1373-PID-P102
REF # 1373-PID-P102-A