

То:	Nevada Division of Environmental Protection Nevada Environmental Response Trust
Cc:	Nevada Environmental Response Trust Stakeholders
From:	Michael Del Vecchio, Director of Engineering and Project Management
Date:	January 27, 2025
Subject:	NERT –GWETS Operation Monthly Report –December 2024

At the request of the Nevada Environmental Response Trust (Trust), Envirogen Technologies, Inc. (ETI) is providing this summary of the groundwater extraction and treatment system (GWETS) operation and performance during December 2024.

Summary of GWETS Operation

Envirogen Technologies, Inc. (ETI) mechanically operated the GWETS and ion exchange (IX) system normally in December 2024. Flow from PC-118, PC-119, PC-120, PC-121, and PC-133 were routed to the IX system, bypassing all flow meters associated with the FBR plant for December. The flow rate to the IX system averaged approximately 251 gallons per minute (gpm). The flow rate to the FBR plant averaged approximately 910 gpm. At the end of the month, the filled GW-11 Pond volume was at 36.3 million gallons (MG), which would allow 18.2 days of additional storage in the event of an emergency FBR plant shutdown with continued well-field pumping. The water volume stored in the GW-11 Pond has increased since November 2024; Figure 1 in this report depicts the actual GW-11 pond volumes and additional storage available.

The influent perchlorate concentration in the IX system averaged 1.2 mg/L for the month, and the concentration in the FBR plant averaged 46 mg/L for the month, with a maximum concentration of 52 mg/L.

During December, ETI continued implementing a preventative maintenance program to refurbish all front and back- side FBRs. Through this program, FBRs will be systematically emptied and dismantled to determine the extent of refurbishment. Additional information on this program is presented later in this report.

Enhanced Operational Metrics

Tables 1 and 2 summarize the current GWETS operational metrics data for flow rates, perchlorate and chromium concentrations, and mass removal. Figure 2 graphically presents historical perchlorate mass flux information. Attachment A summarizes the NPDES permit analytes with numerical discharge limits.

Operational Issues

All routine plant repairs conducted by ETI were performed in accordance with the NERT Perchlorate Treatment System Operations Manual. The following is a list of operational issues, major repairs, and/or equipment replaced during this reporting period.

1. GW-11

There were no operational issues with GW-11 in December.

2. Biological Plant

There were influent/effluent diversions during the reporting period associated with general maintenance or FBR refurbishment activities as well as extraction well short-term shutdown events. Below is a description of the events that occurred:

Diversion Events/Well Shutdowns

- An effluent diversion occurred on December 7, 2024, from 10:16 pm to 11:09 pm, due to a high turbidity reading. Adjustments to the plant were made, laboratory testing was completed, effluent compliance was confirmed, and the effluent was discharged into the outfall.
- An influent diversion occurred on December 11, 2024, from 11:52 pm to 1:16 am, due to a PLC fault. The maintenance team replaced a failed uninterruptible power supply (UPS), and the plant resumed normal operations.
- LS-1, SWF, and IX were shut down for scheduled generator maintenance on December 20, 2024, from 1:13 pm to 1:50 pm. The preventive maintenance for the generator was completed and the SWF and IX returned to normal operations.
- Scheduled PLC maintenance for LS-2 occurred on December 20, 2024, from 2:26 PM to 2:59 PM. LS-1, IX, LS-3, and SWF and AWF wells were shut down during this period. The maintenance team completed the necessary calibrations and repairs. Following this maintenance, LS-1, LS-2, IX, LS-3, and SWF and AWF wells resumed normal operations.

3. IXTreatment Plant

The concentration of perchlorate in shallow groundwater remains elevated in the western wells of the SWF. This increase is a result of the City of Henderson (City) discharging water to Birding Ponds 10 through 13 from late August through October 2023. The perchlorate concentrations in groundwater adjacent to the western leg of the SWF are expected to remain elevated for an extended period as a result of this activity.

4. Treatment System Extension (TSE)

In December 2024, operations at the TSE plant continued to be idle. In July 2024, NERT developed a new version of the Cooperative Agreement to facilitate system restart and provided it to TIMET for their review. While NERT has conceptually discussed the TSE restart with TIMET, TIMET has yet to provide comments to NERT. The timeline for restarting the system will be established during the negotiation of the updated Cooperative Agreement.

5. Effluent Filtration System(EFS)

During December 2024, the EFS operated normally and produced approximately 446,400 gallons of filtered GWETS effluent, which supported the utility water requirements of GWETS operations.

6. Chromium Treatment Subsystem(CTS)

During December 2024, The CTS operated normally and treated approximately 2,423,269 gallons of groundwater.

7. Spills

There were no reportable spills during December.

8. Maintenance

Major maintenance performed by ETI in the reporting month included:

- I. Three combo valves were replaced on the effluent pipeline.
- II. The network cable on the (VFD) at Lift Station 1 (LS-1) has been replaced.
- III. An air pressure sensor for the plant's air supply was installed and programmed into the SCADA.
- IV. Maintenance replaced the 200-amp circuit breaker for the influent pump.
- V. A temporary repair of a leak in FBR 2 was completed.
- VI. The media return pump on Separator 2 has been replaced.
- VII. The north sump pump was replaced.

Preventative maintenance performed by ETI in the reporting month included:

- I. The effluent pipeline combo valves were inspected for leaks.
- II. The primary sump pump and vault were inspected and cleaned.
- III. The TSE plant was inspected.
- IV. The control valves at the EQ were inspected.
- V. The backstage equipment was inspected (FBR, Separators, DAF, T-621).
- VI. Cleaned and inspected the recycle pump strainers.
- VII. Inspected LS-3 equipment and area security.

FBR Refurbishment

I. The refurbishment of FBR 7 is currently in progress.

Facility Projects

- Facility Repair/Replacement Items Envirogen and the Trust have finalized a list of facility items to be addressed in connection with Amendment 8 to the O&M Agreement. All work except for the replacement of the DAF and concrete repairs has been completed. Specific details on inprogress items are provided below:
 - A (WA23-03) Dissolved Air Flotation(DAF) Vessel replacement
 - 1. The replacement DAF was delivered in December 2023. Installation began in September 2024 and will be completed in January 2025.
 - B Concrete Repair at various locations on the FBR pad
 - 1. Work will be completed in January 2025.
- 2. Improved Biological Treatment Plant Efficiency Consistent with Attachment D to the December 2021 GWETS Operation Monthly Report, Envirogen plans to take three FBRs out of service and maintain them in working condition should they be needed. This action will reduce electricity and water use while maintaining sufficient treatment capacity to address current groundwater extracted from the IWF, AWF, and SWF. FBR A was placed into offline mode on April 13, 2022. After the ongoing FBR refurbishment, the remaining four FBRs scheduled to be taken out of service will be addressed in the 2nd quarter of 2025.

Tables

Operational Metrics

Nevada Environmental Response T	rust Groundwater Extraction	n and Treatment System I	Monthly Stakeholder Metrics	
Location ID	Average Flow Rate (gpm) ⁶	Perchlorate (mg/L) ⁷	Chromium (TR) (mg/L) ⁷	Chromium(VI) (mg/L) ⁷
SWF Total Extraction ^{1,2}	718	11	0.00092	0.0034
AWF Total Extraction ^{1,2}	424	48	0.13	0.13
IWF Total Extraction ^{1,2}	47	297	5.7	5.3
AP Area Total Extraction ^{1,2}	7.7	492	0.18	0.18
Chromium Treatment Subsystem Effluent ^{3,4}	56	336	1.6	ND
GW-11 Influent ^{1,2}	0.34	31	0.065	0.062
FBR Influent ^{3,4}	910	46	0.11	0.048
Treatment System Extension Influent ^{3,4,5}	0.0	0.0	0.0	0.0

Notes:

ND = Not detected above laboratory method detection limit (Cr(VI)= $0.25 \mu g/L$).

- 1: Perchlorate and Chromium TR sampled monthly, values reported from Eurofins TestAmerica.
- 2: Chromium (VI) sampled monthly, values reported from Pace National.
- ${\tt 3: Perchlorate and Chromium \, TR \, sampled \, weekly, \, values \, reported \, from \, Eurofins \, Test America.}$
- 4: Chromium (VI) sampled weekly, values reported from Pace National.
- 5: TSE offline from 12/01 to 12/31.
- 6: Sum of daily average flow for individual wells.
- 7: All concentrations reported are monthly flow weighted averages.

Nevada Environmental Response Tru	ust I Groundwater Extraction and Tre	atment System I Monthly Stakehold	ler Metrics
Location ID	Perchlorate (lbs/month) ¹	Chromium (TR) (lbs/month) ¹	Chromium (VI) (lbs/month) ¹
SWF Total Extraction	2,374	0.20	0.75
AWF Total Extraction	7,528	20	20
IWF Total Extraction	5,226	100	93
AP Area Total Extraction	1,415	0.52	0.50
Chromium Treatment Subsystem Effluent	6,955	34	ND
GW-11 Influent	31	0.065	0.062
FBR Influent ¹	15,694	36	16
Treatment System Extension Influent ^{1,2}	0.0	0.0	0.0

Notes:

ND = Not detected above laboratory method detection limit (Cr(VI)= $0.25~\mu g/L$).

TR = Total Recoverable.

1: Total mass extracted is calculated from flow weighted average concentration and average flow (see Table 1).

2: TSE offline from 12/01 to 12/31.

Figures

Operational Metrics

Figure 1 - GW-11 Pond Volume Through 12/31/2024





Figure Updated: 1/7/2025

Figure 2 - Historical Perchlorate Mass Removed From Environment



Attachment A

NPDES Tracking Sheet (Prepared by Ramboll)

										Trea	ated Effluent at Ou	tfall 001							
	Con	tinuous	Daily Samples, con	nposited weekly							Weekly Grab S	amples				Weekly	, collected sep	arately	Quarterly
	Flo	w Rate	Perchlo	orate	р	Н	Hexavalent Chromium	Total Chromium	Manganese	Total Iron	Total Inorganic Nitrogen (TIN)	Total Susper		Total Ammonia as N	Total Phosphorus as P		BOD₅ (inhibited)	Total Dissolved Solids (TDS)
	30-Day Avg. (MGD)	Daily Maximum (MGD)	30-Day Avg. (μg/L)	30-Day Avg. (Ibs/day)	Daily Min. (S.U.)	Daily Max. (S.U.)	Daily Max. (μg/L)	Daily Max. (μg/L)	Daily Max. (μg/L)	Daily Max. (μg/L)	Daily Max. (mg/L)	30-Day Avg. (mg/L)	30-Day Avg. (lbs/day)	30-Day Avg. (Ibs/day)	30-Day Avg. (lbs/day)	30-Day Avg (mg/L)	. Daily Max. (mg/L)	30-Day Avg. (lbs/day)	Daily Max. (mg/L)
	2.52	2.88	18	0.38	6.5	9.0	10	100	5,000	10,000	20	135	2,839	20*	10*	25	40	525	8,000
January 2024	1.76	1.85	ND (<1.6)	0.012	6.98	7.21	ND (<0.150)	12	320	1200	1.8	20	280	1.8	5.3	4.7	13	63	
February 2024	1.35	1.88	ND (<1.6)	0.009	7.20	7.26	ND (<0.150)	35	310	1900	5.9	18	210	0.4	4.9	ND (<5.0)	ND (<5.0)	29	3,900
March 2024	1.59	1.85	ND (<1.6)	0.011	7.04	7.40	ND (<0.150)	59	430	1000	0.87	16	210	0.8	5.8	ND (<5.0)	ND (<5.0)	34	
April 2024	1.66	1.77	ND (<1.6)	0.011	7.04	7.15	0.414	57	420	1100	1.1	20	260	2.2	2.7	ND (<5.0)	ND (<5.0)	34	
May 2024	1.54	1.83	2.0	0.026	6.68	7.25	ND (<0.200)	39	580	1100	1.7	14	190	1.7	2.6	ND (<5.0)	ND (<5.0)	33	4,300
June 2024	1.74	1.85	0.9	0.013	6.92	7.22	ND (<0.200)	15	340	1000	2.5	19	280	2.8	3.3	3.4	6.2	51	
July 2024	1.62	1.86	ND (<1.6)	0.011	7.10	7.21	ND (<0.200)	19	430	1400	1.2	20	280	1.5	2.5	2.9	4.4	39	
August 2024	1.47	1.66	ND (<1.6)	0.010	6.85	7.18	0.225	10	420	1700	0.78	12	150	2.0	2.2	ND (<5.0)	ND (<5.0)	31	4,500
September 2024	1.47	1.67	ND (<1.6)	0.010	6.88	7.13	ND (<0.200)	26	470	500	0.59	18	250	1.1	1.4	ND (<5.0)	ND (<5.0)	34	
October 2024	1.68	1.86	ND (<1.6)	0.011	6.62	6.98	ND (<0.200)	21	450	1300	0.73	17	230	2.2	3.4	ND (<5.0)	ND (<5.0)	34	
November 2024	1.64	1.86	ND (<1.6)	0.011	6.89	7.10	ND (<0.200)	21	500	1400	0.63	18	240	2.0	4.1	ND (<5.0)	ND (<5.0)	34	4,300
December 2024	1.66	1.74	ND (<1.6)	0.011	6.88	7.34	ND (<0.200)	16	450	1400	0.73	13	180	1,5	2.8	ND (<5.0)	ND (<5.0)	35	

Daily Grab Sample Dates	Composite Sample Date	μg/L		lbs/day	Sample Date	S.U.	μg/L	μg/L	μg/L	μg/L	mg/L	mg/L		lbs/day	mg/	/L	lbs/day	mg/L		lbs/day	Sample Date	mg/L		lbs/day	Sample Date	mg/L
12/31 - 1/6	1/6/2024	ND (<1.6)	0.8	0.012	1/3/2024	6.98	ND (<0.150)	12	260	830	0.89		16	233		0.12	1.7		0.44	6.4	1/3/2024	ND (<5.0)	2.5	36		
1/7 - 1/13	1/13/2024	ND (<1.6)	0.8	0.012	1/10/2024	7.18	ND (<0.150)	11	310	590	0.72		19	268		0.13	1.8		0.48	6.8	1/10/2024	ND (<5.0)	2.5	35		
1/14 - 1/20	1/20/2024	ND (<1.6)	0.8	0.012	1/17/2024	7.01	ND (<0.150)	12	320	1200	0.80		28	358		0.071	0.9		0.47	6.0	1/17/2024	Footnote 1	13	171		
1/21 - 1/27	1/27/2024	,	0.8	0.012	1/24/2024	7.21	ND (<0.150)	5.0	280	360	1.8		17	251		0.27	4.0		0.29	4.3	1/24/2024	ND (<5.0)	2.5	37		
1/28 - 2/3	2/3/2024	, -,	0.8	0.011	1/31/2024	7.12	ND (<0.150)	8.3	270	770	0.63		20	296	ND (<0.039)	0.0195	0.3		0.19	2.8	1/31/2024	ND (<5.0)	2.5	37		
2/4 - 2/10	2/10/2024		0.8	0.011	2/7/2024	7.20	ND (<0.150)	35	290	1900	0.81		23	279		0.051	0.6	Footnote 2	0.69	8.4	2/7/2024	ND (<5.0)	2.5	30		
2/11 - 2/17	2/17/2024	. ,	0.8	0.009	2/14/2024	7.24	ND (<0.150)	8.8	310	1100	5.9		20	240	ND (<0.039)	0.0195	0.2		0.51	6.1	2/14/2024	ND (<5.0)	2.5	30		
2/18 - 2/24	2/24/2024		0.8	0.010	2/22/2024	7.24	ND (<0.150)	18	220	950	0.63		13	191	ND (<0.039)	0.0195	0.3		0.17	2.5	2/22/2024	ND (<5.0)	2.5	37	2/22/2024	3,900
2/25 - 3/2	3/2/2024		8.0	0.005	2/29/2024	7.26	ND (<0.150)	15	160	1800	1.50		16	114		0.045	0.3		0.36	2.6	2/29/2024	ND (<5.0)	2.5	18		
3/3 - 3/9	3/9/2024		0.8	0.009	3/7/2024	7.40	ND (<0.150)	17	290	440	0.69		14	140		0.059	0.6	Footnote 3	1.5	14.6	3/7/2024	ND (<5.0)	2.5	25		
3/10 - 3/16	3/16/2024	. ,	0.8	0.011	3/13/2024	7.11	ND (<0.150)	15	430	710	0.80		25	358		0.13	1.9		0.40	5.7	3/13/2024	ND (<5.0)	2.5	36		
3/17 - 3/23	3/23/2024		0.8	0.012	3/20/2024	7.04	ND (<0.150)	25	430	1000	0.84		11	165	ND (<0.039)	0.0195	0.3		0.046	0.7	3/20/2024	ND (<5.0)	2.5	37		
3/24 - 3/30	3/30/2024	. ,	0.8	0.012	3/27/2024	7.37	ND (<0.150)	59	430	940	0.87		12	181	ND (<0.039)	0.0195	0.3		0.15	2.3	3/27/2024	ND (<5.0)	2.5	38		
3/31 - 4/6	4/6/2024	. ,	0.8	0.011	4/3/2024	7.09	ND (<0.150)	44	420	1100	0.98		19	264		0.15	2.1		0.21	2.9	4/3/2024	ND (<5.0)	2.5	35		
4/7 - 4/13	4/13/2024	. ,	0.8	0.011	4/10/2024	7.10	0.414	57	330	970	0.98		28	346		0.16	2.0		0.23	2.8	4/10/2024	ND (<5.0)	2.5	31		
4/14 - 4/20	4/20/2024	,	0.8	0.012	4/17/2024	7.04	ND (<0.150)	26	360	740	1.1		13	192		0.21	3.1		0.21	3.1	4/17/2024	ND (<5.0)	2.5	37		
4/21 - 4/27	4/27/2024	,	0.8	0.011	4/24/2024	7.15	ND (<0.150)	42	360	840	1.1		18	244		0.11	1.5		0.13	1.8	4/24/2024	ND (<5.0)	2.5	34		
4/28 - 5/4	5/4/2024	,	0.8	0.010	5/1/2024	7.06	ND (<0.150)	33	380	600	0.20	ND (<10)	5	53		0.20	2.1		0.21	2.2	5/1/2024	ND (<5.0)	2.5	27		
5/5 - 5/11	5/11/2024	. ,	0.8	0.009	5/8/2024	6.68	ND (<0.150)	18	420	930	1.2		23	287		0.084	1.0		0.21	2.6	5/8/2024	ND (<5.0)	2.5	31		
5/12 - 5/18	5/18/2024		0.8	0.010	5/15/2024	7.22	ND (<0.150)	1.3	360	910	1.7		14	187	ND (<0.039)	0.0195	0.3		0.21	2.8	5/15/2024	ND (<5.0)	2.5	33		
5/19 - 5/25	5/25/2024		6.7	0.088	5/22/2024	7.25	ND (<0.200)	39	580	1100	0.46		18	246	ND (<0.039)	0.0195	0.3	-	0.19	2.6	5/22/2024	ND (<5.0)	2.5	34	5/22/2024	4,300
5/26 - 6/1	6/1/2024	\ -/	0.8	0.012	5/29/2024	7.19	ND (<0.200)	11	280	650	0.99		12	182		0.30	4.6		0.18	2.7	5/29/2024	ND (<5.0)	2.5	38		
6/2 - 6/8	6/8/2024	. ,	0.8	0.012	6/4/2024	7.20	ND (<0.200)	9.2	230	790	2.5		26	399		0.29	4.4		0.23	3.5	6/4/2024	ND (<5.0)	2.5	38		
6/9 - 6/15	6/15/2024		1.3	0.018	6/11/2024	7.14	ND (<0.200)	15	260	670	2.1		15	217		0.31	4.5		0.29	4.2	6/11/2024	ND (<5.0)	2.5	36		
6/16 - 6/22	6/22/2024		0.8	0.011	6/18/2024	6.92	ND (<0.200)	11	340	560	0.81		18	272		0.042	0.6	-	0.19	2.9	6/18/2024	ND (<5.0)	2.5	38		
6/23 - 6/29	6/29/2024	. ,	0.8	0.012	6/25/2024	7.22	ND (<0.200)	12	300	1000	1.0		17	248		0.12	1.8		0.19	2.8	Footnote 4	Footnote 5	6.2	91		
6/30 - 7/6	7/6/2024		0.8	0.012	7/2/2024	7.12	ND (<0.200)	13	340	880	1.2		18	278		0.10	1.5		0.27	4.2	7/2/2024	ND (<5.0)	2.5	39		
7/7 - 7/13	7/13/2024		0.8	0.010	7/9/2024	7.13	ND (<0.200)	6.7	320	1200	0.91		34	501		0.14	2.1		0.18	2.7	7/9/2024	ND (<5.0)	2.5	37		
7/14 - 7/20	7/20/2024		0.8	0.011	7/16/2024	7.21	ND (<0.200)	6.3	270	520	0.46		12	154	ND (<0.039)	0.0195	0.2		0.090	1.2	7/16/2024	ND (<5.0)	2.5	32		
7/21 - 7/27	7/27/2024	,	0.8	0.010	7/23/2024	7.10	ND (<0.200)	19 17	340	1400	0.75		20	270	ND (<0.039)	0.0195	0.3		0.16	2.2	7/23/2024	ND (<5.0)	2.5	34 51		
7/28 - 8/3	8/3/2024	. ,	0.8	0.011	7/30/2024	7.13	ND (<0.200)		430	890	0.34		17	199		0.28	3.3		0.20	2.3	7/30/2024	Footnote 6	4.4		1	
8/4 - 8/10	8/10/2024		0.8	0.010	8/6/2024	6.90	0.225	10	420	930	0.71		13	142		0.22	2.4		0.18	2.0	8/6/2024	ND (<5.0)	2.5	27		
8/11 - 8/17	8/17/2024		0.8	0.009	8/13/2024	7.03	ND (<0.200)	8.5	280	570	0.78	ND (<10)	5	65		0.16	2.1		0.17	2.2	8/13/2024	ND (<5.0)	2.5	32	8/13/2024	4,500
8/18 - 8/24	8/24/2024		0.8	0.010	8/20/2024	7.18	ND (<0.150)	9.4	290	590	0.69	-	10	127	 ND (+0.030)	0.25	3.2		0.15	1.9	8/20/2024	ND (<5.0)	2.5 2.5	32		
8/25 - 8/31	8/31/2024	. ,	0.8	0.010	8/27/2024	6.85	ND (<0.150)	6.9	320	1700	0.36		19	259	ND (<0.039)	0.0195	0.3		0.20	2.7	8/29/2024	ND (<5.0)		34	1	
9/1 - 9/7	9/7/2024	. ,	0.8	0.011	9/3/2024	7.02	ND (<0.200)	5.8	280	360	0.59		14	192	 ND (+0.030)	0.13	1.8		0.090	1.2	9/3/2024	ND (<5.0)	2.5	34 35		
9/8 - 9/14	9/14/2024		0.8	0.011 0.010	9/10/2024	6.88 7.13	ND (<0.200)	26 22	330 470	470 470	0.43		18 16	250 217	ND (<0.039)	0.0195 0.0195	0.3 0.3		0.10 0.10	1.4 1.4	9/10/2024 9/17/2024	ND (<5.0)	2.5 2.5	35 34		
9/15 - 9/21 9/22 - 9/28	9/21/2024 9/28/2024		0.8	0.010	9/17/2024 9/25/2024	7.13 6.89	ND (<0.200) ND (<0.200)	<3.1	470 330	470 500	0.31 0.44		16 24	331	ND (<0.039)	0.0195	1.9		0.10	1.4	9/17/2024 9/25/2024	ND (<5.0) ND (<5.0)	2.5	34 34		
9/22 - 9/28	10/5/2024	. ,	0.8	0.009		6.89		8.5	450	440	0.73	ND (<10)	5	52		0.14	2.5		0.11	2.0		, ,	2.5	26	+	
		. ,	0.8		10/1/2024		ND (<0.200)	8.5 17				. ,	22	312				-	0.19	4.0	10/1/2024	ND (<5.0)	2.5			
10/6 - 10/12	10/12/2024	,	0.8	0.011 0.011	10/9/2024 10/15/2024	6.62 6.70	ND (<0.200)	17	390 290	1300 850	0.68 0.61	-	18	312 266		0.30	4.3 2.5	-	0.28	4.0	10/9/2024 10/15/2024	ND (<5.0)		35 37		
10/13 - 10/19 10/20 - 10/26	10/19/2024 10/26/2024	,	0.8	0.011	10/15/2024	6.98	ND (<0.200)	13 21	290 350	1200	0.61		20	266 298	 ND (<0.039)	0.17 0.0195	0.3		0.27	4.0 5.1	10/15/2024	ND (<5.0)	2.5 2.5	37 37		
10/20 - 10/26	11/2/2024	. ,	0.8	0.012	10/23/2024	6.88	ND (<0.200) ND (<0.200)	13	350 310	810	0.36		20 18	298 243	ND (<0.039)	0.0195	1.3		0.34	2.0	10/23/2024	ND (<5.0) ND (<5.0)	2.5	37 34		
11/3 - 11/9	11/9/2024		0.8	0.012	11/5/2024	6.89	ND (<0.200)	16	320	1000	0.46		15	202		0.093	1.9		0.13	2.6	11/5/2024	ND (<5.0)	2.5	34	+ +	
				0.011						970			15 24	202 328					0.19	2.6 7.9				34 34		
11/10 - 11/16	11/16/2024	. ,	0.8	0.011	11/12/2024	6.92 7.10	ND (<0.200)	21	300 280	1400	0.54 0.63		24 14	328 199		0.18 0.24	2.5 3.4		0.58	7.9 3.5	11/12/2024	ND (<5.0)	2.5	34 35	11/20/2021	4.300
11/17 - 11/23 11/24 - 11/30	11/23/2024 11/30/2024		0.8	0.011	11/20/2024 11/26/2024	7.10 7.08	ND (<0.200) ND (<0.200)	16 13	280 500	1400 960	0.63		14 19	199 250	 ND (<0.039)	0.24	0.3		0.25	3.5 2.5	11/20/2024 11/26/2024	ND (<5.0) ND (<5.0)	2.5 2.5	35 33	11/20/2024	4,300
		. ,					, ,								140 (<0.033)										+ +	
12/1 - 12/7	12/7/2024		0.8	0.011	12/3/2024	6.99	ND (<0.200)	13	450	760	NS ⁷		11	156		0.091	1.3		0.15	2.1	12/3/2024	ND (<5.0)	2.5	36		
12/8 - 12/14	12/14/2024	. ,	0.8	0.011	12/10/2024	7.34	ND (<0.200)	10	380	1100	0.66		20	280		0.10	1.4		0.20	2.8	12/10/2024	ND (<5.0)	2.5	35		
12/15 - 12/21	12/21/2024	,	0.8	0.011	12/17/2024	7.30	ND (<0.200)	16	380	1400	0.72		10	134		0.11	1.5	-	0.22	2.9	12/17/2024	ND (<5.0)	2.5	33		
12/22 - 12/28	12/28/2024	ND (<1.6)	8.0	0.011	12/26/2024	6.88	ND (<0.200)	13	350	1000	0.73		10	142		0.14	2.0		0.23	3.3	12/26/2024	ND (<5.0)	2.5	35		

Note: Analytical responsibilities are performed by Eurofins Environment Testing (Eurofins) in Phoenix, Arizona, and hexavalent chromium is analyzed by Pace Analytical (Pace) in Las Vegas, Nevada, unless otherwise indicated.

NA = Not Available To Date

ND = Not Detected above laboratory reporting limit; concentration in adjacent cell to right is one-half the reporting limit (per Permit condition)

NS = Not Sampled or Not Analyzed

NS = NOL Safripped on NOL Nationyzed.

- E Analytic detected; see column adjacent to right

* Total phosphorus discharge limitation of 10 lbs/day applies between March 1 and October 31; Ammonia discharge limitation of 20 lbs/day applies between April 1 and September 30; no limits apply the rest of the year.

¹ Average of 8.6 mg/L and 18.25 mg/L (rerun duplicates detected 34 mg/L and ND [<5.0 mg/L], respectively). ² Average of 0.73 mg/L and 0.655 mg/L (rerun duplicates detected 0.64 mg/L and 0.67 mg/L, respectively).

³ Average of 1.6 mg/L and 1.3 mg/L (rerun duplicates detected 1.3 mg/L and 1.3 mg/L, respectively).

⁴ Original sample taken 6/25/2024 was analyzed out of hold. Additional sample taken 6/28/2024.

⁵ Average of 2.5 mg/L (<5.0 mg/L) and 9.95 mg/L (additional sample detected 13 mg/L, and rerun duplicates detected 6.8 mg/L and 7.0 mg/L, respectively).

 $^{\rm 6}$ Average of 6.3 mg/L and 2.5 mg/L (rerun duplicates were both ND [<5.0 mg/L]).

⁷ The 12/3/2024 sample was received by the laboratory out of hold for Nitrate/Nitrite, so another sample was collected on 12/6/2024 for Nitrate/Nitrite analysis. Using the ammonia results from the 12/3/2024 sample and the Nitrate/Nitrite results from the 12/6/2024 sample, TIN was calculated to be 0.58 mg/L Last Updated: January 10, 2024

 $[\]ensuremath{^{\scriptscriptstyle +}}$ Additional samples were collected this week.

Attachment B

Equipment Tracking Form

GWETS- Equipment Tracking Form 12/31/2024 12:31

Sub- System	P&ID	Description	Status ¹	Checked	Criticality ²	
		Main Plant Equipment				
		Seep Wells and Lift Station 1				
1.01		Seep Well Field, 9 wells	Running			
1.02		Lift Station 1 Lift Pump A	Running		3	Replaced VFD Ethernet cables
1.03		Lift Station 1 Lift Pump B	Standby			
1.04		Area in and around Lift Station	Running			
		Athens Road Wells and Lift Station 3				
2.01		AthensRoad Well Field, 9 wells	Running			
2.02		Lift Station 3 Lift Pump A	Standby			
2.03		Lift Station 3 Lift Pump B	Running			
2.04		Area in and around Lift Station	Running			
		Lift Station 2 and Transmission Pipelines				
3.01		Influent Pipeline	Running			
3.02		Effluent Pipeline	Running			
3.03		Lift Station 2 Lift Pump A	Running			
3.04		Lift Station 2 Lift Pump B	Standby			
3.05		Area in and around Lift Station	Running			
		Interceptor Wells and Cr Treatment Plant				
4.01		IWF Well Field, 30 wells	Running			
4.02		Ferrous Sulfate Feed System	Running			
4.03		Polymer Feed System	Running			
4.04		Clarifier	Running			
4.05		Filter Press	Running			
4.06		GWTP Effluent Tank	Running			
4.07		Interceptor Booster Pump	Running			
4.08		Interceptor Booster Pump	Standby			
4.09		Area In And Around GWTP	Running			
		Equalization Area and GW-11 Pond				
5.01	PID10A	Pond GW-11	Running			
5.02	PID10A	Pond Water Pump - P101A	Running			
5.03	PID10A	Pond Water Pump - P101B	Standby			
5.04	PID10A	Equalization Tanks	Running			
5.05	PID10A	Area in and Around EQ	Running			
5.06	PID10A	Raw Water Feed Pump - P102A	Standby		3	Replaced 200 amp Circuit Breaker
5.07	PID10A	Raw Water Feed Pump - P102B	Running			
5.08	PID10A	F-101 Filters	Running			
5.09	PID10B	Carbon Absorber - LGAC 201A	Offline			

Status Codes

- 1. Running Unit is in operation
- 2. Standby Spare or duplicate, not currently in operation
- 3. Maintenance Out of service for maintenance
- 4. Offline Not currently needed for use but can be placed in service.

- 1. Critical Cannot continue with operation until repairs made
- 2. Important Can still operate safety and in compliance with permits, but risk is increased
- 3. Moderate Work needs to be performed but plant can still operate with redundancy that is in place
- 4. Low Minor repairs that in no way alter the performance of the plant

GWETS- Equipment TrackingForm 12/31/2024 12:31

Sub- System	P&ID	Description	Status¹	Checked	Criticality ²	
5.10	PID10B	Carbon Absorber - LGAC 201B	Offline			
5.11	PID10B	Carbon Absorber - LGAC 201C	Offline			
		First Stage FBRs A, 1 & 2				
6.01	PID14	FBR	Offline			
6.02	PID14	Separator Tank - 1401	Offline			
6.03	PID14	Media Return Pump - P 1401	Offline			
6.04	PID14	P1401A	Offline			
6.05	PID01A	P1401B	Offline			
6.06	PID01A	FBR	Running			
6.07	PID02A	FBR	Standby			
6.08	PID01A	First Stage Separator Tank - T2011	Running			
6.09	PID01A	Media Return Pump - P2011	Running			
6.10	PID01A	First Stage FBR Pump - P1011	Standby			
6.11	PID01A	First Stage FBR Pump - P1012	Running			
6.12	PID01A	First Stage FRB Pump - P101A	Standby			
6.13	PID07A	FBR A pHFeed Pump - P71A	Offline			
6.14	PID07A	FBR 1 pH Feed Pump - P711	Offline			
6.15	PID07A	FBR 2 pH Feed Pump - P712	Offline			
6.16	PID07A	FBR A Nutrient (Urea) Feed Pump - P72A	Offline			
6.17	PID07A	FBR 1 Nutrient (Urea) Feed Pump - P721	Offline			
6.18	PID07A	FBR 2 Nutrient (Urea) Feed Pump - P722	Offline			
6.19	PID15	FBR A Nutrient (Phos Acid) Feed Pump - P1520A	Offline			
6.20	PID15	FBR 1 Nutrient (Phos Acid) Feed Pump - P1521	Running			
6.21	PID15	FBR 2 Nutrient (Phos Acid) Feed Pump - P1522	Running			
6.22	PID07B	FBR A Electron Donor Assembly Pump - P73A	Running			
6.23	PID07B	FBR 1 Electron Donor Assembly Pump - P731	Running			
6.24	PID07B	FBR 2 Electron Donor Assembly Pump - P732	Running			
		First Stage FBRs 3 & 4				
7.01	PID01B	FBR	Running			
7.02	PID01B	FBR	Running			
7.03	PID02B	First Stage Separator Tank - T2012	Running		3	Replaced media return pump
7.04	PID01B	Media Return Pump - P2012	Running			
7.05	PID01B	First Stage FBR Pump- P1013	Running			
7.06	PID01B	First Stage FRB Pump - P1014	Running			
7.07	PID01B	First Stage FBR Pump - P102A	Running			
7.08	PID07A	FBR 3 pH Feed Pump - P713	Running			
7.09	PID07A	FBR 4 pH Feed Pump - P714	Running			

Status Codes

- 1. Running Unit is in operation
- 2. Standby Spare or duplicate, not currently in operation
- 3. Maintenance Out of service for maintenance
- 4. Offline Not currently needed for use but can be placed in service.

- 1. Critical Cannot continue with operation until repairs made
- 2. Important Can still operate safety and in compliance with permits, but risk is increased
- 3. Moderate Work needs to be performed but plant can still operate with redundancy that is in place
- 4. Low Minor repairs that in no way alter the performance of the plant

GWETS- Equipment Tracking Form 12/31/2024 12:31

Sub- System	P&ID	Description	Status ¹	Checked	Criticality ²	
7.10	PID07A	FBR 3 Nutrient (Urea) Feed Pump - P723	Offline			
7.11	PID07A	FBR 4 Nutrient (Urea) Feed Pump - P724	Offline			
7.12	PID15	FBR 3 Nutrient (Phos Acid) Feed Pump - P1523	Running			
7.13	PID15	FBR 4 Nutrient (Phos Acid) Feed Pump - P1524	Running			
7.14	PID07B	FBR 3 Electron Donor Assembly Pump - P733	Running			
7.15	PID07B	FBR 4 Electron Donor Assembly Pump - P734	Running			
		Second Stage FBRs 5 & 6				
8.01	PID03A	FBR	Running			
8.02	PID03A	FBR	Running			
8.03	PID03C	Second Stage Separator Tank - T3011	Running			
8.04	PID03A	Media Return Pump - P3011	Running			
8.05	PID03A	Second Stage FBR Pump - P3015	Running			
8.06	PID03A	Second Stage FBR Pump - P3016	Standby			
8.07	PID03A	Second Stage FBR Pump - P301A	Running			
8.08	PID07A	FBR 5 pH Feed Pump - P715	Offline			
8.09	PID07A	FBR 6 pH Feed Pump - P716	Offline			
8.1	PID07A	FBR 5 Nutrient (Urea) Feed Pump - P725	Offline			
8.11	PID07A	FBR 6 Nutrient (Urea) Feed Pump - P726	Offline			
8.12	PID07B	FBR 5 Electron Donor Assembly Pump - P735	Running			
8.13	PID07B	FBR 6 Electron Donor Assembly Pump - P736	Running			
		Second Stage FBRs 7 & 8				
9.01	PID03B	FBR	Maintenance		3	FBR 7 down due to refurbishment
9.02	PID03B	FBR	Running			
9.03	PID03D	Second Stage Separator Tank - T3012	Running			
9.04	PID03B	Media Return Pump - P3012	Running			
9.05	PID03B	Second Stage FBR Pump - P3017	Maintenance		3	Out of service for factory pump rebuild
9.06	PID03B	Second Stage FBR Pump - P3018	Running			
9.07	PID03B	Second Stage FBR Pump - P302A	Running			
9.08	PID07A	FBR 7 pH Feed Pump - P717	Offline			
9.09	PID07A	FBR 8 pH Feed Pump - P718	Offline			
9.10	PID07A	FBR 7 Nutrient (Urea) Feed Pump - P727	Offline			
9.11	PID07A	FBR 8 Nutrient (Urea) Feed Pump - P728	Offline			
9.12	PID07B	FBR 7 Electron Donor Assembly Pump - P737	Running			
9.13	PID07B	FBR 8 Electron Donor Assembly Pump - P738	Running			
10		Aeration and DAF System				
10.01	PID04	Aeration Tank	Running			
10.02	PID04	Aeration Blower - B401	Running			

Status Codes

- 1. Running Unit is in operation
- 2. Standby Spare or duplicate, not currently in operation
- 3. Maintenance Out of service for maintenance
- 4. Offline Not currently needed for use but can be placed in service.

- 1. Critical Cannot continue with operation until repairs made
- 2. Important Can still operate safety and in compliance with permits, but risk is increased
- 3. Moderate Work needs to be performed but plant can still operate with redundancy that is in place
- 4. Low Minor repairs that in no way alter the performance of the plant

GWETS- Equipment Tracking Form 12/31/2024 12:31

Sub- System	P&ID	Description	Status¹	Checked	Criticality ²	
10.03	PID04	Bio filter	Running			
10.04	PID04	Nutrient Solution	Running			
10.05	PID04	Bio filter Sump	Running			
10.06	PID04	Nutrient Pump - P401	Running			
10.07	PID04	Bio filter Sump Pump - P402A	Standby			
10.09	PID04	Bio filter Blower	Running			
10.10	PID05	DAF Pressure Tanks	Running			
10.11	PID05	DAF Vessel - D501	Running			
10.12	PID05	DAF Pressure Pump - P501	Running			
10.13	PID05	DAF Float Pump - P502	Running			
10.14	PID05	DAF Vessel - D551	Offline		3	Offline due to New DAF installation
10.15	PID05	DAF Pressure Pump - P551	Offline		3	Offline due to New DAF installation
10.16	PID05	DAF Float Pump - P552	Running			
10.17	PID05	Screw Conveyer Drive	Standby			
10.18	PID05	Skimmer Drive	Running			
11		Pumping System (Old Effluent)				
11.01	PID06	Effluent Tank 601	Running			
11.02	PID06	Effluent Pump - P601	Standby			
11.03	PID06	Effluent Pump - P602	Running			
12		Sand Filter System				
12.01	PID17	Sand Filter	Running			
12.02	PID17	Filter Reject Tank	Running			
12.03	PID17	Filter Reject Pump - P1701A	Standby			
12.04	PID17	Filter Reject Pump - P1701B	Running			
13		EffluentTank and Pumping				
13.01	PID10C	UV Effluent Tank	Running			
13.02	PID10C	Effluent Booster Pump - P1302A	Running			
13.03	PID10C	Effluent Booster Pump - P1302B	Standby			
13.04	PID10C	Area Around Effluent and North D-	Running			
14		Solids Collection and Pressing System				
14.01	PID16	Sludge Storage Tank	Running			
14.02	PID16	Solids Storage Effluent Pump - P1601	Running			
14.03	PID16	Solids Cond. Tank	Running			
14.04	PID09	Sludge Mixer	Running			
14.05	PID09	Filter Press Pump - P901	Running			
14.06	PID09	Filter Press Pump - P902	Standby			
14.07	PID09	West Press	Standby		_	

Status Codes

- 1. Running Unit is in operation
- 2. Standby Spare or duplicate, not currently in operation
- 3. Maintenance Out of service for maintenance
- 4. Offline Not currently needed for use but can be placed in service.

- 1. Critical Cannot continue with operation until repairs made
- 2. Important Can still operate safety and in compliance with permits, but risk is increased
- 3. Moderate Work needs to be performed but plant can still operate with redundancy that is in place
- 4. Low Minor repairs that in no way alter the performance of the plant

GWETS- Equipment TrackingForm 12/31/2024 12:31

Sub-					
System	P&ID	Description	Status ¹	Checked	Criticality ²
14.08	PID09	East Press	Running		
14.09	PID09	Filtrate Tank	Running		
14.10	PID09	Filtrat Tank Effluent (recycle) Pump - P903	Running		
		Chemical System			
15		Electron Donor System			
15.01	PID07B	Electron Donor Tank	Running		
15.02	PID07B	Booster Pump P739A	Running		
15.03	PID07B	Booster Pump P739B	Standby		
17	PID07C	Micro Nutrient System	Running		
18	PID07C	Hydrogen Peroxide System	Running		
19	PID07C	De-Foam System	Running		
20	PID15	Nutrient (Phosphoric Acid) System (Tank only - pumps included in FBRs)	Running		
21	PID07A	Nutrient(Urea) System (Tank only - pumps included in FBRs)	Running		
22	PID07A	pHSystem (Tank and effluent pH feed pump only - other pumps included in FBRs)	Running		
23	PID07C	Ferric Chloride	Running		
24	PID07B	Polymer Systems - DAF	Running		
25	PID09	Polymer System - Solids Dewatering (2 tanks, 2 centrifugal pumps, mixer, volumetric feeder)	Running		
		Utility Systen			
26		Compressed Air System			
26.01	PID08	West Compressor	Running		
26.02	PID08	East Compressor	Standby		
26.03	PID08	O2 Compressor	Offline		
26.04	PID08	Compressed Air Receiver Tank	Running		
26.05	PID08	Air Dryer	Running		
26.06	PID08	Oil Removal Filter	Running		
26.07	PID08	Particulate Filter	Running		
27	PID16	Oxygen System	Offline		
28		GWETS Plant Controls/ Siemens Controls	Running		3
29		Well Control System/ Allen Bradley Controls	Running		
30		MCC FBR Pad	Running		
31		MCC in D-	Running		
32		MCC in EQ area	Running		

Status Codes

- 1. Running Unit is in operation
- 2. Standby Spare or duplicate, not currently in operation
- 3. Maintenance Out of service for maintenance
- 4. Offline Not currently needed for use but can be placed in service.

- 1. Critical Cannot continue with operation until repairs made
- 2. Important Can still operate safety and in compliance with permits, but risk is increased
- 3. Moderate Work needs to be performed but plant can still operate with redundancy that is in place
- 4. Low Minor repairs that in no way alter the performance of the plant

GWETS- Equipment TrackingForm 12/31/2024 12:31

Sub- System	P&ID	Description	Status ¹	Checked	Criticality ²	
		Miscellaneous System				
33		Operations Office/Network	Running			
34		Laboratory Analyzers	Running			
35		Security Systems	Running			
		Shelf Spare				
		Media Retum Pump Rebuild Kit	In stock			
		pH Feed Pump	In stock			
		Nutrient Feed Pump	In stock			
		Electron Donor Feed Pump	In stock			
		Phosphoric Acid Feed Pump	In stock			·
		Interceptor Well Pumps (4 each)	In stock			•
		Seep Well Pump (1 each, same as Athens so total of 2)	In stock		·	•
		AthensRoadWell Pump (1 each, same as Seep so total of 2)	In stock			

Status Codes

- 1. Running Unit is in operation
- 2. Standby Spare or duplicate, not currently in operation
- 3. Maintenance Out of service for maintenance
- 4. Offline Not currently needed for use but can be placed in service.

- 1. Critical Cannot continue with operation until repairs made
- 2. Important Can still operate safety and in compliance with permits, but risk is increased
- 3. Moderate Work needs to be performed but plant can still operate with redundancy that is in place
- 4. Low Minor repairs that in no way alter the performance of the plant